

VAN FERITMELEN, Turkey

WMO: 171700

Lat: 38.468N

Lon: 43.332E

Elev: 5480

StdP: 12.01

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.0	12.5	2.8	7.8	12.3	6.6	9.4	15.0	23.0	34.7	19.6	36.4	3.3	60	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.1	84.4	63.8	82.4	64.2	80.7	64.5	70.9	79.6	68.5	78.7	66.6	77.9	6.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.0	126.7	78.4	64.8	113.0	77.1	62.5	103.8	76.0	38.8	79.7	36.6	78.4	34.7	78.0	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.6	16.3	13.3	DB	4.0	89.5	4.6	3.3	0.7	91.9	-2.0	93.8	-4.5	95.7	-7.9	98.1	(4)
(5)			WB	2.9	72.7	4.5	2.7	-0.4	74.7	-3.0	76.3	-5.6	77.8	-8.8	79.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.4	28.5	29.8	37.0	46.4	55.3	63.8	70.4	70.7	62.9	52.9	41.0	32.4	(6)	
	DBStd	15.88	6.10	6.36	6.46	5.56	4.95	4.31	3.45	3.35	4.62	5.17	5.84	7.10	(7)	
	HDD50	2634	668	565	406	134	11	0	0	0	1	29	274	546	(8)	
	HDD65	6120	1133	985	868	558	303	71	3	2	90	375	721	1011	(9)	
	CDD50	2405	0	0	3	26	175	415	633	642	389	119	3	0	(10)	
	CDD65	414	0	0	0	0	2	36	170	178	28	0	0	0	(11)	
	CDH74	3801	0	0	0	1	10	261	1488	1749	290	2	0	0	(12)	
	CDH80	545	0	0	0	0	1	16	214	288	26	0	0	0	(13)	
(14) Wind	WSAvg	4.7	4.0	4.2	5.0	5.4	5.5	5.1	4.9	4.6	4.8	4.9	4.3	4.1	(14)	
(15) Precipitation	PrecAvg	15.4	1.4	1.4	1.7	2.2	1.9	0.7	0.2	0.1	0.5	1.9	1.9	1.5	(15)	
	PrecMax	21.4	4.6	4.9	3.9	5.3	6.6	3.3	1.1	1.5	2.6	5.0	5.4	5.4	(16)	
	PrecMin	10.6	0.3	0.2	0.2	0.4	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.2	(17)	
	PrecStd	2.9	0.8	0.9	0.7	1.1	1.2	0.7	0.2	0.3	0.7	1.2	1.2	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.7	46.8	60.8	68.1	75.0	82.3	87.6	88.1	82.8	72.3	58.8	51.9	(19)	
		MCWB	38.5	39.7	46.1	52.8	57.9	62.7	62.6	64.2	60.5	55.1	48.3	44.1	(20)	
	2%	DB	42.2	43.8	54.0	62.8	71.2	79.1	84.2	84.8	79.3	69.5	55.8	47.9	(21)	
		MCWB	36.8	38.0	43.7	50.6	56.5	61.5	64.0	64.1	60.2	55.0	46.7	41.1	(22)	
	5%	DB	39.6	41.3	50.2	59.3	68.2	77.0	82.3	82.7	77.1	66.6	53.8	45.0	(23)	
		MCWB	35.0	36.4	42.1	49.0	55.7	61.2	64.4	64.5	59.7	53.4	45.4	39.1	(24)	
	10%	DB	37.7	39.4	46.8	56.9	65.9	75.0	80.6	81.0	75.2	64.4	51.7	42.9	(25)	
		MCWB	33.6	35.2	40.5	48.1	54.9	60.7	65.2	64.7	58.6	52.3	44.1	37.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.6	41.0	47.5	56.1	62.1	69.6	74.4	74.7	67.3	60.0	51.0	46.2	(27)	
		MCDB	42.7	45.6	57.7	62.5	69.3	76.4	80.8	82.0	77.2	66.9	55.7	49.6	(28)	
	2%	WB	37.6	38.6	45.1	52.9	59.3	66.2	71.0	71.5	64.1	57.0	48.5	42.2	(29)	
		MCDB	40.6	42.3	52.9	60.0	67.7	75.1	79.3	80.6	75.3	66.5	54.1	46.2	(30)	
	5%	WB	35.8	37.0	43.1	50.4	57.4	64.2	68.9	68.8	61.8	54.9	46.5	40.0	(31)	
		MCDB	38.7	40.5	49.0	57.2	65.5	74.5	78.6	79.4	74.4	64.3	52.3	44.0	(32)	
	10%	WB	34.0	35.3	41.2	48.4	55.7	62.2	67.1	66.7	59.8	53.1	44.8	38.0	(33)	
		MCDB	37.0	38.7	46.1	55.5	64.0	72.8	77.9	78.9	73.3	62.7	50.6	42.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	15.3	14.8	14.4	15.5	17.5	20.3	20.7	22.1	21.8	19.2	17.1	15.7	(35)	
		MCDBR	14.3	14.7	17.5	18.9	20.4	22.2	22.7	23.5	23.8	21.9	19.1	15.9	(36)	
		MCWBR	10.4	10.5	10.8	11.4	12.2	14.7	15.9	16.5	15.5	13.5	12.3	11.3	(37)	
	5% WB	MCDBR	12.7	13.7	16.4	17.7	18.7	20.9	19.8	21.2	22.6	20.4	17.2	14.8	(38)	
		MCWBR	10.0	10.4	10.9	11.8	12.4	15.4	15.7	17.0	16.4	13.7	12.1	11.1	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.271	0.305	0.354	0.410	0.392	0.357	0.385	0.370	0.327	0.348	0.294	0.268	(40)	
	taud		2.316	2.289	2.233	2.107	2.234	2.380	2.304	2.333	2.446	2.340	2.467	2.402	(41)	
	Ebn at Noon		289	291	286	275	282	291	282	284	292	272	280	283	(42)	
	Edh at Noon		29	34	41	49	44	38	41	39	32	33	25	25	(43)	
(44) All-Sky Solar Radiation	RadAvg		795	1087	1371	1699	2027	2500	2476	2260	1870	1227	828	651	(44)	
	RadStd		62	77	116	146	137	157	90	89	91	84	95	80	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	-2.07	-3.01	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	+1.42	-0.72	-1.37	N/A	N/A	N/A	N/A

Nomenclature: See separate page