

VAN FERITMELEN, Turkey

WMO: 171700

Lat: 38.468N

Lon: 43.332E

Elev: 1670

StdP: 82.80

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.8	-10.8	-16.2	1.1	-11.0	-14.1	1.3	-9.5	10.3	1.5	8.7	2.4	1.5	60	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.3	29.1	17.7	28.0	17.9	27.1	18.0	21.6	26.4	20.3	25.9	19.2	25.5	2.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.0	18.1	25.8	18.2	16.1	25.0	16.9	14.8	24.4	72.3	26.5	67.2	25.8	62.9	25.6	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.3	6.0	DB	-15.5	31.9	2.6	1.8	-17.4	33.3	-18.9	34.3	-20.3	35.4	-22.2	36.7	(4)
(5)			WB	-16.2	22.6	2.5	1.5	-18.0	23.7	-19.5	24.6	-20.9	25.4	-22.7	26.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-2.0	-1.2	2.8	8.0	12.9	17.7	21.3	21.5	17.2	11.6	5.0	0.2	(6)	
	DBStd	8.82	3.39	3.54	3.59	3.09	2.75	2.40	1.92	1.86	2.57	2.87	3.24	3.95	(7)	
	HDD10.0	1463	371	314	226	74	6	0	0	0	1	16	152	303	(8)	
	HDD18.3	3400	629	547	482	310	168	39	2	1	50	208	401	562	(9)	
	CDD10.0	1336	0	0	2	14	97	231	352	357	216	66	2	0	(10)	
	CDD18.3	230	0	0	0	0	1	20	94	99	16	0	0	0	(11)	
	CDH23.3	2112	0	0	0	1	6	145	827	972	161	1	0	0	(12)	
	CDH26.7	303	0	0	0	0	1	9	119	160	14	0	0	0	(13)	
(14) Wind	WSAvg	2.1	1.8	1.9	2.3	2.4	2.4	2.3	2.2	2.1	2.1	2.2	1.9	1.8	(14)	
(15) Precipitation	PrecAvg	391	36	35	44	57	49	19	5	3	12	47	48	38	(15)	
	PrecMax	543	118	124	100	134	168	83	29	39	66	126	138	138	(16)	
	PrecMin	268	8	4	6	11	6	0	0	0	0	0	3	5	(17)	
	PrecStd	74	21	23	19	28	30	19	6	7	17	30	30	27	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.1	8.2	16.0	20.1	23.9	27.9	30.9	31.2	28.2	22.4	14.9	11.1	(19)	
		MCWB	3.6	4.3	7.8	11.5	14.4	17.0	17.0	17.9	15.8	12.8	9.0	6.7	(20)	
	2%	DB	5.6	6.5	12.2	17.1	21.8	26.2	29.0	29.3	26.3	20.9	13.2	8.8	(21)	
		MCWB	2.6	3.3	6.5	10.3	13.6	16.4	17.8	17.8	15.7	12.8	8.1	5.1	(22)	
	5%	DB	4.2	5.2	10.1	15.2	20.1	25.0	27.9	28.2	25.1	19.2	12.1	7.2	(23)	
		MCWB	1.6	2.5	5.6	9.4	13.1	16.2	18.0	18.1	15.4	11.9	7.4	3.9	(24)	
	10%	DB	3.2	4.1	8.2	13.8	18.8	23.9	27.0	27.2	24.0	18.0	11.0	6.1	(25)	
		MCWB	0.9	1.8	4.7	8.9	12.7	16.0	18.4	18.2	14.8	11.3	6.7	3.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.2	5.0	8.6	13.4	16.7	20.9	23.6	23.7	19.6	15.6	10.5	7.9	(27)	
		MCDB	5.9	7.6	14.3	16.9	20.7	24.7	27.1	27.8	25.1	19.4	13.2	9.8	(28)	
	2%	WB	3.1	3.7	7.3	11.6	15.1	19.0	21.7	21.9	17.8	13.9	9.1	5.6	(29)	
		MCDB	4.8	5.7	11.6	15.6	19.8	24.0	26.3	27.0	24.0	19.2	12.3	7.9	(30)	
	5%	WB	2.1	2.8	6.2	10.2	14.1	17.9	20.5	20.5	16.6	12.7	8.0	4.5	(31)	
		MCDB	3.7	4.7	9.5	14.0	18.6	23.6	25.9	26.3	23.6	17.9	11.3	6.7	(32)	
	10%	WB	1.1	1.9	5.1	9.1	13.2	16.8	19.5	19.3	15.4	11.7	7.1	3.3	(33)	
		MCDB	2.8	3.7	7.8	13.0	17.8	22.7	25.5	26.1	23.0	17.0	10.4	5.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	8.2	8.0	8.6	9.7	11.3	11.5	12.3	12.1	10.7	9.5	8.7	(35)	
		MCDBR	7.9	8.2	9.7	10.5	11.3	12.4	12.6	13.0	13.2	12.1	10.6	8.8	(36)	
	5% WB	MCWBR	5.8	5.9	6.0	6.3	6.8	8.2	8.8	9.2	8.6	7.5	6.9	6.3	(37)	
		MCWBR	7.1	7.6	9.1	9.8	10.4	11.6	11.0	11.8	12.6	11.4	9.6	8.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.271	0.305	0.354	0.410	0.392	0.357	0.385	0.370	0.327	0.348	0.294	0.268	(40)	
		taud	2.316	2.289	2.233	2.107	2.234	2.380	2.304	2.333	2.446	2.340	2.467	2.402	(41)	
	Ebn at Noon		911	918	901	867	889	918	889	896	921	858	882	892	(42)	
		Edh at Noon	91	108	128	155	139	120	129	122	102	103	79	78	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.51	3.43	4.32	5.36	6.39	7.88	7.80	7.12	5.89	3.87	2.61	2.05	(44)	
	RadStd		0.20	0.24	0.36	0.46	0.43	0.49	0.28	0.28	0.29	0.27	0.30	0.25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-1.15	-1.67	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	+0.79	-0.40	-0.76	N/A	N/A	N/A	N/A

Nomenclature: See separate page