

DIKILI, Turkey

WMO: 171800

Lat: 39.0739N

Lon: 26.8881E

Elev: 10

StdP: 14.69

Time Zone: 3.00 (E03)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.9	(c) 33.3	(d) 22.0	(e) 16.6	(f) 34.1	(g) 24.5	(h) 18.6	(i) 35.8	(j) 17.3	(k) 51.4	(l) 14.5	(m) 49.1	(n) 4.0	(o) 160	(p) 0.359

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	91.9	71.8	89.0	72.4	86.3	73.1	76.9	85.9	75.6	85.0	74.6	84.1	7.0	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.8	126.0	84.2	72.5	120.4	83.3	71.2	115.0	82.3	40.3	86.2	39.2	85.1	38.2	84.3	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.5	14.1	12.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			23.6	78.7	3.3	0.6	21.3	79.1	19.3	79.5	17.5	79.8	15.1	80.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.0	45.8	47.7	51.7	58.5	65.7	74.4	79.0	78.6	72.0	65.2	55.4	49.6	(6)
(7)		DBStd	12.84	6.09	6.20	5.86	5.72	5.33	4.12	3.40	3.70	4.14	5.66	6.44	7.19	(7)
(8)		HDD50	450	161	107	52	6	0	0	0	0	0	0	28	96	(8)
(9)		HDD65	2589	595	485	411	206	56	1	0	2	66	291	476	(9)	
(10)		CDD50	4847	30	42	106	262	486	731	898	887	661	470	189	85	(10)
(11)		CDD65	1512	0	0	0	12	77	283	433	422	212	71	1	1	(11)
(12)		CDH74	11608	0	0	0	27	276	1979	4035	3854	1176	260	1	0	(12)
(13)		CDH80	3395	0	0	0	2	43	436	1346	1315	224	29	0	0	(13)
(14)	Wind	WSAvg	5.1	4.3	4.9	5.2	5.2	5.7	6.0	5.6	5.4	5.3	4.4	4.5	4.9	(14)
(15)	Precipitation	PrecAvg	24.5	3.5	3.6	2.4	2.0	1.0	0.6	0.2	0.8	2.2	3.6	4.4	(15)	
(16)		PrecMax	35.6	8.4	8.9	6.2	4.6	3.6	1.5	0.5	1.3	3.0	7.2	9.4	11.5	(16)
(17)		PrecMin	14.8	0.0	0.4	0.2	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	(17)
(18)		PrecStd	5.7	2.3	2.2	1.4	0.9	0.9	0.5	0.1	0.2	0.9	1.9	2.4	2.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.9	64.6	70.2	77.9	84.9	92.2	95.4	96.4	90.1	83.4	71.9	67.2	(19)
MCWB			58.1	56.0	57.6	62.7	69.0	69.7	72.4	73.6	72.5	70.9	63.4	58.8	(20)	
2%		DB	60.7	61.6	66.2	73.2	79.5	87.5	92.3	91.5	85.1	79.8	69.7	64.5	(21)	
		MCWB	55.1	54.7	57.5	62.1	68.0	70.8	71.6	72.7	72.7	69.8	61.9	57.9	(22)	
5%		DB	58.1	59.7	63.8	70.5	76.8	84.5	89.3	88.4	82.6	76.8	66.9	62.6	(23)	
		MCWB	52.9	53.7	56.3	60.9	67.0	71.8	71.7	74.0	71.8	68.5	60.0	56.8	(24)	
10%		DB	55.3	57.6	61.5	67.8	74.6	82.3	86.3	86.1	80.0	74.1	64.7	60.4	(25)	
		MCWB	50.7	52.3	54.4	60.0	65.7	70.9	72.3	74.6	70.4	66.8	58.6	55.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.3	57.5	59.9	65.7	71.3	76.4	77.4	78.9	76.5	73.2	64.5	60.0	(27)
MCD B			63.2	62.9	66.5	72.8	79.6	85.2	87.4	86.7	84.8	81.0	70.3	65.4	(28)	
2%		WB	55.4	55.5	58.4	63.8	69.3	74.5	76.1	77.4	74.4	70.8	62.6	58.3	(29)	
		MCD B	60.0	60.6	64.8	71.3	78.2	83.2	86.2	86.0	83.0	78.0	68.7	63.5	(30)	
5%		WB	53.3	54.1	56.9	62.1	68.0	73.2	75.1	76.3	72.7	69.1	60.7	57.1	(31)	
		MCD B	57.8	59.1	63.2	69.1	75.7	82.1	85.2	85.3	81.1	76.0	66.1	62.1	(32)	
10%		WB	51.2	52.5	55.2	60.3	66.5	71.8	73.9	75.2	71.1	67.3	59.0	55.8	(33)	
		MCD B	54.9	57.2	60.6	67.1	73.8	80.7	84.0	84.4	78.9	73.8	63.9	60.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.1	13.4	14.6	14.0	13.9	14.8	15.3	15.4	15.0	13.7	12.7	10.7	(35)
MCDBR			13.6	15.0	16.5	16.8	15.8	18.1	20.1	19.5	17.9	16.6	14.0	11.5	(36)	
MCWBR			10.4	10.7	11.1	10.4	9.7	10.7	9.5	9.9	11.1	11.4	9.6	8.2	(37)	
5% WB		MCD BR	12.9	13.8	15.7	15.1	14.1	14.3	15.5	15.2	15.0	15.3	13.0	9.7	(38)	
		MCWBR	9.8	10.4	11.1	10.7	9.8	10.5	10.0	10.1	11.0	11.5	9.5	7.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.360	0.393	0.429	0.469	0.441	0.411	0.409	0.413	0.408	0.402	0.378	0.365	(40)	
taud		2.379	2.262	2.160	2.077	2.226	2.352	2.358	2.337	2.345	2.338	2.357	2.371	(41)		
Ebn at Noon		253	259	261	258	268	275	275	271	265	252	244	241	(42)		
Edh at Noon		28	36	44	50	44	39	39	38	36	33	29	27	(43)		
(44)	All-Sky Solar Radiation	RadAvg	609	843	1288	1692	2102	2376	2467	2184	1695	1166	773	557	(44)	
(45)		RadStd	74	87	101	167	113	146	65	66	95	83	70	77	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		+0.85	N/A	N/A	N/A	N/A	N/A	N/A	-205	+189	+94

Nomenclature: See separate page