

USA, Turkey

WMO: 171880

Lat: 38.683N

Lon: 29.400E

Elev: 919

StdP: 90.76

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.6	-5.6	-12.8	1.4	-4.3	-10.8	1.7	-2.8	9.1	4.3	7.8	3.0	1.5	280	0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.7	33.9	17.8	32.4	17.3	31.0	17.1	19.7	30.4	18.9	29.2	18.2	28.2	3.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	12.7	24.0	15.1	12.0	23.1	14.4	11.4	22.7	60.5	30.5	57.5	29.2	55.1	28.2	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.3	5.2	DB	-10.7	35.9	3.4	1.7	-13.1	37.2	-15.2	38.2	-17.1	39.2	-19.6	40.4	(4)
(5)			WB	-11.3	20.9	3.2	1.4	-13.6	21.9	-15.5	22.7	-17.3	23.4	-19.6	24.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	2.9	4.2	6.9	11.0	15.8	20.0	23.4	23.7	19.2	14.2	8.8	4.6	(6)	
	DBStd	8.01	4.00	3.91	3.63	3.69	3.29	3.05	2.48	2.39	3.08	3.50	3.70	3.70	(7)	
	HDD10.0	763	221	164	107	31	1	0	0	0	7	62	171		(8)	
	HDD18.3	2433	479	396	353	222	91	17	0	1	26	134	286	427	(9)	
	CDD10.0	1833	0	1	12	59	181	300	415	426	275	137	26	2	(10)	
	CDD18.3	462	0	0	0	1	13	67	157	168	51	6	0	0	(11)	
	CDH23.3	5437	0	0	1	18	192	787	1856	1846	656	82	0	0	(12)	
(13)	CDH26.7	2113	0	0	0	1	29	250	804	800	218	12	0	0	(13)	
(14)	Wind	WSAvg	2.0	1.8	2.0	2.1	1.9	1.9	2.1	2.3	2.3	1.9	1.8	1.5	1.7	(14)
(15) Precipitation	PrecAvg	516	72	65	58	55	48	26	16	10	20	45	58	85	(15)	
	PrecMax	749	212	171	125	121	122	128	76	30	116	141	152	211	(16)	
	PrecMin	346	2	7	9	0	2	0	0	0	0	0	1	7	(17)	
	PrecStd	101	49	36	30	28	30	24	19	9	22	31	36	45	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	17.4	20.9	25.9	29.2	33.1	36.1	35.4	33.2	28.2	21.6	16.2	(19)	
		MCWB	7.7	8.2	10.6	13.1	16.0	17.5	18.3	18.2	16.0	15.0	11.9	8.0	(20)	
	2%	DB	11.5	14.6	18.0	23.0	27.3	31.1	34.1	33.8	31.2	25.7	19.3	13.1	(21)	
		MCWB	6.9	7.7	9.2	12.3	15.1	17.1	18.3	17.6	15.8	14.0	10.8	7.7	(22)	
	5%	DB	10.0	12.4	16.0	20.8	25.6	29.5	32.5	32.4	29.2	23.4	17.3	11.4	(23)	
		MCWB	6.3	6.9	8.5	11.5	14.7	16.7	17.7	17.4	15.6	13.3	10.0	7.3	(24)	
	10%	DB	8.5	10.4	13.9	18.6	23.7	27.8	30.9	31.0	27.2	21.4	15.3	9.9	(25)	
		MCWB	5.5	6.2	7.7	10.7	14.1	16.3	17.4	17.3	15.2	12.6	9.5	7.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	9.9	11.6	14.1	17.4	19.4	21.1	20.6	18.7	16.8	13.6	9.9	(27)	
		MCDB	11.7	15.5	19.3	23.0	26.7	29.4	31.6	31.6	29.5	26.1	18.7	12.9	(28)	
	2%	WB	7.5	8.2	10.1	13.1	16.2	18.2	20.0	19.6	17.5	15.1	12.0	8.8	(29)	
		MCDB	10.6	13.0	16.0	21.6	25.1	28.0	31.0	30.1	27.3	22.2	17.0	11.7	(30)	
	5%	WB	6.7	7.3	9.0	12.1	15.4	17.5	19.1	18.9	16.7	14.2	11.0	8.1	(31)	
		MCDB	9.3	11.5	14.6	19.6	23.8	27.1	29.6	29.0	25.7	21.0	15.4	10.6	(32)	
	10%	WB	5.8	6.5	8.1	11.1	14.5	16.8	18.3	18.2	15.9	13.4	10.1	7.2	(33)	
		MCDB	8.1	10.0	13.1	17.5	22.3	26.1	28.4	28.1	24.5	19.8	14.1	9.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	8.7	10.0	11.0	12.5	13.3	14.2	13.7	13.7	11.9	10.4	8.1	(35)	
		MCDBR	9.9	12.8	14.3	15.5	15.4	15.2	16.1	15.6	17.3	15.5	14.4	11.1	(36)	
	5% WB	MCWBR	6.2	7.2	7.3	7.1	6.4	5.4	5.3	5.0	6.4	6.9	7.7	6.7	(37)	
		MCWBR	8.5	10.8	11.9	13.9	14.1	14.1	13.9	13.6	13.9	12.6	10.8	8.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.298	0.327	0.366	0.397	0.382	0.357	0.352	0.354	0.341	0.338	0.312	0.300	(40)	
		taud	2.451	2.377	2.274	2.212	2.312	2.400	2.408	2.384	2.421	2.432	2.479	2.491	(41)	
	Ebn at Noon		882	896	889	880	898	918	919	911	905	872	858	854	(42)	
		Edh at Noon	81	100	123	139	129	118	116	116	105	94	79	73	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.10	2.87	4.07	5.25	6.32	7.29	7.65	6.73	5.38	3.79	2.64	1.92	(44)	
	RadStd		0.26	0.39	0.36	0.48	0.43	0.50	0.24	0.26	0.35	0.22	0.26	0.26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page