

KAPADOKYA, Turkey

WMO: 171940

Lat: 38.767N

Lon: 34.533E

Elev: 3100

StdP: 13.12

Time Zone: 3.00 (E03)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.4	15.5	5.4	8.1	14.4	10.1	10.3	20.7	27.7	40.1	22.6	41.4	5.5	120	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	29.0	96.7	62.7	93.5	62.1	91.1	61.7	65.9	87.5	64.7	85.5	63.5	84.0	9.2	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.3	84.5	70.7	57.6	79.3	69.9	56.4	76.1	69.6	32.4	87.6	31.4	85.1	30.5	84.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.8	19.4	16.6	4.1	101.0	6.9	2.7	-0.9	102.9	-4.9	104.5	-8.7	106.0	-13.8	108.0
			3.4	68.7	6.7	2.6	-1.4	70.6	-5.3	72.1	-9.1	73.6	-13.9	75.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	55.2	33.7	38.5	45.8	53.3	62.0	69.8	75.0	75.7	67.1	57.2	45.4	37.3	(6)
(7)		DBStd	15.97	9.21	9.78	7.69	6.92	5.82	4.73	4.54	4.47	6.17	6.68	7.02	8.44	(7)
(8)		HDD50	1635	507	329	172	41	1	0	0	0	18	171	396		(8)
(9)		HDD65	4553	972	743	596	355	129	11	0	49	251	589	858		(9)
(10)		CDD50	3518	0	6	43	141	372	593	775	798	514	241	32	3	(10)
(11)		CDD65	962	0	0	1	5	36	154	311	334	112	9	0	0	(11)
(12)		CDH74	13119	0	0	15	139	644	2041	4085	4345	1629	221	0	0	(12)
(13)		CDH80	5907	0	0	2	26	169	796	2035	2220	624	35	0	0	(13)
(14)	Wind	WSAvg	7.0	7.1	6.8	7.8	7.5	7.0	7.6	8.3	7.8	6.5	6.0	5.8	5.9	(14)
(15)	Precipitation	PrecAvg	15.0	1.4	1.5	1.7	1.7	2.1	1.3	0.4	0.3	0.6	1.2	1.3	1.7	(15)
(16)		PrecMax	19.2	3.0	2.5	4.3	3.5	5.0	4.1	1.9	0.8	2.5	4.6	3.0	3.5	(16)
(17)		PrecMin	9.8	0.2	0.3	0.7	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.2	(17)
(18)		PrecStd	2.5	0.6	0.6	0.8	0.9	1.3	0.9	0.5	0.2	0.6	0.9	0.9	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.7	66.3	75.2	83.8	88.1	95.0	100.5	100.3	93.6	84.2	71.6	62.2	(19)
(20)		0.4%	MCWB	44.1	47.5	52.0	54.4	58.9	60.9	63.3	63.6	60.7	56.3	51.8	48.4	(20)
(21)		2%	DB	53.4	61.2	68.3	77.4	84.4	91.3	96.9	96.9	89.9	80.2	66.6	55.8	(21)
(22)		2%	MCWB	43.1	46.0	48.3	53.6	57.7	61.3	62.8	62.9	59.5	55.8	50.0	45.6	(22)
(23)		5%	DB	49.7	57.1	64.4	73.5	80.9	87.9	93.5	94.7	86.3	75.6	62.8	52.2	(23)
(24)		5%	MCWB	42.0	45.0	47.4	52.2	57.1	60.4	62.4	62.5	58.9	55.3	48.1	44.2	(24)
(25)		10%	DB	46.0	53.2	60.6	69.4	77.2	84.5	89.9	91.3	82.8	71.9	58.9	48.6	(25)
(26)		10%	MCWB	40.3	43.5	46.0	50.9	56.4	59.6	61.7	62.3	58.0	54.6	47.4	42.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.4	50.1	52.1	56.2	61.9	65.8	67.4	67.8	64.1	60.0	54.1	49.4	(27)
(28)		0.4%	MCDWB	55.1	62.0	70.6	75.5	78.7	84.2	89.0	89.4	85.3	72.2	67.6	58.2	(28)
(29)		2%	WB	44.1	47.2	50.2	54.6	60.0	64.3	65.8	66.2	61.7	57.9	51.5	47.1	(29)
(30)		2%	MCDWB	50.8	58.5	64.5	74.6	77.4	81.8	88.2	87.9	82.2	72.1	62.7	54.4	(30)
(31)		5%	WB	42.3	45.5	48.4	53.1	58.5	62.8	64.4	64.9	60.4	56.6	49.7	45.3	(31)
(32)		5%	MCDWB	47.7	55.8	61.6	70.6	75.5	79.6	85.7	86.2	81.1	71.3	59.9	51.4	(32)
(33)		10%	WB	40.4	43.6	46.9	51.6	57.3	61.5	63.2	63.7	59.2	55.5	47.9	43.2	(33)
(34)		10%	MCDWB	45.1	51.6	58.8	66.6	73.7	78.5	84.4	84.9	79.2	69.2	57.5	47.8	(34)
(35)	Mean Daily Temperature Range		MDBR	15.9	19.6	21.6	24.4	25.7	26.9	28.3	29.0	28.6	25.6	23.1	16.7	(35)
(36)		5% DB	MCDBR	20.3	25.4	28.5	32.0	31.8	31.8	32.9	32.9	33.6	31.0	29.0	21.7	(36)
(37)		5% DB	MCWBR	12.3	13.2	13.3	13.3	11.4	10.1	10.3	11.3	13.1	14.2	15.1	12.9	(37)
(38)		5% WB	MCDBR	17.4	22.9	24.8	28.5	27.8	27.0	28.6	28.1	28.4	26.3	24.9	18.9	(38)
(39)		5% WB	MCWBR	11.1	12.2	12.1	12.6	10.4	9.1	8.9	9.4	11.2	12.3	13.3	11.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.302	0.331	0.370	0.411	0.389	0.360	0.359	0.360	0.337	0.347	0.315	0.299	(40)	
(41)		taud	2.393	2.321	2.227	2.135	2.266	2.364	2.365	2.330	2.400	2.368	2.427	2.445	(41)	
(42)		Ebn at Noon	277	282	280	274	283	290	290	287	289	272	270	270	(42)	
(43)		Edh at Noon	27	34	41	48	43	39	38	39	34	31	26	24	(43)	
(44)	All-Sky Solar Radiation	RadAvg	671	990	1332	1684	2010	2327	2438	2202	1753	1207	831	601	(44)	
(45)		RadStd	80	128	110	142	119	155	102	64	102	72	79	74	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (6 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page