

KAYSERI ERKILET, Turkey

WMO: 171950

Lat: 38.773N

Lon: 35.491E

Elev: 1054

StdP: 89.29

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.8	-11.1	-17.1	1.0	-12.4	-14.1	1.2	-9.5	12.0	6.8	10.1	7.4	1.5	30	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	34.8	17.1	33.0	16.7	31.2	16.2	19.0	29.4	18.0	29.0	17.3	28.1	3.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.3	12.4	22.3	14.2	11.5	21.5	13.2	10.8	20.9	58.3	29.6	55.1	28.6	52.7	28.1	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
9.0	7.4	6.0	-18.0	37.4	4.3	1.4	-21.1	38.4	-23.6	39.2	-26.0	40.0	-29.1	41.0		
			-18.3	20.5	4.2	1.4	-21.3	21.5	-23.7	22.3	-26.1	23.1	-29.1	24.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	-0.5	1.3	5.9	10.7	15.1	19.1	22.1	22.3	17.9	12.5	6.1	1.3
	DBStd	8.82	5.07	5.41	4.15	3.84	3.23	2.77	2.58	2.54	3.26	3.73	3.98	4.73
	HDD10.0	1161	326	245	138	37	2	0	0	0	1	19	124	270
	HDD18.3	2937	584	478	386	231	109	24	1	2	46	182	367	528
	CDD10.0	1597	0	1	11	57	160	272	377	380	236	97	7	1
	CDD18.3	331	0	0	0	1	8	46	119	124	31	2	0	0
	CDH23.3	5324	0	0	2	40	223	762	1762	1766	679	90	0	0
	CDH26.7	2222	0	0	0	6	46	261	830	833	233	12	0	0
Wind	WSAvg	2.2	2.1	2.3	2.6	2.5	2.3	2.4	2.4	2.2	1.9	1.7	1.6	1.9
Precipitation	PrecAvg	368	31	33	39	54	51	39	11	6	15	29	34	42
	PrecMax	536	74	75	86	133	115	165	62	23	48	94	79	89
	PrecMin	258	1	2	9	8	13	1	0	0	0	0	0	4
	PrecStd	66	17	17	19	26	25	31	15	7	14	23	22	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	17.1	21.9	27.2	30.2	33.2	37.0	36.4	33.8	28.2	20.6	15.1
		MCWB	6.7	7.4	9.8	13.1	15.3	16.4	17.9	17.5	15.3	13.9	10.5	7.8
	2%	DB	10.2	13.9	18.9	24.0	27.9	31.2	35.0	34.8	31.2	25.9	18.2	12.2
		MCWB	5.3	6.8	9.0	11.6	14.3	15.9	17.3	17.0	15.0	12.9	9.7	7.0
	5%	DB	8.5	11.8	16.7	21.9	26.0	29.8	33.1	33.0	29.3	23.8	16.2	10.2
		MCWB	4.6	5.9	8.2	11.0	13.8	15.7	17.0	16.8	14.8	12.6	8.7	5.9
	10%	DB	6.8	9.5	14.3	19.3	23.9	27.9	31.2	31.2	27.3	21.3	14.0	8.4
		MCWB	3.6	5.0	7.2	10.1	13.3	15.1	16.5	16.6	14.2	11.9	8.0	5.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	8.9	11.3	14.2	16.8	18.8	20.6	20.2	17.7	15.3	11.7	8.9
		MCDB	11.3	14.7	18.6	22.5	24.9	28.2	31.9	30.9	27.3	24.2	17.5	13.0
	2%	WB	6.0	7.4	9.7	12.7	15.5	17.5	19.1	18.9	16.6	14.1	10.5	7.6
		MCDB	9.4	12.6	16.9	21.6	24.8	27.2	30.2	29.3	27.1	22.4	16.4	11.3
	5%	WB	4.8	6.2	8.6	11.7	14.6	16.7	18.1	18.0	15.7	13.2	9.5	6.4
		MCDB	7.8	11.0	15.4	19.9	23.7	26.3	29.3	29.3	26.2	21.3	14.9	9.7
	10%	WB	3.6	5.1	7.6	10.7	13.8	15.9	17.3	17.3	14.9	12.5	8.5	5.2
		MCDB	6.3	9.3	13.7	18.0	22.2	25.1	28.3	28.6	25.5	20.1	13.3	8.0
Mean Daily Temperature Range	5% DB	MDBR	9.9	11.1	12.5	14.0	14.6	16.0	17.5	17.7	17.7	15.5	14.0	10.1
		MCDBR	12.3	14.7	17.1	18.2	18.3	18.7	19.8	19.5	20.4	19.4	17.8	13.1
		MCWBR	8.3	8.6	9.1	8.6	7.8	6.9	6.9	6.6	8.2	9.2	10.4	8.6
	5% WB	MCDBR	11.3	13.4	14.8	15.9	16.5	16.3	17.9	17.4	17.9	16.4	15.4	11.8
		MCWBR	8.1	8.3	8.5	8.5	7.9	7.2	7.2	6.7	8.2	8.5	9.5	8.1
Clear-Sky Solar Irradiance	taub	0.303	0.334	0.377	0.417	0.395	0.360	0.354	0.359	0.335	0.352	0.317	0.299	
	taud	2.360	2.279	2.192	2.112	2.245	2.367	2.383	2.338	2.405	2.343	2.409	2.418	
	Ebn at Noon	868	883	875	860	886	914	917	906	911	851	845	848	
	Edh at Noon	88	110	133	154	137	122	119	121	106	102	84	78	
All-Sky Solar Radiation	RadAvg	2.24	3.28	4.14	5.24	6.26	7.34	7.77	7.08	5.61	3.83	2.63	1.92	
	RadStd	0.27	0.44	0.38	0.48	0.38	0.47	0.35	0.22	0.34	0.24	0.26	0.22	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+49
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page