

ESKISEHIR ANADOLU, Turkey

WMO: 172006

Lat: 39.810N

Lon: 30.519E

Elev: 2588

StdP: 13.37

Time Zone: 3.00 (E03)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	17.8	10.4	10.3	19.8	13.6	12.1	21.3	22.3	27.5	19.6	33.2	5.0	270	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.2	91.7	64.2	89.3	64.0	86.2	63.4	68.4	82.7	67.2	81.6	65.9	80.3	8.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.2	99.1	72.9	62.6	93.4	72.1	61.0	88.2	71.4	34.1	83.2	33.1	81.8	32.1	79.8	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.8	16.6	15.0	DB	8.0	97.8	6.3	2.4	3.5	99.5	-0.2	100.9	-3.8	102.3	-8.3	104.0	(4)
(5)			WB	7.4	71.4	6.1	1.4	3.0	72.4	-0.6	73.2	-4.0	74.0	-8.4	75.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.9	32.1	37.3	43.9	51.8	59.1	66.6	71.6	72.1	65.0	54.2	44.5	35.8
	DBStd	14.99	7.72	8.48	7.03	6.81	5.46	4.88	3.99	3.75	5.83	6.34	6.93	7.30
	HDD50	1849	555	358	207	58	4	0	0	0	0	34	188	445
	HDD65	5008	1020	774	653	397	194	37	3	2	72	336	614	906
	CDD50	2910	0	3	19	112	285	499	668	684	449	164	24	3
	CDD65	596	0	0	0	1	10	86	206	221	71	1	0	0
	CDH74	7727	0	0	1	99	318	1183	2488	2404	1158	76	0	0
	CDH80	2839	0	0	0	9	56	395	1001	944	423	11	0	0
Wind	WSAvg	7.0	7.5	7.1	7.7	7.1	6.8	7.0	7.9	7.8	6.7	5.7	5.8	7.0
Precipitation	PrecAvg	15.4	1.7	1.2	1.6	1.6	1.8	1.4	0.5	0.4	0.6	1.2	1.2	1.9
	PrecMax	20.0	4.1	3.1	3.1	4.6	5.0	5.0	2.5	1.6	3.3	3.9	2.9	5.0
	PrecMin	11.7	0.1	0.1	0.3	0.4	0.3	0.1	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.2	1.1	0.8	0.7	0.9	1.1	1.1	0.6	0.4	0.7	0.8	0.7	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.5	64.6	70.1	80.9	84.6	91.7	97.0	93.6	93.1	81.4	69.9	60.4
		MCWB	46.6	50.8	50.8	57.5	61.1	64.9	64.8	64.4	63.1	58.7	53.9	50.5
	2%	DB	50.2	59.1	65.9	77.0	80.9	88.1	91.8	91.2	89.2	75.4	66.1	53.6
		MCWB	43.8	47.1	49.3	55.9	59.5	64.3	64.4	64.4	62.2	57.2	51.8	47.7
	5%	DB	46.3	55.2	62.2	73.1	77.3	84.4	88.2	88.0	85.6	71.7	61.1	49.9
		MCWB	42.1	45.9	47.9	54.5	58.4	63.0	64.3	64.3	61.3	56.3	50.4	45.2
	10%	DB	42.8	51.4	58.6	68.1	73.7	80.8	85.8	85.8	80.8	67.8	57.1	46.6
		MCWB	40.2	44.0	46.8	52.7	57.4	61.9	63.8	64.1	60.5	55.2	48.5	43.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.3	52.5	52.8	59.2	64.1	69.1	69.5	70.3	67.0	61.2	56.3	51.6
		MCDB	54.2	62.4	64.6	77.1	79.6	82.5	84.6	85.0	83.6	72.8	66.1	56.8
	2%	WB	44.1	48.4	50.4	56.7	61.9	67.2	67.9	68.7	65.2	59.6	52.9	48.1
		MCDB	48.8	56.7	62.2	72.8	75.6	81.7	83.0	82.6	81.0	70.5	63.3	52.4
	5%	WB	42.0	46.8	48.6	55.2	60.3	65.4	66.5	67.6	63.6	58.2	50.9	45.9
		MCDB	45.4	54.0	59.7	70.5	72.8	79.8	81.9	81.3	78.5	68.1	59.7	49.3
	10%	WB	39.7	44.3	47.3	53.2	58.5	63.7	65.5	66.2	62.1	56.5	49.0	43.6
		MCDB	42.2	50.2	56.9	66.2	70.4	77.0	80.8	79.6	76.2	65.1	56.0	46.5
Mean Daily Temperature Range	5% DB	MDBR	12.1	18.6	21.6	25.0	24.1	25.4	27.2	26.9	28.3	24.1	21.9	13.5
		MCDBR	17.5	26.8	30.7	33.7	31.7	31.7	32.8	31.5	36.6	31.7	28.9	18.7
		MCWBR	12.2	16.1	16.5	15.4	13.1	11.8	10.8	10.2	13.1	15.7	16.8	12.6
	5% WB	MCDBR	16.4	24.3	26.3	30.0	27.3	27.4	28.1	25.9	30.1	24.8	25.4	14.8
		MCWBR	11.7	15.1	14.6	14.5	12.9	11.5	10.2	8.8	11.6	13.1	15.3	10.3
Clear-Sky Solar Irradiance	taub	0.314	0.341	0.387	0.424	0.404	0.383	0.380	0.382	0.367	0.357	0.326	0.314	
	taud	2.385	2.321	2.202	2.124	2.254	2.343	2.356	2.340	2.376	2.389	2.439	2.430	
	Ebn at Noon	269	276	273	270	278	283	283	279	277	267	263	260	
	Edh at Noon	27	33	42	48	43	39	39	38	35	31	25	24	
All-Sky Solar Radiation	RadAvg	577	853	1218	1579	1904	2199	2333	2050	1589	1083	748	517	
	RadStd	64	111	106	156	156	194	91	99	119	83	89	69	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page