

IZMIR GUZELYALI, Turkey

WMO: 172200

Lat: 38.3945N

Lon: 27.0821E

Elev: 95

StdP: 14.65

Time Zone: 3.00 (E03)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.5	36.4	18.1	13.7	36.2	21.6	16.2	39.6	18.8	52.2	16.8	51.1	6.1	160	0.382

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.9	96.4	70.7	94.2	70.3	92.2	70.0	74.5	89.8	73.3	88.7	72.3	87.6	7.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.4	108.4	83.6	68.0	103.2	82.6	66.6	98.3	82.5	38.0	90.0	37.0	88.6	36.0	87.5	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	13.6	12.1	30.3	101.4	4.2	2.0	27.3	102.8	24.8	103.9	22.4	105.0	19.4	106.4
			26.8	76.4	4.0	1.9	23.9	77.8	21.6	78.9	19.3	79.9	16.4	81.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	48.8	51.8	56.3	63.0	70.7	78.7	83.7	83.7	76.2	67.2	59.9	51.8	(6)
		DBStd	13.25	6.82	6.74	5.55	5.26	5.10	5.09	3.03	3.10	4.55	4.98	5.87	6.85	(7)
		HDD50	231	104	55	11	0	0	0	0	0	0	2	59		(8)
		HDD65	1872	501	372	271	99	10	0	0	0	0	36	171	412	(9)
		CDD50	6098	67	104	207	391	642	861	1045	1046	786	533	300	116	(10)
		CDD65	2264	0	1	2	40	188	411	580	581	336	104	18	3	(11)
		CDH74	23799	0	4	7	248	1293	4268	7372	7373	2836	373	25	0	(12)
		CDH80	10252	0	0	0	43	322	1796	3597	3535	921	37	1	0	(13)
(14)	Wind	WSAvg	5.8	6.0	6.0	5.9	5.5	5.5	6.6	6.4	5.6	5.1	5.2	5.5		(14)
(15)	Precipitation	PrecAvg	25.6	4.3	3.7	2.8	2.0	1.2	0.5	0.1	0.1	0.8	1.9	3.6	4.6	(15)
(16)		PrecMax	40.2	9.2	10.3	7.2	4.2	4.7	2.0	0.6	1.1	4.3	8.2	11.4	10.1	(16)
(17)		PrecMin	14.0	0.0	0.0	0.4	0.6	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	6.3	2.6	3.0	1.8	1.1	1.1	0.6	0.1	0.2	1.1	1.8	2.4	2.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	66.3	72.5	74.2	84.5	90.3	98.9	99.6	98.7	93.8	83.9	77.2	71.3		(19)
(20)		0.4% MCWB	56.3	57.2	57.1	62.0	64.7	71.5	70.9	70.8	67.9	66.3	63.3	57.7		(20)
(21)		2% DB	63.2	66.4	70.2	80.6	86.4	95.0	96.3	95.9	90.4	80.5	73.5	67.5		(21)
(22)		2% MCWB	54.3	55.6	55.6	60.9	64.8	70.3	70.2	71.3	68.3	64.7	61.3	57.5		(22)
(23)		5% DB	60.7	63.8	68.0	76.6	83.6	91.9	94.1	93.5	87.6	77.9	71.1	64.7		(23)
(24)		5% MCWB	52.9	54.6	55.1	59.8	64.0	68.9	70.2	71.1	67.2	63.6	60.2	56.6		(24)
(25)		10% DB	58.1	61.6	65.7	73.2	80.8	89.0	92.1	91.6	85.3	75.7	68.9	61.8		(25)
(26)		10% MCWB	51.7	53.5	54.5	58.8	63.4	68.0	69.8	70.8	66.9	62.9	59.4	55.2		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	58.7	58.8	59.3	64.8	68.7	74.7	76.0	76.4	72.9	68.9	65.3	60.1		(27)
(28)		0.4% MCDB	65.0	68.1	69.4	79.0	82.9	92.9	89.6	92.4	85.3	77.8	73.5	67.3		(28)
(29)		2% WB	54.9	56.7	57.8	62.7	67.0	72.7	74.1	74.7	71.3	67.2	63.0	58.6		(29)
(30)		2% MCDB	61.2	64.5	67.3	76.2	81.2	89.6	89.1	90.0	83.0	76.6	71.2	65.0		(30)
(31)		5% WB	53.5	55.3	56.5	61.1	65.7	71.0	72.9	73.7	70.0	66.0	61.4	57.2		(31)
(32)		5% MCDB	59.0	62.7	65.5	74.0	79.7	86.8	88.5	88.8	82.1	75.0	69.3	63.7		(32)
(33)		10% WB	52.2	53.9	55.4	59.6	64.5	69.8	71.9	72.7	68.9	64.6	59.9	55.5		(33)
(34)		10% MCDB	57.6	60.6	63.8	71.4	78.1	85.2	87.8	87.8	81.2	73.2	67.3	61.2		(34)
(35)	Mean Daily Temperature Range	MDBR	10.4	11.9	14.1	16.1	17.0	16.3	16.5	15.9	15.8	14.8	12.9	10.6		(35)
(36)		5% DB MCDBR	11.0	13.7	16.3	20.7	19.9	19.5	19.4	17.9	18.8	16.6	13.6	9.8		(36)
(37)		5% WB MCWBR	6.3	7.4	8.0	9.1	8.1	7.7	8.4	7.5	8.3	7.7	7.0	6.2		(37)
(38)		5% WB MCDBR	10.1	12.9	14.8	19.2	18.0	17.0	16.5	15.4	15.9	15.0	12.1	9.5		(38)
(39)		5% WB MCWBR	6.7	7.0	7.8	9.1	8.0	7.5	7.5	6.9	7.4	7.3	6.9	6.6		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.359	0.392	0.429	0.467	0.443	0.408	0.405	0.410	0.402	0.399	0.376	0.364		(40)
(41)		taud	2.381	2.260	2.150	2.074	2.207	2.344	2.353	2.326	2.347	2.336	2.361	2.380		(41)
(42)		Ebn at Noon	255	260	262	259	267	277	276	272	268	255	246	244		(42)
(43)		Edh at Noon	28	36	44	51	45	40	39	39	36	33	29	27		(43)
(44)	All-Sky Solar Radiation	RadAvg	658	897	1350	1768	2165	2449	2527	2241	1769	1243	830	604		(44)
(45)		RadStd	77	89	95	161	107	125	47	47	92	68	70	85		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (13 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-167	N/A	N/A	(47)

Nomenclature: See separate page