

AYDIN, Turkey

WMO: 172340

Lat: 37.850N

Lon: 27.850E

Elev: 56

StdP: 100.65

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.3	(c) 1.0	(d) -8.2	(e) 1.9	(f) 4.8	(g) -6.2	(h) 2.2	(i) 5.2	(j) 5.4	(k) 10.7	(l) 4.6	(m) 9.3	(n) 1.3	(o) 90	(p) 0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	38.3	21.8	37.0	21.8	35.7	21.7	24.7	34.9	23.8	33.7	23.0	32.6	2.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.6	16.4	30.1	20.5	15.3	29.0	19.7	14.5	28.0	75.2	35.2	71.5	33.8	68.3	32.5	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.6	(b) 3.9	(c) 3.4	(e) -2.3	(f) 40.9	(g) 1.2	(h) 1.6	(i) -3.1	(j) 42.0	(k) -3.8	(l) 43.0	(m) -4.5	(n) 43.8	(o) -5.3	(p) 45.0		
(a) 4.6	(b) 3.9	(c) 3.4	(e) -3.4	(f) 26.0	(g) 1.3	(h) 1.3	(i) -4.3	(j) 26.9	(k) -5.0	(l) 27.7	(m) -5.7	(n) 28.4	(o) -6.7	(p) 29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	8.9	9.9	12.6	16.5	21.9	26.5	29.1	28.8	24.8	20.1	14.5	10.1
	DBStd	7.83	3.35	3.34	3.30	3.31	3.11	2.78	1.92	1.96	2.50	3.24	3.54	3.34
	HDD10.0	162	61	39	13	2	0	0	0	0	0	0	8	39
	HDD18.3	1183	293	236	179	72	7	0	0	0	0	20	121	256
	CDD10.0	3333	26	37	94	197	369	496	591	582	443	314	142	43
	CDD18.3	1313	0	0	2	17	117	246	332	324	193	76	6	0
	CDH23.3	14226	0	0	12	148	1070	2770	4187	3804	1724	487	23	1
	CDH26.7	7393	0	0	2	29	424	1461	2418	2132	789	136	2	0
Wind	WSAvg	1.4	1.4	1.4	1.4	1.3	1.3	1.5	1.6	1.5	1.4	1.1	1.2	1.3
Precipitation	PrecAvg	663	108	96	71	58	41	10	5	3	15	46	89	119
	PrecMax	993	270	199	135	120	126	47	31	13	76	120	313	252
	PrecMin	405	12	18	10	8	5	0	0	0	0	0	2	6
	PrecStd	143	65	57	36	27	30	12	6	4	20	32	60	68
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.8	20.1	24.7	29.8	35.2	39.6	40.6	39.7	36.7	32.3	26.0	20.4
		MCWB	12.6	12.6	14.4	17.3	19.0	21.0	22.7	21.8	20.6	18.6	16.4	13.7
	2%	DB	17.0	18.3	21.9	27.0	32.9	37.1	38.5	38.0	34.7	30.0	23.4	17.9
		MCWB	12.1	11.7	13.4	16.0	18.8	20.9	22.0	22.1	20.5	18.2	15.3	12.7
	5%	DB	15.3	16.8	20.3	24.8	31.0	35.5	37.1	36.5	33.0	28.1	21.6	16.5
		MCWB	11.0	11.1	12.7	14.9	18.5	20.7	22.0	22.3	20.2	17.7	14.6	11.9
	10%	DB	14.0	15.3	18.7	22.8	29.1	33.7	35.7	35.1	31.2	26.1	19.9	15.0
		MCWB	10.3	10.5	12.0	14.3	17.8	20.3	21.9	22.1	19.5	17.0	14.2	11.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.1	14.0	15.9	18.6	21.2	24.0	26.0	26.1	23.2	20.7	18.0	14.7
		MCDB	16.7	17.7	22.3	27.5	32.0	34.8	36.5	36.0	33.1	26.9	22.9	19.1
	2%	WB	12.6	12.6	14.6	16.8	20.1	22.7	24.7	24.9	22.2	19.9	16.7	13.5
		MCDB	15.7	16.8	20.1	24.7	30.5	33.5	35.3	34.8	31.0	25.9	21.0	16.9
	5%	WB	11.7	11.7	13.6	15.8	19.2	21.8	23.7	24.0	21.3	19.0	15.7	12.6
		MCDB	14.5	15.7	18.6	22.7	28.7	32.4	34.1	33.4	29.7	25.0	19.9	15.4
	10%	WB	10.8	10.9	12.7	15.0	18.4	21.0	23.0	23.1	20.5	18.2	14.8	11.8
		MCDB	13.4	14.4	17.4	21.3	26.9	31.1	33.1	32.1	28.4	23.6	18.5	14.3
Mean Daily Temperature Range	5% DB	MDBR	7.8	8.6	10.2	11.0	12.9	13.8	14.2	13.5	13.5	11.7	9.8	7.7
		MCDBR	8.8	10.3	12.4	13.9	15.3	15.6	15.5	14.7	15.2	13.8	11.6	8.7
		MCWBR	5.0	5.4	6.0	5.8	5.4	5.2	5.5	5.3	5.4	5.0	5.4	4.8
	5% WB	MCDBR	7.5	8.8	10.9	12.4	13.8	14.1	13.9	13.1	13.4	11.5	9.4	7.0
MCWBR		4.7	4.9	5.8	5.7	5.4	5.4	5.8	5.5	5.4	4.8	5.0	4.3	
Clear-Sky Solar Irradiance	taub	0.350	0.384	0.424	0.462	0.443	0.405	0.400	0.409	0.394	0.392	0.367	0.354	
	taud	2.390	2.268	2.144	2.076	2.190	2.335	2.347	2.311	2.352	2.341	2.379	2.404	
	Ebn at Noon	820	832	831	822	844	875	876	860	854	815	793	788	
	Edh at Noon	89	114	141	160	146	126	124	125	114	104	89	83	
All-Sky Solar Radiation	RadAvg	2.19	2.97	4.36	5.64	6.83	7.77	8.01	7.11	5.70	4.05	2.75	2.01	
	RadStd	0.26	0.32	0.30	0.50	0.36	0.39	0.16	0.16	0.29	0.21	0.24	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		+0.32	N/A	N/A	N/A	N/A	N/A	N/A	-73	+85	N/A

Nomenclature: See separate page