

DENIZLI, Turkey

WMO: 172370

Lat: 37.7619N

Lon: 29.0919E

Elev: 1394

StdP: 13.97

Time Zone: 3.00 (E03)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.3	30.2	14.8	12.2	36.8	18.1	14.4	37.1	15.9	55.7	12.0	54.9	3.2	320	0.359

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	100.9	68.0	98.4	67.6	95.8	67.3	73.1	93.7	71.5	91.6	70.0	89.5	4.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	102.0	84.0	64.4	95.3	82.8	62.8	90.0	81.0	37.7	93.8	36.2	91.9	34.9	89.7	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.1	7.0	DB	23.3	105.1	4.3	2.7	20.2	107.1	17.7	108.7	15.3	110.3	12.2	112.3	(4)
(5)			WB	21.0	74.8	3.6	2.2	18.4	76.4	16.2	77.6	14.2	78.9	11.6	80.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.8	44.1	47.2	53.2	60.8	69.4	77.8	84.3	84.1	75.8	65.6	55.5	46.7	(6)
(7)		DBStd	15.26	7.08	7.36	6.75	6.39	6.00	5.65	3.94	3.63	5.41	5.93	6.51	6.92	(7)
(8)		HDD50	541	201	124	44	2	0	0	0	0	0	1	25	144	(8)
(9)		HDD65	2619	647	497	369	159	26	0	0	0	2	63	290	566	(9)
(10)		CDD50	5581	19	47	143	325	602	834	1063	1057	773	486	189	43	(10)
(11)		CDD65	2184	0	0	3	32	163	384	598	592	325	83	4	0	(11)
(12)		CDH74	24206	0	2	22	289	1443	4148	7570	7289	2936	495	12	0	(12)
(13)		CDH80	12215	0	0	2	66	490	2018	4247	4000	1292	100	0	0	(13)
(14)	Wind	WSAvg	2.7	2.7	2.9	2.8	2.8	3.0	3.2	2.8	2.5	2.2	2.2	2.2	(14)	
(15)	Precipitation	PrecAvg	21.4	3.6	3.1	2.5	2.0	1.5	0.8	0.6	0.5	0.6	1.5	2.1	3.8	(15)
(16)		PrecMax	29.8	10.2	8.3	4.5	4.4	5.0	2.4	2.3	2.6	3.3	4.3	4.5	7.4	(16)
(17)		PrecMin	13.3	0.2	0.4	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.1	0.2	0.6	(17)
(18)		PrecStd	5.0	2.6	1.9	1.1	1.1	1.2	0.7	0.6	0.6	0.8	1.1	1.3	1.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.6	70.1	76.5	86.1	92.6	102.3	105.2	103.2	99.3	86.8	75.7	67.8	(19)
(20)			MCWB	50.6	52.6	54.1	59.4	62.8	67.4	68.9	68.6	65.9	62.2	57.9	52.0	(20)
(21)		2%	DB	59.6	64.1	71.9	81.2	89.1	97.1	101.4	100.5	94.8	82.9	71.4	62.2	(21)
(22)			MCWB	49.7	50.9	53.7	58.5	62.5	67.0	68.2	68.7	65.4	61.7	56.6	51.2	(22)
(23)		5%	DB	56.8	60.9	68.1	76.9	85.5	93.4	98.6	98.1	90.9	79.4	68.3	59.0	(23)
(24)			MCWB	48.1	49.6	52.6	57.2	62.1	66.2	68.0	67.8	65.5	60.5	55.0	50.4	(24)
(25)		10%	DB	54.0	58.0	64.6	72.9	82.0	90.4	95.8	95.5	87.5	76.2	65.2	56.1	(25)
(26)			MCWB	47.0	48.3	51.6	56.0	61.1	65.9	67.2	68.1	64.2	59.7	53.9	49.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.1	54.8	58.2	61.9	66.8	71.7	74.6	75.8	71.2	65.9	60.9	54.3	(27)
(28)			MCDWB	59.9	67.6	71.8	80.2	86.0	93.0	96.5	95.3	89.8	79.4	70.1	62.8	(28)
(29)		2%	WB	50.5	52.0	55.5	60.1	65.1	69.9	72.7	73.8	69.0	63.7	58.2	52.7	(29)
(30)			MCDWB	57.7	61.6	67.8	76.7	83.8	91.2	94.8	93.5	86.9	76.7	67.9	59.8	(30)
(31)		5%	WB	48.9	50.3	53.8	58.6	63.6	68.3	71.2	72.2	67.5	62.2	56.5	51.1	(31)
(32)			MCDWB	55.3	59.1	65.3	73.8	81.1	88.9	92.7	91.2	84.6	75.3	65.6	57.3	(32)
(33)		10%	WB	47.4	48.7	52.2	57.0	62.1	66.9	69.8	70.5	66.2	60.8	55.0	49.7	(33)
(34)			MCDWB	53.1	56.6	62.7	70.8	78.3	86.5	90.2	88.9	82.7	73.4	63.3	55.2	(34)
(35)	Mean Daily Temperature Range	MDBR		12.4	14.1	17.0	19.1	21.4	22.8	23.6	23.4	22.3	19.2	16.6	12.2	(35)
(36)		5% DB	MCDBR	15.3	17.6	21.9	24.8	25.5	25.9	26.3	25.8	26.4	23.1	19.9	14.9	(36)
(37)			MCWBR	8.5	8.8	10.2	10.2	9.3	8.3	7.7	7.6	9.0	8.7	9.3	8.5	(37)
(38)		5% WB	MCDBR	13.6	16.3	19.1	22.1	23.0	23.7	23.8	22.9	22.4	20.0	17.1	13.0	(38)
(39)			MCWBR	8.1	8.6	9.7	10.0	9.3	8.6	8.4	8.6	8.9	8.6	8.4	7.7	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.325	0.359	0.405	0.441	0.426	0.392	0.386	0.396	0.375	0.371	0.341	0.327	(40)
(41)		taud		2.426	2.318	2.172	2.104	2.210	2.341	2.351	2.311	2.368	2.367	2.425	2.456	(41)
(42)		Ebn at Noon		271	274	270	267	272	281	282	277	277	266	262	262	(42)
(43)		Edh at Noon		27	34	43	49	45	40	39	40	36	32	27	25	(43)
(44)	All-Sky Solar Radiation	RadAvg		707	959	1364	1743	2070	2387	2469	2180	1778	1273	887	648	(44)
(45)		RadStd		86	115	101	148	134	138	70	70	106	69	77	86	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page