

DENIZLI, Turkey

WMO: 172370

Lat: 37.7619N

Lon: 29.0919E

Elev: 425

StdP: 96.32

Time Zone: 3.00 (E03)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.6	(c) -1.0	(d) -9.6	(e) 1.7	(f) 2.6	(g) -7.7	(h) 2.1	(i) 2.8	(j) 7.1	(k) 13.1	(l) 5.4	(m) 12.7	(n) 1.4	(o) 320	(p) 0.359

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 13.1	(c) 38.3	(d) 20.0	(e) 36.9	(f) 19.8	(g) 35.4	(h) 19.6	(i) 22.8	(j) 34.3	(k) 21.9	(l) 33.1	(m) 21.1	(n) 32.0	(o) 1.9	(p) 330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	14.6	28.9	18.0	13.6	28.2	17.1	12.9	27.2	69.8	34.3	66.2	33.3	63.3	32.1	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.4	(b) 3.6	(c) 3.1	(e) -4.8	(f) 40.6	(g) 2.4	(h) 1.5	(i) -6.5	(j) 41.7	(k) -7.9	(l) 42.6	(m) -9.3	(n) 43.5	(o) -11.0	(p) 44.6		
(4) 4.4	(5) 3.6	(6) 3.1	(7) -4.8	(8) 40.6	(9) 2.4	(10) 1.5	(11) -6.5	(12) 41.7	(13) -7.9	(14) 42.6	(15) -9.3	(16) 43.5	(17) -11.0	(18) 44.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	6.7	8.5	11.8	16.0	20.8	25.4	29.0	29.0	24.3	18.7	13.0	8.2		
	DBStd	8.48	3.93	4.09	3.75	3.55	3.33	3.14	2.19	2.01	3.01	3.29	3.61	3.85		
	HDD10.0	301	112	69	24	1	0	0	0	0	1	14	80			
	HDD18.3	1455	359	276	205	88	14	0	0	0	1	35	161	314		
	CDD10.0	3101	11	26	79	181	334	463	591	587	429	270	105	24		
	CDD18.3	1213	0	0	2	18	91	213	332	329	181	46	2	0		
	CDH23.3	13448	0	1	12	161	802	2304	4206	4049	1631	275	7	0		
	CDH26.7	6786	0	0	1	37	272	1121	2359	2222	718	56	0	0		
(14) Wind	WSAvg	1.2	1.2	1.3	1.3	1.3	1.2	1.3	1.4	1.3	1.1	1.0	1.0	1.0		
(15) Precipitation	PrecAvg	544	92	78	63	50	38	21	16	12	16	38	54	97		
	PrecMax	757	258	211	115	112	126	62	58	66	83	108	114	188		
	PrecMin	338	5	11	6	2	2	0	0	0	0	2	5	16		
	PrecStd	127	67	48	28	29	30	17	16	16	21	27	34	46		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.5	21.2	24.7	30.0	33.7	39.0	40.7	39.5	37.4	30.5	24.3	19.9		
		MCWB	10.3	11.5	12.3	15.2	17.1	19.7	20.5	20.3	18.9	16.8	14.4	11.1		
	2%	DB	15.3	17.8	22.2	27.3	31.7	36.2	38.5	38.0	34.9	28.3	21.9	16.8		
		MCWB	9.8	10.5	12.1	14.7	16.9	19.4	20.1	20.4	18.6	16.5	13.6	10.7		
	5%	DB	13.8	16.1	20.0	25.0	29.7	34.1	37.0	36.7	32.7	26.3	20.2	15.0		
		MCWB	8.9	9.8	11.4	14.0	16.7	19.0	20.0	19.9	18.6	15.9	12.8	10.2		
	10%	DB	12.2	14.4	18.1	22.7	27.8	32.4	35.4	35.3	30.8	24.6	18.4	13.4		
		MCWB	8.3	9.1	10.9	13.3	16.2	18.8	19.6	20.0	17.9	15.4	12.2	9.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	12.7	14.5	16.6	19.3	22.0	23.7	24.3	21.8	18.8	16.0	12.4		
		MCDB	15.5	19.8	22.1	26.8	30.0	33.9	35.9	35.2	32.1	26.3	21.1	17.1		
	2%	WB	10.3	11.1	13.0	15.6	18.4	21.0	22.6	23.2	20.5	17.6	14.5	11.5		
		MCDB	14.3	16.5	19.9	24.8	28.8	32.9	34.9	34.2	30.5	24.8	19.9	15.4		
	5%	WB	9.4	10.1	12.1	14.8	17.6	20.2	21.8	22.3	19.7	16.8	13.6	10.6		
		MCDB	12.9	15.1	18.5	23.2	27.3	31.6	33.7	32.9	29.2	24.1	18.7	14.1		
	10%	WB	8.6	9.3	11.2	13.9	16.7	19.4	21.0	21.4	19.0	16.0	12.8	9.8		
		MCDB	11.7	13.7	17.0	21.6	25.7	30.3	32.3	31.6	28.2	23.0	17.4	12.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	7.8	9.4	10.6	11.9	12.6	13.1	13.0	12.4	10.7	9.2	6.8		
		MCDBR	8.5	9.8	12.2	13.8	14.1	14.4	14.6	14.3	14.7	12.8	11.0	8.3		
	5% WB	MCWBR	4.7	4.9	5.7	5.7	5.1	4.6	4.3	4.2	5.0	4.9	5.2	4.7		
		MCWBR	7.6	9.1	10.6	12.3	12.8	13.2	13.2	12.7	12.4	11.1	9.5	7.2		
(40) Clear-Sky Solar Irradiance	taub		0.325	0.359	0.405	0.441	0.426	0.392	0.386	0.396	0.375	0.371	0.341	0.327		
	taud		2.426	2.318	2.172	2.104	2.210	2.341	2.351	2.311	2.368	2.367	2.425	2.456		
	Ebn at Noon		853	863	851	841	859	887	889	873	873	838	826	825		
	Edh at Noon		85	108	137	156	143	125	123	125	112	102	85	78		
(44) All-Sky Solar Radiation	RadAvg		2.23	3.02	4.30	5.49	6.53	7.52	7.78	6.87	5.60	4.01	2.80	2.04		
	RadStd		0.27	0.36	0.32	0.47	0.42	0.43	0.22	0.22	0.33	0.22	0.24	0.27		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page