

DENZILI CARDAK, Turkey

WMO: 172375

Lat: 37.786N

Lon: 29.701E

Elev: 2795

StdP: 13.27

Time Zone: 3.00 (E03)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 17.2	(c) 21.4	(d) 10.0	(e) 10.1	(f) 22.0	(g) 14.1	(h) 12.5	(i) 27.7	(j) 25.6	(k) 42.8	(l) 23.1	(m) 43.4	(n) 4.9	(o) 110	(p) 0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.8	94.9	64.1	92.9	63.7	90.0	63.2	68.4	85.5	67.1	84.4	65.9	83.4	9.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.9	95.3	72.7	61.2	89.7	72.4	60.5	87.2	72.4	34.3	85.9	33.2	85.3	32.2	83.9	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	18.4	16.2	DB	6.5	99.4	12.5	2.6	-2.5	101.2	-9.8	102.7	-16.8	104.2	-25.9	106.0
			WB	5.5	71.4	12.0	1.9	-3.1	72.8	-10.1	73.9	-16.8	75.0	-25.5	76.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	37.2	42.2	46.6	54.2	61.3	69.4	75.9	75.8	68.4	57.8	48.6	40.5	(6)
	DBStd	14.51	8.62	7.14	6.38	6.00	5.32	5.47	3.62	3.13	5.12	5.87	6.54	7.34	(7)
	HDD50	1205	398	229	138	23	1	0	0	0	0	11	101	304	(8)
	HDD65	4057	862	638	571	326	139	15	0	0	26	230	492	758	(9)
	CDD50	3606	1	11	32	150	352	582	803	801	552	252	59	11	(10)
	CDD65	983	0	0	0	3	25	147	338	336	128	6	0	0	(11)
	CDH74	13044	0	0	0	121	476	1969	4436	4080	1798	164	0	0	(12)
	CDH80	5794	0	0	0	9	106	789	2214	1936	719	21	0	0	(13)
(14) Wind	WSAvg	6.7	7.1	7.6	7.5	6.7	6.1	6.6	7.4	7.5	6.4	5.9	5.4	6.1	(14)
(15) Precipitation	PrecAvg	21.6	3.1	2.7	2.2	2.0	1.7	0.9	0.6	0.5	0.7	1.5	2.3	3.5	(15)
	PrecMax	32.1	9.5	5.8	5.5	3.8	3.9	3.3	2.2	1.9	2.2	3.7	5.4	9.4	(16)
	PrecMin	11.0	0.0	0.4	0.4	0.4	0.2	0.0	0.0	0.1	0.0	0.0	0.0	0.2	(17)
	PrecStd	4.6	2.2	1.6	1.3	0.9	0.9	0.8	0.5	0.5	0.6	1.0	1.3	2.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.6	67.9	69.9	81.0	86.4	94.9	99.7	97.0	93.5	82.6	72.0	63.0	(19)
		MCWB	46.9	49.8	50.2	56.1	59.7	63.3	65.3	65.1	62.8	58.2	52.8	49.6	(20)
	2%	DB	53.9	61.0	66.3	77.4	82.7	91.8	95.2	94.6	91.0	78.5	68.2	58.8	(21)
		MCWB	45.1	47.9	49.4	55.1	59.3	63.6	64.3	64.1	61.9	57.7	52.7	48.1	(22)
	5%	DB	51.5	57.2	62.9	73.8	79.2	88.2	93.1	91.7	87.8	75.1	64.8	55.2	(23)
		MCWB	43.9	46.4	48.4	54.5	58.6	62.5	63.7	63.8	60.7	56.2	50.8	46.6	(24)
	10%	DB	48.5	53.6	59.4	69.6	75.5	84.4	91.0	89.6	84.3	71.7	62.2	52.0	(25)
		MCWB	42.6	44.9	47.4	52.6	57.1	62.0	63.5	63.5	60.9	55.8	49.9	45.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.1	51.7	53.0	58.4	62.7	68.3	70.5	70.1	66.6	60.9	57.9	51.7	(27)
		MCDB	55.1	64.7	65.7	75.2	80.8	84.0	88.0	87.6	83.6	74.4	65.5	60.8	(28)
	2%	WB	46.1	48.7	51.0	56.7	61.0	66.2	68.3	68.5	65.2	59.2	54.7	48.9	(29)
		MCDB	52.7	58.4	62.4	73.5	77.4	83.1	86.3	85.6	82.4	72.5	64.4	56.1	(30)
	5%	WB	44.4	47.2	49.4	55.0	59.7	64.8	66.7	67.4	63.7	58.2	52.5	47.5	(31)
		MCDB	50.4	56.2	60.3	70.4	75.2	81.6	85.6	84.1	80.4	71.0	62.0	54.1	(32)
	10%	WB	42.9	45.5	47.9	53.4	58.4	63.6	65.6	66.3	62.5	56.9	51.0	46.0	(33)
		MCDB	47.8	53.3	58.1	67.1	72.5	79.9	84.5	82.7	78.5	69.0	60.3	51.5	(34)
(35) Mean Daily Temperature Range	MDBR		16.1	18.9	20.7	24.7	24.7	26.7	28.8	28.1	29.3	25.5	23.7	17.9	(35)
	5% DB	MCDBR	19.5	24.7	27.6	32.6	30.5	30.5	32.4	30.9	34.6	30.9	28.2	21.3	(36)
		MCWBR	12.0	13.5	14.4	14.3	12.1	9.7	10.4	10.0	13.1	14.0	14.8	12.8	(37)
	5% WB	MCDBR	17.7	22.7	24.1	29.2	27.8	27.1	28.7	27.0	29.2	25.2	23.2	17.3	(38)
		MCWBR	11.3	12.7	12.9	13.4	11.6	9.7	9.7	9.2	11.3	11.8	13.3	10.9	(39)
(40) Clear-Sky Solar Irradiance	taub		0.297	0.325	0.366	0.396	0.386	0.359	0.355	0.363	0.342	0.339	0.312	0.299	(40)
	taud		2.472	2.398	2.283	2.223	2.309	2.404	2.406	2.368	2.430	2.437	2.485	2.507	(41)
	Ebn at Noon		283	286	283	280	284	291	291	287	288	278	275	274	(42)
	Edh at Noon		26	31	39	44	41	37	37	37	33	30	25	23	(43)
(44) All-Sky Solar Radiation	RadAvg		709	970	1369	1739	2044	2363	2440	2158	1767	1265	890	648	(44)
	RadStd		86	115	101	142	140	139	75	69	105	71	77	86	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page