

DENZILI CARDAK, Turkey

WMO: 172375

Lat: 37.786N

Lon: 29.701E

Elev: 852

StdP: 91.50

Time Zone: 3.00 (E03)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.2	-5.9	-12.2	1.4	-5.6	-10.0	1.8	-2.4	11.4	6.0	10.3	6.3	2.2	110	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	34.9	17.8	33.8	17.6	32.2	17.3	20.2	29.7	19.5	29.1	18.9	28.6	4.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	13.6	22.6	16.2	12.8	22.4	15.8	12.5	22.4	62.0	30.0	59.2	29.6	57.0	28.8	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.2	7.2	DB	-14.2	37.4	6.9	1.4	-19.1	38.5	-23.2	39.3	-27.1	40.1	-32.1	41.1	(4)
(5)			WB	-14.7	21.9	6.7	1.1	-19.5	22.6	-23.4	23.3	-27.1	23.9	-32.0	24.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.7	2.9	5.7	8.1	12.4	16.3	20.8	24.4	24.4	20.2	14.3	9.2	4.7	(6)
(7)		DBStd	8.06	4.79	3.97	3.55	3.34	2.95	3.04	2.01	1.74	2.84	3.26	3.63	4.08	(7)
(8)		HDD10.0	669	221	127	77	13	1	0	0	0	0	6	56	169	(8)
(9)		HDD18.3	2254	479	354	317	181	77	8	0	0	14	128	273	421	(9)
(10)		CDD10.0	2003	1	6	18	83	196	323	446	445	307	140	33	6	(10)
(11)		CDD18.3	546	0	0	0	2	14	82	188	187	71	3	0	0	(11)
(12)		CDH23.3	7247	0	0	0	67	264	1094	2464	2267	999	91	0	0	(12)
(13)		CDH26.7	3219	0	0	0	5	59	438	1230	1076	399	12	0	0	(13)
(14)	Wind	WSAvg	3.0	3.2	3.4	3.4	3.0	2.7	2.9	3.3	3.3	2.8	2.6	2.4	2.7	(14)
(15)	Precipitation	PrecAvg	548	79	68	55	50	43	24	15	13	18	38	58	88	(15)
(16)		PrecMax	816	242	148	140	97	99	85	56	48	56	95	138	239	(16)
(17)		PrecMin	280	1	9	11	11	5	1	1	2	0	1	1	4	(17)
(18)		PrecStd	118	57	40	33	23	23	20	12	13	15	26	33	58	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.8	19.9	21.0	27.2	30.2	35.0	37.6	36.1	34.1	28.1	22.2	17.2	(19)
(20)			MCWB	8.3	9.9	10.1	13.4	15.4	17.4	18.5	18.4	17.1	14.5	11.6	9.8	(20)
(21)		2%	DB	12.2	16.1	19.0	25.2	28.2	33.2	35.1	34.8	32.8	25.8	20.1	14.9	(21)
(22)			MCWB	7.3	8.8	9.7	12.8	15.2	17.6	17.9	17.8	16.6	14.3	11.5	8.9	(22)
(23)		5%	DB	10.8	14.0	17.1	23.2	26.2	31.2	33.9	33.2	31.0	23.9	18.2	12.9	(23)
(24)			MCWB	6.6	8.0	9.1	12.5	14.8	17.0	17.6	17.7	16.0	13.5	10.4	8.1	(24)
(25)		10%	DB	9.1	12.0	15.2	20.9	24.1	29.1	32.8	32.0	29.1	22.0	16.8	11.1	(25)
(26)			MCWB	5.9	7.2	8.6	11.4	13.9	16.7	17.5	17.5	16.0	13.2	9.9	7.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	10.9	11.7	14.7	17.1	20.2	21.4	21.2	19.2	16.0	14.4	10.9	(27)
(28)			MCDWB	12.8	18.2	18.7	24.0	27.1	28.9	31.1	30.9	28.7	23.5	18.6	16.0	(28)
(29)		2%	WB	7.8	9.3	10.5	13.7	16.1	19.0	20.2	20.3	18.4	15.1	12.6	9.4	(29)
(30)			MCDWB	11.5	14.7	16.9	23.0	25.2	28.4	30.2	29.8	28.0	22.5	18.0	13.4	(30)
(31)		5%	WB	6.9	8.4	9.7	12.8	15.4	18.2	19.3	19.7	17.6	14.5	11.4	8.6	(31)
(32)			MCDWB	10.2	13.4	15.7	21.4	24.0	27.5	29.8	29.0	26.9	21.6	16.7	12.3	(32)
(33)		10%	WB	6.1	7.5	8.8	11.9	14.7	17.6	18.7	19.0	16.9	13.8	10.5	7.8	(33)
(34)			MCDWB	8.8	11.8	14.5	19.5	22.5	26.6	29.2	28.2	25.8	20.6	15.7	10.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.0	10.5	11.5	13.7	13.7	14.8	16.0	15.6	16.3	14.2	13.2	9.9	(35)
(36)			MCDBR	10.9	13.7	15.3	18.1	16.9	16.9	18.0	17.2	19.2	17.1	15.7	11.9	(36)
(37)			MCWBR	6.7	7.5	8.0	8.0	6.7	5.4	5.8	5.5	7.3	7.8	8.2	7.1	(37)
(38)		5% WB	MCDBR	9.9	12.6	13.4	16.2	15.4	15.1	15.9	15.0	16.2	14.0	12.9	9.6	(38)
(39)			MCWBR	6.3	7.1	7.2	7.5	6.5	5.4	5.4	5.1	6.3	6.6	7.4	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.297	0.325	0.366	0.396	0.386	0.359	0.355	0.363	0.342	0.339	0.312	0.299	(40)	
(41)		taud	2.472	2.398	2.283	2.223	2.309	2.404	2.406	2.368	2.430	2.437	2.485	2.507	(41)	
(42)		Ebn at Noon	892	903	893	882	895	917	917	904	908	876	866	865	(42)	
(43)		Edh at Noon	81	99	123	138	129	118	116	118	105	94	79	74	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.24	3.06	4.32	5.48	6.44	7.45	7.69	6.80	5.57	3.99	2.81	2.04	(44)	
(45)		RadStd	0.27	0.36	0.32	0.45	0.44	0.44	0.24	0.22	0.33	0.23	0.24	0.27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page