

ISPARTA, Turkey

WMO: 172400

Lat: 37.7852N

Lon: 30.5668E

Elev: 997

StdP: 89.91

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.7	-5.8	-13.4	1.3	-5.6	-11.4	1.6	-3.7	8.3	6.4	7.2	7.0	1.4	270	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	33.7	18.5	32.3	18.2	31.0	17.8	21.1	30.6	20.0	29.2	19.0	28.2	2.4	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.6	14.3	27.0	16.5	13.3	25.8	15.4	12.4	24.6	66.1	30.7	61.8	29.2	58.2	28.2	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.4	4.6	-10.9	35.9	2.5	1.5	-12.8	37.0	-14.2	37.8	-15.7	38.7	-17.5	39.8		
(5)			-11.7	22.1	2.5	1.3	-13.5	23.1	-14.9	23.8	-16.3	24.5	-18.1	25.5	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.7	2.3	3.8	6.8	10.9	15.6	20.1	23.7	23.6	19.1	13.8	8.1	4.0		
	DBStd	8.11	3.70	3.71	3.46	3.42	3.01	2.79	2.14	2.19	2.79	3.13	3.49	3.63		
	HDD10.0	819	239	174	108	28	1	0	0	0	7	73	189			
	HDD18.3	2509	498	406	358	223	92	14	0	1	23	142	307	446		
	CDD10.0	1807	0	1	8	55	176	302	424	422	274	126	17	1		
	CDD18.3	454	0	0	0	1	9	66	166	164	48	2	0	0		
	CDH23.3	5352	0	0	0	16	171	767	1889	1825	632	52	1	0		
	CDH26.7	2086	0	0	0	1	27	241	823	786	204	4	0	0		
(14) Wind	WSAvg	1.7	1.7	1.9	2.1	2.0	1.7	1.6	1.7	1.5	1.4	1.4	1.4	1.5		
(15) Precipitation	PrecAvg	542	74	65	57	53	54	30	15	13	17	38	48	83		
	PrecMax	969	259	181	169	154	150	112	87	68	98	141	202	360		
	PrecMin	283	2	4	5	3	2	1	0	0	0	0	0	0		
	PrecStd	153	54	42	34	30	33	24	20	16	19	32	36	67		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	15.6	19.7	25.3	29.2	33.0	35.8	35.5	33.2	27.2	20.7	14.7		
		MCWB	7.0	8.4	10.6	13.3	16.2	18.3	19.4	18.7	16.2	15.0	11.3	7.5		
	2%	DB	10.4	13.2	17.2	22.7	27.1	31.2	33.9	33.8	30.8	24.7	18.2	12.4		
		MCWB	6.5	7.1	8.9	12.2	15.2	17.5	18.8	18.6	16.5	14.1	10.7	7.6		
	5%	DB	9.0	11.2	15.4	20.2	25.2	29.4	32.5	32.3	29.0	22.9	16.4	10.8		
		MCWB	5.6	6.2	8.2	11.3	14.7	17.1	18.5	18.4	15.9	13.5	9.7	7.2		
	10%	DB	7.7	9.6	13.4	18.1	23.3	27.7	31.1	30.9	27.1	20.9	14.5	9.5		
		MCWB	5.0	5.7	7.5	10.4	14.0	16.5	17.9	18.1	15.6	12.6	9.1	6.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	9.2	11.7	14.2	17.6	20.1	22.9	22.4	19.6	16.6	12.7	9.5		
		MCDB	10.6	14.2	18.2	22.9	27.3	30.1	33.1	31.7	27.9	24.4	18.2	12.4		
	2%	WB	7.0	7.8	9.8	12.8	16.2	18.9	21.2	21.2	18.2	15.2	11.5	8.5		
		MCDB	9.4	11.8	15.4	20.9	25.0	28.6	31.1	30.4	26.8	22.0	16.3	11.2		
	5%	WB	6.1	6.9	8.8	11.8	15.3	18.0	20.1	20.1	17.1	14.2	10.6	7.7		
		MCDB	8.6	10.1	14.0	19.1	23.6	27.3	29.6	29.1	26.0	20.7	15.0	10.2		
	10%	WB	5.2	6.1	7.9	10.8	14.4	17.1	19.0	19.1	16.3	13.4	9.7	6.8		
		MCDB	7.5	9.2	12.8	17.1	22.0	26.0	28.3	28.2	25.1	19.6	13.6	9.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	8.8	10.0	10.9	12.5	13.4	14.1	14.2	14.5	12.6	11.2	8.2		
		MCDBR	9.6	12.2	14.3	15.5	16.1	15.8	16.4	16.3	17.8	16.2	15.1	10.6		
	5% WB	MCWBR	6.4	7.2	7.8	7.4	7.0	6.4	6.4	6.2	7.1	7.5	8.3	6.7		
		MCWBR	7.9	9.8	12.2	13.6	14.7	14.4	15.1	14.6	15.3	13.7	12.0	8.1		
(40) Clear-Sky Solar Irradiance	taub		0.313	0.345	0.396	0.432	0.415	0.381	0.378	0.386	0.361	0.358	0.327	0.313		
	taud		2.399	2.303	2.154	2.085	2.197	2.333	2.340	2.296	2.373	2.356	2.413	2.441		
	Ebn at Noon		867	877	860	849	868	896	896	881	887	851	842	842		
	Edh at Noon		87	109	140	159	145	126	124	127	111	102	85	79		
(44) All-Sky Solar Radiation	RadAvg		2.16	3.00	4.29	5.42	6.38	7.39	7.65	6.79	5.55	3.95	2.78	2.00		
	RadStd		0.29	0.37	0.32	0.44	0.46	0.47	0.23	0.19	0.33	0.24	0.24	0.29		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.36	N/A	N/A	+0.75	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page