

ISPARTA SULEYMAN DEMIREL, Turkey

WMO: 172410

Lat: 37.855N

Lon: 30.368E

Elev: 2835

StdP: 13.25

Time Zone: 3.00 (E03)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.7	21.2	8.8	9.6	24.0	12.2	11.4	26.5	27.3	40.2	25.0	39.8	7.2	340	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.9	96.5	62.7	93.5	62.1	91.4	61.8	66.2	84.6	65.1	84.4	64.1	83.9	9.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.0	88.9	71.5	59.1	83.1	71.3	57.3	77.8	70.1	32.5	85.4	31.5	84.3	30.7	83.9	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.4	20.6	18.1	DB	11.8	100.2	4.5	2.8	8.5	102.2	5.9	103.8	3.4	105.4	0.2	107.4	(4)
			WB	10.8	69.0	4.3	1.7	7.8	70.3	5.3	71.2	2.9	72.2	-0.2	73.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	56.3	36.2	40.2	46.0	53.3	61.2	70.1	77.3	68.8	58.2	47.3	39.1	(6)	
(7)		DBStd	15.20	6.63	6.93	5.51	5.29	5.37	5.05	3.70	3.52	5.05	5.35	5.95	6.40	(7)
(8)		HDD50	1337	427	278	144	25	0	0	0	0	8	116	339	(8)	
(9)		HDD65	4248	892	695	589	353	142	9	0	0	21	214	531	802	(9)
(10)		CDD50	3647	0	3	19	122	347	604	845	843	565	262	35	2	(10)
(11)		CDD65	1085	0	0	0	0	24	163	380	378	136	4	0	0	(11)
(12)		CDH74	14227	0	0	0	77	539	2159	4779	4628	1857	187	1	0	(12)
(13)		CDH80	6689	0	0	0	5	132	882	2501	2380	765	24	0	0	(13)
(14)	Wind	WSAvg	7.6	7.3	7.6	8.4	7.9	7.4	8.3	9.2	8.6	7.6	6.7	6.1	6.3	(14)
(15)	Precipitation	PrecAvg	18.5	2.0	1.7	2.1	2.2	2.0	1.1	0.9	0.6	0.7	1.4	1.8	2.5	(15)
(16)		PrecMax	24.4	6.5	3.2	5.4	5.3	4.6	3.0	2.3	2.3	3.3	5.0	4.8	8.2	(16)
(17)		PrecMin	12.9	0.1	0.6	0.4	0.9	0.2	0.1	0.0	0.0	0.0	0.1	0.3	0.0	(17)
(18)		PrecStd	3.1	1.3	0.7	1.3	1.1	1.0	0.7	0.7	0.6	0.8	1.2	1.1	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.6	63.0	69.5	80.5	87.4	95.4	100.6	98.9	94.4	82.8	71.1	60.5	(19)
(20)		0.4%	MCWB	46.5	48.8	50.8	56.6	59.7	62.6	63.8	63.8	60.6	56.8	53.5	49.5	(20)
(21)		2%	DB	51.9	58.7	65.8	75.8	84.0	91.7	97.0	96.1	91.3	78.9	67.6	55.4	(21)
(22)		2%	MCWB	44.6	46.9	49.1	54.4	59.0	61.4	62.6	62.7	60.2	56.4	52.4	47.2	(22)
(23)		5%	DB	49.6	55.1	62.4	71.8	80.5	89.2	93.6	93.4	88.0	75.3	63.0	52.1	(23)
(24)		5%	MCWB	43.5	45.6	47.7	53.4	58.2	60.9	62.4	62.4	59.1	55.6	50.5	45.5	(24)
(25)		10%	DB	46.6	51.7	58.8	67.8	76.6	85.6	91.4	91.3	84.5	71.8	59.3	49.8	(25)
(26)		10%	MCWB	41.8	43.7	47.0	52.1	57.2	60.4	62.1	62.1	58.9	54.6	49.0	44.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.0	50.7	52.6	58.7	62.6	66.0	68.1	68.2	65.0	60.2	56.4	51.0	(27)
(28)		0.4%	MCDWB	53.5	61.0	64.3	75.4	80.4	82.1	86.3	83.7	81.7	73.8	66.1	57.1	(28)
(29)		2%	WB	45.4	47.9	50.8	55.8	60.8	64.1	66.1	66.5	63.1	58.7	54.0	48.3	(29)
(30)		2%	MCDWB	51.1	56.1	61.6	71.2	78.0	82.7	85.8	84.3	80.5	70.8	63.7	54.3	(30)
(31)		5%	WB	43.8	46.2	48.9	54.3	59.3	63.0	64.8	65.4	61.9	57.5	52.0	46.8	(31)
(32)		5%	MCDWB	48.6	54.1	59.6	68.9	75.6	81.5	85.4	84.2	79.3	70.4	60.5	51.4	(32)
(33)		10%	WB	42.1	44.5	47.5	52.6	58.0	61.9	63.8	64.4	60.7	56.2	50.3	45.0	(33)
(34)		10%	MCDWB	45.8	50.9	57.4	65.7	73.0	80.0	84.9	83.9	78.5	68.8	58.5	49.0	(34)
(35)	Mean Daily Temperature Range		MDBR	16.2	19.0	21.7	24.9	25.7	27.3	27.9	28.1	28.5	25.7	23.4	17.5	(35)
(36)		5% DB	MCDBR	20.5	24.9	30.3	33.5	32.5	31.7	31.9	31.3	34.4	31.7	29.5	21.5	(36)
(37)			MCWBR	13.7	14.8	16.3	15.8	13.0	10.3	10.0	10.0	12.7	14.2	16.5	14.0	(37)
(38)			MCDBR	17.2	22.1	24.7	29.2	28.4	28.0	28.2	27.4	28.1	26.1	24.3	17.8	(38)
(39)		5% WB	MCWBR	12.0	13.4	14.0	14.7	12.4	9.8	8.9	8.7	10.2	12.3	14.2	12.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.305	0.335	0.380	0.413	0.400	0.370	0.367	0.374	0.352	0.349	0.320	0.306	(40)	
(41)		taud	2.433	2.353	2.223	2.159	2.261	2.372	2.376	2.336	2.406	2.402	2.452	2.473	(41)	
(42)		Ebn at Noon	279	282	278	275	280	287	287	283	285	274	271	270	(42)	
(43)		Edh at Noon	27	33	41	47	43	38	38	39	34	31	26	24	(43)	
(44)	All-Sky Solar Radiation	RadAvg	688	955	1359	1720	2023	2343	2428	2154	1758	1252	881	635	(44)	
(45)		RadStd	89	117	101	139	146	149	75	64	105	76	78	91	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	(47)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page