

KONYA, Turkey

WMO: 172440

Lat: 37.984N

Lon: 32.574E

Elev: 3383

StdP: 12.99

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	16.7	7.8	9.3	15.8	11.1	11.0	20.2	29.1	32.8	25.9	31.5	3.8	340	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	93.5	61.7	91.2	61.5	88.2	60.9	65.2	85.3	63.6	84.1	62.4	83.0	9.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.4	82.6	72.1	56.0	75.6	70.4	54.7	72.1	69.7	32.0	84.8	30.6	84.1	29.7	83.0	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.9	20.7	18.5	4.9	97.9	6.5	2.7	0.3	99.9	-3.5	101.5	-7.1	103.0	-11.8	104.9		
(5)			4.3	67.3	6.2	2.2	-0.1	68.9	-3.7	70.2	-7.2	71.4	-11.7	72.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.3	32.9	36.2	43.7	52.0	61.1	69.2	75.7	75.6	67.2	56.4	44.6	35.7		
	DBStd	16.47	8.49	8.53	7.47	7.03	5.95	5.44	4.60	4.84	5.88	6.69	7.48	7.83		
	HDD50	1848	531	387	219	56	2	0	0	0	0	23	186	444		
	HDD65	4862	996	806	661	391	149	21	0	1	44	273	613	907		
	CDD50	3417	0	2	23	117	346	577	797	793	517	221	23	1		
	CDD65	955	0	0	0	2	28	148	333	329	110	5	0	0		
	CDH74	10580	0	0	7	66	436	1572	3667	3470	1236	126	0	0		
	CDH80	4173	0	0	0	9	84	525	1641	1505	393	16	0	0		
(14) Wind	WSAvg	8.0	6.6	7.5	8.6	8.1	7.8	9.3	10.5	10.0	8.1	7.2	6.0	6.1		
(15) Precipitation	PrecAvg	12.9	1.4	1.1	1.1	1.4	1.5	0.9	0.3	0.2	0.6	1.2	1.3	1.9		
	PrecMax	19.7	3.8	2.4	3.6	3.3	3.1	3.1	1.1	0.7	3.5	3.3	4.3	4.7		
	PrecMin	7.6	0.0	0.2	0.2	0.3	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	2.8	0.8	0.5	0.7	0.8	0.7	0.8	0.3	0.2	0.8	0.9	1.0	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.7	63.0	72.5	80.7	86.2	91.7	97.4	96.8	91.5	82.3	68.9	59.0		
		MCWB	44.8	46.7	49.7	54.7	58.0	60.2	62.5	62.4	59.5	57.2	51.8	47.4		
	2%	DB	51.7	57.3	66.3	75.1	82.2	88.4	94.8	93.4	87.8	77.3	64.7	53.6		
		MCWB	43.0	45.0	47.6	52.6	57.3	60.2	62.1	61.9	59.2	54.9	50.4	45.5		
	5%	DB	47.8	53.5	62.3	71.2	78.9	85.9	91.6	91.2	84.5	73.7	60.9	49.9		
		MCWB	41.6	43.4	46.8	51.6	56.3	59.5	61.7	61.9	58.1	54.4	48.5	43.6		
	10%	DB	44.2	49.7	57.6	66.4	75.4	82.7	88.3	88.0	81.0	69.9	57.2	46.5		
		MCWB	40.1	41.7	45.1	50.0	55.4	58.6	61.3	61.5	57.4	53.2	47.2	42.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.4	48.4	51.5	56.5	60.4	64.3	69.4	68.4	63.5	59.3	54.3	48.7		
		MCDB	53.3	59.3	68.1	72.9	78.7	83.1	88.7	86.3	79.6	73.4	64.5	55.4		
	2%	WB	43.9	46.0	49.2	54.2	58.8	62.3	65.4	65.5	61.2	57.3	51.8	46.4		
		MCDB	49.9	55.9	63.0	70.5	77.3	81.0	85.8	85.6	80.0	71.2	61.7	52.2		
	5%	WB	41.9	43.9	47.4	52.4	57.5	61.1	63.6	63.8	59.9	55.8	49.8	44.3		
		MCDB	46.7	51.9	59.9	67.7	74.6	79.7	84.9	84.4	79.0	69.3	58.9	49.0		
	10%	WB	39.9	41.9	45.7	50.9	56.4	60.0	62.3	62.6	58.7	54.5	47.9	42.4		
		MCDB	43.6	48.5	56.8	64.7	72.5	78.3	83.8	83.3	77.4	67.2	55.5	45.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.3	17.2	20.6	21.9	22.9	23.0	23.3	22.8	23.8	21.5	19.9	14.2		
		MCDBR	20.2	24.3	28.9	29.2	28.6	26.6	27.4	26.0	28.4	28.0	26.4	19.8		
		MCWBR	13.0	13.9	14.4	12.9	11.4	9.6	10.0	9.8	11.5	12.7	14.4	12.9		
	5% WB	MCDBR	18.3	22.2	25.9	25.6	25.5	23.5	23.9	22.5	24.6	23.4	22.7	17.5		
		MCWBR	12.4	13.2	13.5	12.4	10.9	9.2	9.2	8.9	10.5	11.1	13.0	12.0		
(40) Clear-Sky Solar Irradiance	taub		0.298	0.324	0.361	0.399	0.383	0.361	0.360	0.362	0.338	0.339	0.310	0.297		
	taud		2.412	2.345	2.248	2.165	2.268	2.348	2.345	2.310	2.388	2.387	2.437	2.455		
	Ebn at Noon		281	286	284	279	285	290	290	287	289	277	274	273		
	Edh at Noon		27	33	40	46	43	39	39	40	35	31	26	24		
(44) All-Sky Solar Radiation	RadAvg		686	1007	1381	1739	2043	2344	2433	2179	1757	1236	861	612		
	RadStd		86	114	81	144	131	139	76	50	99	75	88	75		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+1.06	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page