

OGUZELI, Turkey

WMO: 172600

Lat: 36.947N

Lon: 37.471E

Elev: 2315

StdP: 13.51

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.3	26.8	9.5	9.7	35.7	13.9	12.1	36.1	20.5	42.1	18.0	39.2	3.8	340	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.7	102.4	69.3	100.3	68.3	98.2	67.6	74.2	97.5	72.4	95.5	70.9	93.2	7.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	105.1	89.9	64.2	98.1	87.7	62.4	91.9	86.4	39.4	97.1	37.7	96.1	36.2	93.6	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	16.5	14.3	18.6	105.8	3.9	2.6	15.8	107.7	13.5	109.2	11.4	110.6	8.5	112.5
			17.0	76.6	3.7	4.8	14.3	80.0	12.2	82.8	10.1	85.5	7.5	89.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.7	40.0	42.7	49.4	57.4	67.3	77.7	85.1	84.7	76.0	64.7	51.6	43.1		
	DBStd	16.76	4.99	5.58	5.43	6.11	6.04	5.19	3.99	3.72	5.07	5.92	6.07	5.44		
	HDD50	877	309	209	77	9	0	0	0	0	0	1	53	219		
	HDD65	3331	774	625	484	237	47	0	0	0	2	80	403	679		
	CDD50	5165	1	4	58	231	537	830	1087	1075	780	456	101	5		
	CDD65	2141	0	0	0	8	119	380	622	610	332	70	0	0		
	CDH74	29055	0	0	3	192	1567	4945	8938	8508	4006	888	8	0		
	CDH80	15995	0	0	0	35	551	2577	5433	5140	2022	237	0	0		
	WSAvg	5.6	4.9	5.1	5.8	5.7	5.8	7.8	8.2	6.7	5.4	4.1	3.8	4.4		
	PrecAvg	21.1	3.6	3.3	2.4	2.0	1.2	0.3	0.1	0.2	0.4	1.5	2.6	3.6		
(15) Precipitation	PrecMax	36.5	8.9	6.6	8.8	5.8	3.9	1.2	1.3	2.4	2.1	4.1	8.0	9.1		
	PrecMin	13.9	0.9	0.5	0.2	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6		
	PrecStd	5.6	1.9	1.6	1.7	1.3	0.8	0.3	0.2	0.4	0.5	1.1	1.7	2.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.6	65.9	72.3	84.5	94.1	100.7	106.2	104.5	98.9	89.3	75.2	64.7		
		MCWB	47.4	51.4	55.8	62.3	71.2	67.7	70.9	69.4	65.3	66.7	56.7	50.3		
	2%	DB	54.5	60.5	68.3	78.8	89.3	97.6	103.6	102.3	96.4	85.7	71.6	59.2		
		MCWB	45.9	49.2	53.4	59.4	65.9	66.8	69.6	69.5	65.9	63.9	56.2	48.4		
	5%	DB	51.8	56.8	65.2	75.3	86.0	95.0	100.7	100.3	93.4	82.5	68.1	55.7		
		MCWB	44.5	47.4	52.3	57.8	63.9	66.5	68.1	69.0	65.4	61.8	54.5	46.4		
	10%	DB	48.9	53.4	62.1	71.7	82.6	92.2	98.4	98.2	90.9	79.1	64.5	52.3		
		MCWB	43.3	45.9	50.6	56.5	63.1	65.9	67.8	68.0	65.1	60.1	52.5	45.7		
	0.4%	WB	50.3	52.8	58.9	66.4	73.7	74.7	77.6	76.5	72.8	69.6	61.7	53.1		
		MCDB	54.8	62.1	69.9	78.9	91.6	94.8	100.0	99.8	93.7	86.0	72.2	61.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	47.8	50.3	55.5	63.1	69.7	71.5	74.1	74.1	70.8	66.6	58.6	50.6		
		MCDB	52.1	58.5	66.0	74.4	85.6	92.0	98.5	98.3	91.3	82.3	68.4	55.5		
	5%	WB	46.0	48.4	53.2	60.1	66.6	69.3	72.4	72.2	68.8	64.2	55.9	49.0		
		MCDB	49.8	55.3	62.3	71.7	82.3	90.8	97.1	96.0	88.3	79.5	64.7	53.2		
	10%	WB	44.2	46.6	51.2	57.7	64.1	67.7	70.5	70.6	66.7	61.8	53.4	47.2		
		MCDB	47.9	52.3	60.2	69.6	79.8	88.7	94.3	93.2	85.6	75.6	61.4	51.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.9	17.2	19.9	22.4	24.9	25.8	25.7	26.3	26.8	24.5	21.4	15.9		
		MCDBR	20.8	23.7	25.8	28.7	30.0	28.1	28.2	28.3	29.8	29.4	27.7	23.4		
		MCWBR	14.7	15.9	15.6	15.2	15.5	12.1	11.4	11.9	12.8	15.7	17.1	15.2		
		MCDBR	16.4	20.4	22.8	24.9	27.4	26.1	26.2	26.7	27.3	26.0	23.4	17.4		
	5% WB	MCWBR	12.9	14.7	15.9	17.2	18.5	15.4	14.3	14.3	16.0	17.2	16.9	12.8		
(40) Clear-Sky Solar Irradiance	taub		0.345	0.368	0.396	0.444	0.424	0.376	0.370	0.384	0.358	0.391	0.353	0.340		
	taud		2.292	2.223	2.159	2.040	2.152	2.308	2.331	2.284	2.353	2.227	2.303	2.319		
	Ebn at Noon		262	271	274	266	273	286	287	281	283	259	257	256		
	Edh at Noon		31	38	44	53	48	41	40	41	36	37	31	29		
(44) All-Sky Solar Radiation	RadAvg		685	948	1402	1781	2167	2551	2534	2238	1830	1271	896	652		
	RadStd		95	148	103	137	114	81	51	66	63	80	91	110		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-3.82	N/A	-1.84	N/A	N/A	-97	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	-3.15	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page