

OGUZELI, Turkey

WMO: 172600

Lat: 36.947N

Lon: 37.471E

Elev: 706

StdP: 93.13

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.3	-2.9	-12.5	1.4	2.1	-10.0	1.7	2.3	9.1	5.6	8.0	4.0	1.7	340	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	39.1	20.7	38.0	20.2	36.8	19.8	23.4	36.4	22.5	35.3	21.6	34.0	3.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	15.0	32.2	17.9	14.0	31.0	16.9	13.1	30.2	73.9	36.2	69.8	35.6	66.4	34.2	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.4	7.4	6.4	DB	-7.4	41.0	2.2	1.4	-9.0	42.0	-10.3	42.9	-11.5	43.7	-13.0	44.7	(4)
			WB	-8.3	24.8	2.0	2.7	-9.8	26.7	-11.0	28.2	-12.1	29.7	-13.6	31.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	4.5	5.9	9.7	14.1	19.6	25.4	29.5	29.3	24.5	18.2	10.9	6.2	(6)
(7)		DBStd	9.31	2.77	3.10	3.01	3.39	3.36	2.88	2.21	2.07	2.82	3.29	3.37	3.02	(7)
(8)		HDD10.0	487	172	116	43	5	0	0	0	0	1	29	122		(8)
(9)		HDD18.3	1851	430	347	269	132	26	0	0	1	44	224	377		(9)
(10)		CDD10.0	2869	1	2	32	128	298	461	604	597	433	253	56	3	(10)
(11)		CDD18.3	1189	0	0	0	4	66	211	346	339	184	39	0	0	(11)
(12)		CDH23.3	16142	0	0	2	107	871	2747	4966	4727	2226	493	4	0	(12)
(13)		CDH26.7	8886	0	0	0	19	306	1432	3018	2856	1123	132	0	0	(13)
(14)	Wind	WSAvg	2.5	2.2	2.3	2.6	2.6	3.5	3.7	3.0	2.4	1.8	1.7	2.0	(14)	
(15)	Precipitation	PrecAvg	537	91	85	62	50	31	7	3	9	37	65	91	(15)	
(16)		PrecMax	926	227	168	224	147	99	31	32	60	54	103	202	231	(16)
(17)		PrecMin	354	23	13	5	8	1	0	0	0	0	0	0	16	(17)
(18)		PrecStd	142	49	41	43	34	21	8	6	11	12	27	42	55	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.2	18.9	22.4	29.2	34.5	38.1	41.2	40.3	37.2	31.8	24.0	18.2	(19)
(20)		0.4%	MCWB	8.5	10.8	13.2	16.8	21.8	19.9	21.6	20.8	18.5	19.3	13.7	10.2	(20)
(21)		2%	DB	12.5	15.8	20.1	26.0	31.8	36.5	39.8	39.1	35.8	29.8	22.0	15.1	(21)
(22)		2%	MCWB	7.7	9.6	11.9	15.2	18.8	19.3	20.9	20.9	18.8	17.7	13.4	9.1	(22)
(23)		5%	DB	11.0	13.8	18.4	24.1	30.0	35.0	38.2	38.0	34.1	28.1	20.1	13.1	(23)
(24)		5%	MCWB	6.9	8.5	11.3	14.3	17.7	19.2	20.0	20.6	18.5	16.5	12.5	8.0	(24)
(25)		10%	DB	9.4	11.9	16.7	22.1	28.1	33.4	36.9	36.8	32.7	26.1	18.0	11.3	(25)
(26)		10%	MCWB	6.3	7.7	10.3	13.6	17.3	18.9	19.9	20.0	18.4	15.6	11.4	7.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	11.6	14.9	19.1	23.1	23.7	25.3	24.7	22.7	20.9	16.5	11.7	(27)
(28)		0.4%	MCDWB	12.7	16.7	21.1	26.1	33.1	34.9	37.8	37.7	34.3	30.0	22.3	16.3	(28)
(29)		2%	WB	8.8	10.2	13.0	17.3	20.9	22.0	23.4	23.4	21.6	19.2	14.8	10.3	(29)
(30)		2%	MCDWB	11.2	14.7	18.9	23.5	29.8	33.3	36.9	36.8	32.9	27.9	20.2	13.1	(30)
(31)		5%	WB	7.8	9.1	11.8	15.6	19.2	20.7	22.4	22.3	20.5	17.9	13.3	9.4	(31)
(32)		5%	MCDWB	9.9	12.9	16.9	22.1	27.9	32.7	36.1	35.5	31.3	26.4	18.2	11.8	(32)
(33)		10%	WB	6.8	8.1	10.7	14.3	17.8	19.8	21.4	21.4	19.3	16.5	11.9	8.5	(33)
(34)		10%	MCDWB	8.8	11.3	15.7	20.9	26.6	31.5	34.6	34.0	29.8	24.2	16.3	10.6	(34)
(35)	Mean Daily Temperature Range		MDBR	8.3	9.5	11.0	12.4	13.9	14.4	14.3	14.6	14.9	13.6	11.9	8.8	(35)
(36)		5% DB	MCDBR	11.6	13.2	14.3	15.9	16.7	15.6	15.7	16.6	16.3	15.4	13.0		(36)
(37)			MCWBR	8.2	8.8	8.7	8.4	8.6	6.7	6.3	6.6	7.1	8.7	9.5	8.4	(37)
(38)			MCDBR	9.1	11.3	12.6	13.8	15.2	14.5	14.5	14.8	15.1	14.5	13.0	9.6	(38)
(39)		5% WB	MCWBR	7.2	8.2	8.8	9.5	10.3	8.5	7.9	7.9	8.9	9.5	9.4	7.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.345	0.368	0.396	0.444	0.424	0.376	0.370	0.384	0.358	0.391	0.353	0.340	(40)	
(41)		taud	2.292	2.223	2.159	2.040	2.152	2.308	2.331	2.284	2.353	2.227	2.303	2.319	(41)	
(42)		Ebn at Noon	827	853	863	839	862	902	904	885	892	816	810	806	(42)	
(43)		Edh at Noon	99	120	140	167	152	130	126	129	114	117	97	90	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.16	2.99	4.42	5.62	6.83	8.04	7.99	7.06	5.77	4.01	2.83	2.06	(44)	
(45)		RadStd	0.30	0.47	0.32	0.43	0.36	0.26	0.16	0.21	0.20	0.25	0.29	0.35	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	-2.12	N/A	-1.02	N/A	N/A	-54	N/A	N/A	(46)
(47)	Regional (11 neighbors)	N/A	N/A	-1.75	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page