

SANLIURFA, Turkey

WMO: 172700

Lat: 37.1604N

Lon: 38.7867E

Elev: 1801

StdP: 13.76

Time Zone: 3.00 (E03)

Period: 98-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.0	(c) 32.6	(d) 10.9	(e) 10.2	(f) 40.0	(g) 15.0	(h) 12.6	(i) 42.9	(j) 14.0	(k) 42.9	(l) 11.5	(m) 42.9	(n) 3.8	(o) 300	(p) 0.407

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.2	105.9	69.9	103.7	69.6	101.5	69.0	77.3	97.0	75.2	96.0	73.4	94.3	5.2	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.4	123.8	90.9	68.6	112.3	88.5	66.3	103.8	87.2	42.2	96.5	40.1	95.9	38.3	93.9	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.8	(b) 11.3	(c) 9.5	(e) 26.9	(f) 109.5	(g) 2.8	(h) 2.3	(i) 24.9	(j) 111.1	(k) 23.3	(l) 112.5	(m) 21.7	(n) 113.8	(o) 19.7	(p) 115.4		
(a) 13.8	(b) 11.3	(c) 9.5	(e) 23.0	(f) 79.8	(g) 2.1	(h) 3.8	(i) 21.5	(j) 82.6	(k) 20.2	(l) 84.8	(m) 19.0	(n) 87.0	(o) 17.5	(p) 89.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	66.8	44.0	47.0	54.2	63.0	73.4	83.8	90.4	89.1	81.1	70.8	57.1	47.1	(6)
(7)		DBStd	17.20	5.12	5.94	6.05	6.47	5.98	4.96	4.13	3.97	5.28	6.29	6.68	5.47	(7)
(8)		HDD50	470	192	115	27	1	0	0	0	0	0	0	17	118	(8)
(9)		HDD65	2435	652	504	336	113	8	0	0	0	0	22	244	556	(9)
(10)		CDD50	6618	5	31	156	390	724	1015	1251	1211	933	645	230	27	(10)
(11)		CDD65	3109	0	0	1	52	267	565	786	746	483	202	7	0	(11)
(12)		CDH74	42302	0	0	9	428	2738	7817	12554	11431	5776	1511	36	2	(12)
(13)		CDH80	24944	0	0	0	90	1133	4560	8343	7310	3008	500	0	0	(13)
(14)	Wind	WSAvg	3.7	2.9	3.1	3.7	4.0	4.4	5.2	5.0	4.3	3.8	2.9	2.6	2.7	(14)
(15)	Precipitation	PrecAvg	17.8	3.3	2.8	2.4	1.9	1.1	0.2	0.0	0.1	1.0	1.9	3.2	(15)	
(16)		PrecMax	31.0	12.8	7.0	11.7	9.3	4.4	1.2	0.4	1.0	1.1	4.8	7.4	10.2	(16)
(17)		PrecMin	8.6	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	5.1	2.2	1.7	1.9	1.6	1.2	0.2	0.1	0.2	0.2	1.1	1.3	2.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.0	69.0	75.2	86.8	95.8	104.7	109.8	107.5	102.0	92.0	78.1	66.1	(19)
(20)			MCWB	47.6	51.4	54.7	60.2	65.0	69.0	69.7	71.7	69.6	65.8	55.9	50.3	(20)
(21)		2%	DB	56.7	63.4	72.1	82.3	92.2	101.6	107.2	105.2	98.2	88.2	74.3	60.6	(21)
(22)			MCWB	46.4	50.3	54.6	58.4	63.7	68.2	69.6	71.0	68.1	64.1	55.7	48.8	(22)
(23)		5%	DB	54.0	60.0	68.9	79.0	89.5	99.1	104.8	103.1	95.7	85.5	71.0	57.6	(23)
(24)			MCWB	45.2	48.8	53.5	57.9	63.4	67.0	68.9	70.6	67.5	62.7	55.0	46.8	(24)
(25)		10%	DB	51.6	56.5	65.5	75.5	86.5	96.8	102.5	100.8	93.0	82.5	67.4	54.7	(25)
(26)			MCWB	44.2	47.0	52.0	56.8	62.3	66.2	68.6	70.1	67.1	62.1	53.8	46.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.7	54.0	59.7	64.6	71.1	75.0	78.0	82.8	76.3	69.8	61.1	53.5	(27)
(28)			MCD B	55.4	64.5	69.9	78.0	90.9	99.2	100.5	100.4	95.0	87.1	70.7	60.7	(28)
(29)		2%	WB	48.9	51.8	56.8	62.0	68.2	72.4	75.8	79.5	73.4	67.0	58.8	51.3	(29)
(30)			MCD B	53.3	60.6	67.1	74.9	85.0	95.9	98.1	96.6	92.2	83.9	69.4	56.3	(30)
(31)		5%	WB	47.2	50.0	54.9	60.0	66.0	70.3	74.0	76.4	71.4	65.2	57.0	49.8	(31)
(32)			MCD B	51.6	58.2	65.5	73.2	83.0	93.1	96.5	95.6	90.5	81.7	66.3	54.1	(32)
(33)		10%	WB	45.6	48.2	53.1	58.4	63.9	68.5	72.1	74.4	69.5	63.3	55.3	48.2	(33)
(34)			MCD B	49.7	54.6	63.8	72.0	81.8	90.8	94.9	94.3	88.0	78.7	64.3	52.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.5	14.5	17.4	19.2	21.6	23.1	23.2	22.5	19.3	16.5	12.8	(35)	
(36)			MCDBR	16.2	19.3	21.2	23.0	24.4	24.5	24.5	24.4	23.6	22.3	20.2	17.3	(36)
(37)			MCWBR	9.3	10.3	10.6	9.3	9.3	8.4	8.2	9.4	9.7	10.0	9.7	9.6	(37)
(38)		5% WB	MCDBR	12.6	17.1	19.5	20.1	23.6	25.2	25.0	25.6	23.7	21.2	16.9	12.1	(38)
(39)			MCWBR	8.0	9.9	10.8	10.0	10.5	9.9	9.7	11.6	11.1	10.3	8.7	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.360	0.387	0.412	0.467	0.442	0.384	0.374	0.386	0.364	0.411	0.365	0.355	(40)	
(41)		taud	2.238	2.158	2.113	1.982	2.101	2.288	2.326	2.281	2.338	2.160	2.263	2.257	(41)	
(42)		Ebn at Noon	255	263	268	259	268	284	285	280	281	251	251	248	(42)	
(43)		Edh at Noon	33	40	46	56	50	42	40	41	36	40	32	30	(43)	
(44)	All-Sky Solar Radiation	RadAvg	704	966	1418	1785	2167	2532	2484	2201	1817	1263	893	657	(44)	
(45)		RadStd	88	129	96	137	132	100	63	70	69	83	88	104	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	-1.55	N/A	N/A	N/A	N/A

Nomenclature: See separate page