

SANLIURFA, Turkey

WMO: 172700

Lat: 37.1604N

Lon: 38.7867E

Elev: 549

StdP: 94.90

Time Zone: 3.00 (E03)

Period: 98-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.1	0.3	-11.7	1.5	4.5	-9.4	1.8	6.1	6.3	6.1	5.1	6.1	1.7	300	0.407

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	41.1	21.0	39.9	20.9	38.6	20.6	25.1	36.1	24.0	35.6	23.0	34.6	2.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.9	17.7	32.7	20.3	16.0	31.4	19.1	14.8	30.6	80.2	35.8	75.3	35.5	71.2	34.4	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.2	5.0	4.2	-2.8	43.1	1.6	1.3	-3.9	44.0	-4.8	44.7	-5.7	45.4	-6.8	46.3
			-5.0	26.6	1.2	2.1	-5.9	28.1	-6.5	29.3	-7.2	30.5	-8.1	32.1
	</													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.4	6.6	8.3	12.3	17.2	23.0	28.8	32.4	31.7	27.3	21.6	13.9	8.4	(6)
(7)		DBStd	9.56	2.84	3.30	3.36	3.59	3.32	2.76	2.29	2.21	2.93	3.49	3.71	3.04	(7)
(8)		HDD10.0	261	107	64	15	1	0	0	0	0	0	9	66		(8)
(9)		HDD18.3	1353	362	280	187	63	4	0	0	0	12	136	309		(9)
(10)		CDD10.0	3677	3	17	87	217	402	564	695	673	518	358	128	15	(10)
(11)		CDD18.3	1727	0	0	1	29	148	314	437	414	268	112	4	0	(11)
(12)		CDH23.3	23501	0	0	5	238	1521	4343	6974	6351	3209	839	20	1	(12)
(13)		CDH26.7	13858	0	0	0	50	629	2533	4635	4061	1671	278	0	0	(13)
(14)	Wind	WSAvg	1.7	1.3	1.4	1.7	1.8	2.0	2.3	2.3	1.9	1.7	1.3	1.2	1.2	(14)
(15)	Precipitation	PrecAvg	452	84	70	62	47	27	4	1	1	2	26	47	81	(15)
(16)		PrecMax	787	326	177	297	236	112	31	10	26	29	123	188	259	(16)
(17)		PrecMin	219	1	2	3	1	0	0	0	0	0	1	0		(17)
(18)		PrecStd	129	57	42	49	41	31	6	2	4	5	29	32	50	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.6	20.6	24.0	30.5	35.4	40.4	43.2	41.9	38.9	33.3	25.6	19.0	(19)
(20)		MCWB	8.7	10.8	12.6	15.6	18.4	20.6	20.9	22.0	20.9	18.8	13.3	10.2		(20)
(21)		2%	DB	13.7	17.5	22.3	28.0	33.5	38.6	41.8	40.7	36.8	31.2	23.5	15.9	(21)
(22)		MCWB	8.0	10.2	12.6	14.7	17.6	20.1	20.9	21.7	20.1	17.8	13.2	9.3		(22)
(23)		5%	DB	12.2	15.5	20.5	26.1	31.9	37.3	40.4	39.5	35.4	29.7	21.7	14.2	(23)
(24)		MCWB	7.3	9.3	12.0	14.4	17.4	19.5	20.5	21.4	19.7	17.1	12.8	8.2		(24)
(25)		10%	DB	10.9	13.6	18.6	24.2	30.3	36.0	39.1	38.2	33.9	28.1	19.7	12.6	(25)
(26)		MCWB	6.8	8.3	11.1	13.8	16.8	19.0	20.3	21.2	19.5	16.7	12.1	7.8		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	12.2	15.4	18.1	21.7	23.9	25.6	28.2	24.6	21.0	16.1	11.9	(27)
(28)		MCDWB	13.0	18.0	21.1	25.6	32.7	37.3	38.0	38.0	35.0	30.6	21.5	15.9		(28)
(29)		2%	WB	9.4	11.0	13.8	16.7	20.1	22.4	24.3	26.4	23.0	19.5	14.9	10.7	(29)
(30)		MCDWB	11.8	15.9	19.5	23.9	29.5	35.5	36.7	35.9	33.4	28.8	20.8	13.5		(30)
(31)		5%	WB	8.5	10.0	12.7	15.6	18.9	21.3	23.3	24.7	21.9	18.4	13.9	9.9	(31)
(32)		MCDWB	10.9	14.6	18.6	22.9	28.4	33.9	35.9	35.3	32.5	27.6	19.1	12.3		(32)
(33)		10%	WB	7.5	9.0	11.7	14.7	17.7	20.3	22.3	23.6	20.8	17.4	12.9	9.0	(33)
(34)		MCDWB	9.8	12.6	17.7	22.2	27.7	32.7	34.9	34.6	31.1	26.0	18.0	11.3		(34)
(35)	Mean Daily Temperature Range	MDBR	7.0	8.1	9.7	10.7	12.0	12.8	12.9	12.9	12.5	10.7	9.1	7.1	(35)	
(36)		5% DB	MCDBR	9.0	10.7	11.8	12.8	13.5	13.6	13.6	13.1	12.4	11.2	9.6		(36)
(37)		MCWBR	5.1	5.7	5.9	5.2	5.1	4.7	4.6	5.2	5.4	5.5	5.4	5.3	(37)	
(38)		5% WB	MCDBR	7.0	9.5	10.8	11.2	13.1	14.0	13.9	14.2	13.2	11.8	9.4	6.7	(38)
(39)		MCWBR	4.4	5.5	6.0	5.5	5.8	5.5	5.4	6.5	6.2	5.7	4.8	4.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.360	0.387	0.412	0.467	0.442	0.384	0.374	0.386	0.364	0.411	0.365	0.355	(40)	
(41)		taud	2.238	2.158	2.113	1.982	2.101	2.288	2.326	2.281	2.338	2.160	2.263	2.257	(41)	
(42)		Ebn at Noon	805	829	846	818	846	894	900	882	885	791	792	781	(42)	
(43)		Edh at Noon	104	127	146	177	159	132	126	129	115	125	101	96	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.22	3.05	4.47	5.63	6.83	7.98	7.83	6.94	5.73	3.98	2.81	2.07	(44)	
(45)		RadStd	0.28	0.41	0.30	0.43	0.41	0.32	0.20	0.22	0.22	0.26	0.28	0.33	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (9 neighbors)	N/A	N/A	N/A	-0.86	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page