

SANLIURFA GAP, Turkey

WMO: 172710

Lat: 37.445N

Lon: 38.904E

Elev: 822

StdP: 91.83

Time Zone: 3.00 (E03)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.9	(c) -2.0	(d) -12.8	(e) 1.4	(f) 1.7	(g) -10.4	(h) 1.7	(i) 3.6	(j) 13.0	(k) 6.6	(l) 11.6	(m) 6.2	(n) 4.7	(o) 20	(p) 0.517

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	39.0	17.9	37.9	17.7	36.8	17.5	20.5	31.4	19.8	30.9	19.0	31.6	4.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	13.5	26.6	15.9	12.5	25.7	14.8	11.6	24.7	63.3	31.0	60.4	31.0	57.7	31.2	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.1	8.7	7.6	-6.2	41.1	2.4	1.5	-7.9	42.2	-9.2	43.0	-10.5	43.9	-12.3	44.9
			-7.4	21.8	2.3	1.2	-9.0	22.6	-10.4	23.3	-11.7	24.0	-13.4	24.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	4.3	6.4	9.8	14.8	20.0	26.0	29.9	30.0	25.4	19.0	11.7	6.4		
	DBStd	9.53	3.01	3.33	3.45	3.38	3.36	2.89	2.22	1.99	3.26	3.44	3.35	3.03		
	HDD10.0	474	178	108	46	4	0	0	0	0	0	0	22	116		
	HDD18.3	1777	436	336	264	113	22	0	0	0	2	35	199	370		
	CDD10.0	3039	0	6	40	148	308	481	618	619	463	278	73	4		
	CDD18.3	1299	0	0	0	7	72	231	359	361	215	54	0	0		
	CDH23.3	17001	0	0	0	57	712	2862	5313	5262	2415	379	1	0		
	CDH26.7	9341	0	0	0	4	224	1479	3236	3161	1157	81	0	0		
(14) Wind	WSAvg	3.9	4.1	3.7	4.0	3.9	3.9	4.5	4.3	3.9	3.6	3.5	3.3	4.0		
(15) Precipitation	PrecAvg	440	83	71	55	42	28	5	1	2	6	26	50	72		
	PrecMax	823	186	165	273	123	120	27	8	19	68	70	176	187		
	PrecMin	284	17	16	3	3	1	0	0	0	0	1	0	6		
	PrecStd	120	43	36	52	24	26	7	2	4	13	22	35	45		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	18.2	20.8	27.0	33.1	38.2	40.9	40.2	37.1	30.8	22.9	18.8		
		MCWB	7.2	9.7	11.1	13.8	15.7	17.9	18.3	18.3	16.8	14.8	10.2	9.3		
	2%	DB	11.1	15.2	19.0	24.9	30.9	36.8	39.2	38.9	35.5	28.8	21.1	14.0		
		MCWB	6.3	8.8	10.5	12.7	15.5	17.3	17.9	18.0	16.5	14.5	10.4	8.2		
	5%	DB	9.9	13.1	17.8	23.3	29.1	35.0	38.0	37.8	34.0	27.1	19.1	12.1		
		MCWB	6.0	8.0	10.3	12.5	15.2	16.6	17.7	17.9	16.2	14.1	10.1	7.4		
	10%	DB	8.7	11.7	16.0	21.8	27.2	33.2	36.9	36.8	32.6	25.2	17.8	10.8		
		MCWB	5.7	7.3	9.6	12.0	14.7	16.3	17.4	17.9	15.7	13.6	9.3	6.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	11.2	13.4	15.2	17.5	19.9	21.5	22.0	19.1	17.1	13.6	10.7		
		MCDB	10.6	16.1	17.3	21.7	27.7	32.7	32.4	32.8	28.8	24.8	19.4	14.0		
	2%	WB	8.1	9.8	11.9	14.3	16.7	18.9	20.3	20.9	18.3	16.1	12.4	9.8		
		MCDB	9.2	13.7	16.8	21.5	27.2	32.2	31.6	31.7	28.6	24.2	16.8	12.2		
	5%	WB	7.2	8.8	11.0	13.5	16.1	18.1	19.5	20.1	17.7	15.5	11.6	8.9		
		MCDB	8.8	12.2	15.8	20.8	26.0	30.7	31.6	30.5	28.6	23.4	15.9	10.7		
	10%	WB	6.2	7.9	10.1	12.9	15.5	17.5	18.8	19.4	17.1	14.7	10.7	8.0		
		MCDB	7.6	10.8	14.9	19.9	24.9	29.9	31.8	31.0	28.6	22.3	15.2	9.5		
(35) Mean Daily Temperature Range	MDBR		6.7	7.9	9.1	10.3	11.8	13.1	13.2	12.9	11.9	10.2	9.0	6.8		
	5% DB	MCDBR	8.4	9.9	10.5	12.3	13.4	13.6	13.9	13.6	12.9	11.7	11.1	9.3		
		MCWBR	5.3	5.6	5.6	5.5	5.0	4.2	4.6	4.5	4.6	4.9	5.3	5.6		
	5% WB	MCDBR	6.3	8.5	9.1	10.8	12.3	13.3	13.5	13.3	12.0	10.0	8.5	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.338	0.363	0.388	0.438	0.413	0.361	0.353	0.364	0.342	0.386	0.344	0.334		
	taud		2.314	2.240	2.194	2.069	2.196	2.360	2.389	2.348	2.407	2.248	2.343	2.334		
	Ebn at Noon		833	856	870	844	871	915	920	903	908	819	820	809		
	Edh at Noon		96	117	135	162	145	123	118	121	107	114	92	88		
(44) All-Sky Solar Radiation	RadAvg		2.16	2.98	4.40	5.57	6.81	7.99	7.85	6.96	5.74	3.96	2.79	2.04		
	RadStd		0.30	0.43	0.32	0.47	0.42	0.33	0.20	0.22	0.21	0.27	0.28	0.35		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	N/A	N/A	N/A	N/A	-0.95	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page