

BATMAN, Turkey

WMO: 172820

Lat: 37.933N

Lon: 41.117E

Elev: 1772

StdP: 13.78

Time Zone: 3.00 (E03)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.0	23.3	11.8	10.7	27.6	16.0	13.2	31.3	22.8	48.0	19.2	47.7	3.7	30	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.9	106.4	66.6	104.5	66.2	102.6	65.8	69.7	99.5	68.5	98.1	67.5	96.8	6.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.8	84.9	74.6	59.2	80.1	73.0	57.6	75.7	72.0	34.8	99.8	33.8	98.4	32.9	97.1	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.3	13.7	11.2	13.0	111.0	10.1	2.2	5.7	112.6	-0.2	113.8	-5.8	115.0	-13.2	116.6
			12.2	72.3	9.9	2.1	5.1	73.8	-0.7	75.1	-6.3	76.3	-13.5	77.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.6	38.7	42.5	50.1	58.8	66.9	78.1	84.6	84.8	76.0	65.1	50.9	41.2
	DBStd	17.11	6.51	6.62	6.34	5.77	5.15	4.43	3.30	2.97	5.29	5.66	5.43	6.83
	HDD50	981	350	219	76	3	0	0	0	0	0	0	53	280
	HDD65	3382	815	630	462	201	40	0	0	0	2	70	424	738
	CDD50	5207	0	9	80	267	524	842	1073	1079	781	467	79	6
	CDD65	2135	0	0	1	15	99	392	608	614	334	72	0	0
	CDH74	33255	0	0	20	339	1636	6150	9721	9499	4843	1045	2	0
	CDH80	20997	0	0	4	92	637	3775	6702	6584	2850	353	0	0
Wind	WSAvg	4.5	4.4	4.5	5.3	5.0	4.7	5.0	4.8	4.6	4.4	3.8	3.2	3.9
Precipitation	PrecAvg	21.1	3.2	3.4	3.0	2.8	1.5	0.3	0.1	0.0	0.2	1.2	2.2	3.3
	PrecMax	30.9	6.5	6.9	8.8	7.0	7.2	1.3	0.2	0.3	1.1	3.9	6.9	7.2
	PrecMin	14.0	1.0	1.5	0.8	0.8	0.2	0.0	0.0	0.0	0.0	0.2	0.2	0.1
	PrecStd	4.4	1.5	1.4	1.7	1.4	1.4	0.3	0.1	0.0	0.3	0.9	1.7	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.1	67.7	75.6	89.8	93.9	104.5	109.7	109.3	103.1	91.1	73.3	61.8
		MCWB	48.1	50.6	56.6	62.5	63.6	67.4	68.1	67.4	64.1	61.5	54.2	49.2
	2%	DB	53.5	61.4	70.7	81.7	89.8	101.7	106.9	106.9	100.2	87.5	69.3	56.5
		MCWB	45.3	49.1	53.6	59.2	62.8	65.4	66.9	66.5	63.8	60.2	53.1	48.6
	5%	DB	50.4	57.4	67.5	77.4	86.9	98.8	105.0	104.8	97.1	84.3	66.1	53.6
		MCWB	43.9	47.5	52.1	57.4	62.2	64.9	66.3	66.2	62.8	58.8	51.9	47.4
	10%	DB	48.3	53.9	64.0	73.7	83.7	96.1	102.9	103.0	94.5	80.3	62.6	51.1
		MCWB	43.1	46.0	51.0	56.7	61.5	63.9	66.0	66.0	62.4	58.0	51.1	45.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.0	52.8	58.3	64.4	67.4	69.8	71.5	71.3	68.3	65.6	58.3	52.5
		MCDB	54.6	62.6	72.6	86.1	85.6	98.8	100.5	100.8	95.1	80.0	66.4	57.2
	2%	WB	46.8	50.4	55.1	61.4	65.4	68.2	69.6	69.7	65.9	62.8	56.1	50.3
		MCDB	51.0	58.1	67.0	77.4	83.2	96.1	99.8	99.8	92.4	78.6	63.2	54.7
	5%	WB	45.4	48.7	53.4	59.5	63.9	66.7	68.4	68.5	64.5	61.3	54.2	48.6
		MCDB	48.9	55.9	64.5	73.0	81.3	93.9	99.1	98.6	92.0	76.7	61.6	52.2
	10%	WB	43.9	47.0	51.8	57.7	62.5	65.3	67.4	67.5	63.2	60.1	52.5	46.9
		MCDB	47.1	52.9	62.2	69.8	78.8	91.4	98.1	97.4	90.9	74.3	60.3	49.8
Mean Daily Temperature Range	5% DB	MDBR	16.1	20.2	22.3	25.5	28.8	34.9	36.9	37.6	34.5	27.5	23.9	16.0
		MCDBR	19.6	25.8	28.4	32.4	34.8	37.0	39.8	39.7	39.1	33.4	28.7	20.4
		MCWBR	12.2	14.4	13.8	14.5	13.0	11.4	12.0	10.5	13.1	12.7	14.6	12.5
	5% WB	MCDBR	14.8	21.2	24.6	28.3	29.9	34.6	37.1	37.3	33.3	25.9	21.7	15.3
		MCWBR	9.7	12.0	12.8	13.8	12.4	11.3	11.7	10.3	12.4	10.6	11.6	9.7
Clear-Sky Solar Irradiance	taub	0.354	0.386	0.421	0.479	0.446	0.394	0.394	0.393	0.367	0.414	0.358	0.351	
	taud	2.235	2.159	2.093	1.961	2.111	2.275	2.278	2.264	2.329	2.157	2.299	2.261	
	Ebn at Noon	255	261	264	255	266	280	279	278	279	248	252	246	
	Edh at Noon	33	40	47	57	50	43	42	42	37	40	30	30	
All-Sky Solar Radiation	RadAvg	670	941	1318	1661	2099	2537	2502	2234	1830	1238	869	612	
	RadStd	97	146	107	174	147	110	66	65	68	85	95	106	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	N/A	N/A	N/A	N/A	-1.85	N/A	N/A	N/A	N/A	+88

Nomenclature: See separate page