

BATMAN, Turkey

WMO: 172820

Lat: 37.933N

Lon: 41.117E

Elev: 540

StdP: 95.00

Time Zone: 3.00 (E03)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.2	-4.8	-11.2	1.5	-2.4	-8.9	1.9	-0.4	10.2	8.9	8.6	8.7	1.7	30	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.5	41.4	19.2	40.3	19.0	39.2	18.8	20.9	37.5	20.3	36.7	19.7	36.0	2.9	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	12.1	23.7	15.1	11.4	22.8	14.2	10.8	22.2	63.0	37.7	60.7	36.9	58.7	36.2	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.8	6.1	5.0	DB	-10.6	43.9	5.6	1.2	-14.6	44.8	-17.9	45.5	-21.0	46.1	-25.1	47.0	
			WB	-11.0	22.4	5.5	1.2	-15.0	23.2	-18.2	23.9	-21.3	24.6	-25.3	25.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	3.7	5.8	10.1	14.9	19.4	25.6	29.2	29.3	24.5	18.4	10.5	5.1
	DBStd	9.51	3.62	3.68	3.52	3.21	2.86	2.46	1.83	1.65	2.94	3.14	3.02	3.79
	HDD10.0	545	194	122	42	2	0	0	0	0	0	0	29	156
	HDD18.3	1879	453	350	257	112	22	0	0	0	1	39	236	410
	CDD10.0	2893	0	5	44	148	291	468	596	599	434	259	44	3
	CDD18.3	1186	0	0	1	8	55	218	338	341	186	40	0	0
	CDH23.3	18475	0	0	11	188	909	3417	5401	5277	2691	581	1	0
	CDH26.7	11665	0	0	2	51	354	2097	3723	3658	1583	196	0	0
Wind	WSAvg	2.0	2.0	2.0	2.4	2.2	2.1	2.2	2.1	2.1	2.0	1.7	1.4	1.7
Precipitation	PrecAvg	536	81	86	77	70	38	7	2	1	5	30	55	85
	PrecMax	785	166	176	224	177	182	32	6	7	29	99	176	183
	PrecMin	356	25	39	20	20	4	0	0	0	0	0	6	3
	PrecStd	112	37	35	44	36	36	7	2	1	7	24	42	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.0	19.8	24.2	32.1	34.4	40.3	43.2	42.9	39.5	32.9	23.0	16.5
		MCWB	9.0	10.3	13.7	16.9	17.5	19.7	20.0	19.7	17.8	16.4	12.4	9.5
	2%	DB	11.9	16.3	21.5	27.6	32.1	38.7	41.6	41.6	37.9	30.8	20.7	13.6
		MCWB	7.4	9.5	12.0	15.1	17.1	18.6	19.4	19.2	17.7	15.7	11.7	9.2
	5%	DB	10.2	14.1	19.7	25.2	30.5	37.1	40.6	40.4	36.1	29.1	19.0	12.0
		MCWB	6.6	8.6	11.2	14.1	16.8	18.3	19.1	19.0	17.1	14.9	11.1	8.5
	10%	DB	9.0	12.2	17.8	23.1	28.7	35.6	39.4	39.5	34.7	26.8	17.0	10.6
		MCWB	6.2	7.8	10.5	13.7	16.4	17.7	18.9	18.9	16.9	14.5	10.6	7.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	11.6	14.6	18.0	19.7	21.0	22.0	21.8	20.1	18.7	14.6	11.4
		MCDB	12.6	17.0	22.5	30.1	29.8	37.1	38.1	38.2	35.1	26.7	19.1	14.0
	2%	WB	8.2	10.2	12.8	16.3	18.5	20.1	20.9	21.0	18.8	17.1	13.4	10.2
		MCDB	10.6	14.5	19.5	25.2	28.4	35.6	37.7	37.6	33.6	25.9	17.4	12.6
	5%	WB	7.4	9.3	11.9	15.3	17.7	19.3	20.2	20.3	18.1	16.3	12.3	9.2
		MCDB	9.4	13.3	18.0	22.8	27.4	34.4	37.3	37.0	33.3	24.8	16.4	11.2
	10%	WB	6.6	8.3	11.0	14.3	16.9	18.5	19.7	19.7	17.3	15.6	11.4	8.3
		MCDB	8.4	11.6	16.8	21.0	26.0	33.0	36.7	36.3	32.7	23.5	15.7	9.9
Mean Daily Temperature Range	5% DB	MDBR	8.9	11.2	12.4	14.1	16.0	19.4	20.5	20.9	19.2	15.3	13.3	8.9
		MCDBR	10.9	14.3	15.8	18.0	19.3	20.6	22.1	22.1	21.7	18.6	15.9	11.3
		MCWBR	6.8	8.0	7.6	8.0	7.2	6.3	6.7	5.8	7.3	7.1	8.1	6.9
	5% WB	MCDBR	8.2	11.8	13.7	15.7	16.6	19.2	20.6	20.7	18.5	14.4	12.1	8.5
		MCWBR	5.4	6.7	7.1	7.7	6.9	6.3	6.5	5.7	6.9	5.9	6.4	5.4
Clear-Sky Solar Irradiance	taub	0.354	0.386	0.421	0.479	0.446	0.394	0.394	0.393	0.367	0.414	0.358	0.351	
	taud	2.235	2.159	2.093	1.961	2.111	2.275	2.278	2.264	2.329	2.157	2.299	2.261	
	Ebn at Noon	803	824	832	805	840	884	881	875	879	783	796	777	
	Edh at Noon	103	126	148	180	157	134	132	131	116	125	96	94	
All-Sky Solar Radiation	RadAvg	2.11	2.97	4.16	5.24	6.62	8.00	7.89	7.04	5.77	3.90	2.74	1.93	
	RadStd	0.31	0.46	0.34	0.55	0.46	0.35	0.21	0.21	0.21	0.27	0.30	0.33	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	-1.03	N/A	N/A	N/A	N/A	+49

Nomenclature: See separate page