

BODRUM, Turkey

WMO: 172900

Lat: 37.033N

Lon: 27.440E

Elev: 26

StdP: 101.01

Time Zone: 3.00 (E03)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.2	4.7	-6.7	2.2	6.9	-5.1	2.5	7.2	10.1	14.4	8.9	14.2	3.8	340	0.348

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	37.3	22.0	35.8	22.0	34.4	21.9	25.2	30.8	24.5	30.4	23.8	30.0	3.8	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.8	18.7	27.6	22.8	17.6	27.4	22.0	16.7	27.3	77.2	30.8	74.3	30.5	71.6	30.0	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
8.2	7.1	6.1	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	12.2	12.5	14.3	17.1	21.8	26.7	29.4	29.6	25.8	21.5	16.8	13.1
	DBStd	6.92	3.12	3.17	2.81	2.89	2.53	2.77	1.98	2.08	2.29	2.70	2.97	3.49
	HDD10.0	51	17	14	3	1	0	0	0	0	0	2	14	
	HDD18.3	772	192	164	128	54	2	0	0	0	7	60	164	
	CDD10.0	3740	84	83	136	214	367	502	601	608	474	356	205	110
	CDD18.3	1421	0	0	3	18	111	252	343	350	224	104	14	2
	CDH23.3	13761	0	0	6	59	571	2485	4163	4215	1814	433	14	0
	CDH26.7	6144	0	0	1	7	137	1083	2098	2109	637	73	0	0
Wind	WSAvg	2.5	2.7	2.8	2.7	2.4	2.2	2.6	2.6	2.4	2.3	2.1	2.2	2.6
Precipitation	PrecAvg	664	120	105	69	44	22	3	1	1	11	44	96	150
	PrecMax	1041	311	229	157	107	61	14	6	15	54	150	252	312
	PrecMin	355	5	25	2	4	1	0	0	0	3	17	2	
	PrecStd	176	67	64	43	26	17	3	1	3	15	37	57	81
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.4	20.7	23.6	27.7	32.5	38.8	39.3	39.6	35.3	30.7	25.0	21.3
		MCWB	14.4	14.6	15.1	16.8	19.7	21.5	22.6	21.5	20.9	19.9	18.2	16.0
	2%	DB	18.3	18.9	21.3	25.0	29.8	35.6	37.2	37.3	33.0	28.6	23.4	19.6
		MCWB	13.8	13.8	14.0	15.5	19.0	21.0	22.0	22.3	20.8	19.0	17.0	15.1
	5%	DB	17.4	17.9	19.8	23.3	28.1	33.8	35.7	35.8	31.7	27.1	22.2	18.8
		MCWB	13.5	13.5	13.4	15.3	18.8	20.9	22.1	22.4	20.7	18.9	16.6	14.6
	10%	DB	16.6	16.8	18.5	21.8	26.5	31.9	34.2	34.4	30.2	25.8	21.1	17.8
		MCWB	13.1	13.0	13.1	14.8	18.2	20.5	21.9	22.4	20.9	18.7	16.2	14.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.6	15.4	16.7	19.1	21.9	24.6	26.4	26.1	24.9	22.9	19.6	17.0
		MCDB	18.3	19.0	20.9	23.8	28.0	31.1	31.7	30.8	29.1	26.9	22.7	20.0
	2%	WB	14.8	14.6	15.6	17.6	20.9	23.4	25.2	25.2	23.8	21.4	18.4	16.3
		MCDB	17.2	17.8	19.3	22.2	26.7	29.9	30.9	30.8	28.5	25.2	21.8	19.0
	5%	WB	14.2	14.1	14.8	16.6	20.1	22.6	24.4	24.6	23.0	20.6	17.6	15.4
		MCDB	16.8	17.0	18.5	21.0	25.5	29.2	30.6	30.6	28.1	24.8	21.1	18.0
	10%	WB	13.5	13.5	14.0	15.8	19.4	21.9	23.7	24.0	22.3	19.8	16.8	14.4
		MCDB	16.2	16.4	17.6	20.1	24.6	28.6	30.2	30.3	27.4	24.2	20.3	17.2
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.1	6.9	7.4	8.1	9.1	9.6	9.4	8.4	7.7	6.8	6.0
		MCDBR	6.4	6.5	8.3	9.6	10.3	11.4	11.5	11.2	10.1	9.0	7.5	6.0
		MCWBR	4.2	3.6	4.3	4.6	4.1	3.8	3.7	3.6	4.0	3.9	4.0	3.5
	5% WB	MCDBR	5.3	5.6	7.0	7.9	8.8	9.7	9.3	9.5	8.5	7.2	6.5	4.7
		MCWBR	4.0	3.5	4.2	4.6	4.4	4.2	4.1	4.0	4.4	4.1	4.0	3.4
Clear-Sky Solar Irradiance	taub	0.354	0.384	0.419	0.451	0.436	0.400	0.397	0.408	0.393	0.393	0.372	0.358	
	taud	2.427	2.325	2.215	2.158	2.258	2.400	2.406	2.370	2.415	2.391	2.414	2.438	
	Ebn at Noon	825	840	842	834	851	880	880	864	859	820	796	794	
	Edh at Noon	88	109	133	148	136	118	117	119	108	101	88	82	
All-Sky Solar Radiation	RadAvg	2.29	3.12	4.59	5.95	7.12	8.02	8.06	7.20	5.84	4.19	2.84	2.10	
	RadStd	0.24	0.26	0.27	0.44	0.32	0.27	0.11	0.10	0.22	0.20	0.21	0.25	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-62	N/A	N/A	N/A

Nomenclature: See separate page