

MUGLA, Turkey

WMO: 172920

Lat: 37.2094N

Lon: 28.3669E

Elev: 2119

StdP: 13.60

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.4	29.0	12.9	11.4	32.9	17.1	14.1	34.6	12.9	45.7	11.2	44.6	4.0	290	0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.2	98.6	66.9	96.1	66.7	93.6	66.5	71.8	90.6	70.2	88.8	68.9	87.2	5.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.9	103.5	80.2	64.0	96.7	78.5	62.4	91.3	77.3	36.9	90.4	35.5	88.8	34.3	87.2	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.0	9.2	7.8	DB	23.0	102.8	2.8	2.2	21.0	104.4	19.3	105.7	17.7	107.0	15.7	108.6
			WB	21.0	74.2	2.9	2.5	18.8	76.0	17.1	77.5	15.5	78.9	13.3	80.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.8	42.7	44.4	49.1	55.9	65.5	75.3	81.8	81.7	72.9	62.6	52.2	44.8	(6)
	DBStd	15.03	5.40	5.35	5.44	6.02	5.94	5.94	4.39	4.27	5.54	5.79	5.78	5.43	(7)
	HDD50	711	232	164	81	16	0	0	0	0	0	1	42	175	(8)
	HDD65	3239	693	576	492	278	68	2	0	0	4	114	385	627	(9)
	CDD50	4664	4	8	54	193	481	759	987	982	686	391	107	12	(10)
	CDD65	1718	0	0	0	5	84	311	522	517	241	38	0	0	(11)
	CDH74	18524	0	0	2	101	883	3249	5982	5744	2212	345	6	0	(12)
	CDH80	8976	0	0	0	14	251	1489	3207	3028	924	63	0	0	(13)
(14) Wind	WSAvg	3.5	3.2	3.3	3.5	3.4	3.4	3.8	4.2	4.2	3.7	2.9	2.7	3.1	(14)
(15) Precipitation	PrecAvg	46.4	8.9	7.1	4.9	2.7	1.9	0.9	0.4	0.3	0.7	2.8	5.6	10.6	(15)
	PrecMax	71.1	25.4	14.6	10.9	9.0	6.6	3.7	3.5	3.5	4.6	9.1	14.2	24.8	(16)
	PrecMin	25.8	0.0	0.9	0.4	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.7	0.4	(17)
	PrecStd	11.8	5.3	4.0	2.7	1.7	1.7	1.0	0.6	0.6	1.0	2.1	2.9	5.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.4	64.0	71.1	81.9	89.0	99.6	103.0	101.0	96.3	86.0	74.2	62.4	(19)
		MCWB	48.7	51.0	53.3	59.2	63.0	65.5	67.3	67.7	64.7	62.2	57.8	50.3	(20)
	2%	DB	55.4	59.8	66.7	76.5	85.7	95.1	99.0	98.1	92.5	81.2	69.0	57.7	(21)
		MCWB	48.5	49.0	51.8	57.2	62.0	66.3	67.5	66.9	64.7	60.8	55.2	50.0	(22)
	5%	DB	53.0	56.2	63.4	72.4	83.0	91.6	96.3	95.7	89.1	77.8	65.4	55.1	(23)
		MCWB	47.8	47.8	50.9	55.9	61.8	65.6	67.0	66.8	64.5	59.5	54.7	49.8	(24)
	10%	DB	50.8	53.2	60.1	68.2	79.4	88.5	93.5	93.4	85.7	74.4	62.1	53.0	(25)
		MCWB	46.8	47.0	49.7	54.3	60.9	65.1	66.6	66.9	63.4	58.6	53.8	49.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.3	52.8	55.5	61.1	67.3	71.1	74.5	74.4	70.2	65.5	62.8	54.4	(27)
		MCDB	54.5	61.0	66.7	76.5	83.9	90.0	93.4	91.9	85.5	77.1	65.3	56.7	(28)
	2%	WB	50.2	50.6	53.5	58.9	64.8	69.5	71.9	71.9	67.9	63.5	58.3	52.5	(29)
		MCDB	53.2	56.3	62.8	73.6	80.5	88.2	90.9	90.7	84.6	74.0	64.2	55.0	(30)
	5%	WB	48.8	49.2	52.1	57.1	63.1	67.7	70.2	70.4	66.4	61.9	56.5	51.0	(31)
		MCDB	51.7	53.9	60.8	69.8	78.1	85.7	89.6	88.7	83.0	72.2	62.4	53.6	(32)
	10%	WB	47.5	48.0	50.6	55.3	61.6	66.1	68.7	69.0	65.1	60.3	54.9	49.6	(33)
		MCDB	50.2	52.1	58.4	65.9	75.7	84.2	88.0	86.8	80.9	70.3	60.0	52.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	15.3	18.0	19.7	22.4	22.9	23.2	22.9	23.1	21.3	18.5	14.3	(35)
		MCDBR	18.0	21.7	24.4	26.9	27.2	25.3	25.6	25.2	26.7	26.2	25.0	19.2	(36)
		MCWBR	11.5	12.7	12.6	11.9	10.3	8.4	8.2	7.7	9.0	10.4	13.1	11.8	(37)
	5% WB	MCDBR	13.5	17.0	21.0	24.5	24.2	23.7	23.8	22.9	23.6	21.9	18.4	13.0	(38)
		MCWBR	9.5	10.7	11.8	11.8	10.8	9.4	9.0	8.2	9.4	10.4	10.9	9.0	(39)
(40) Clear-Sky Solar Irradiance	taub		0.320	0.348	0.382	0.413	0.400	0.368	0.364	0.377	0.357	0.356	0.334	0.322	(40)
	taud		2.476	2.385	2.271	2.213	2.306	2.425	2.429	2.382	2.445	2.439	2.478	2.499	(41)
	Ebn at Noon		275	279	279	276	280	289	289	283	284	273	267	266	(42)
	Edh at Noon		26	32	40	44	41	36	36	37	33	30	26	24	(43)
(44) All-Sky Solar Radiation	RadAvg		718	974	1411	1810	2168	2476	2528	2239	1829	1312	900	663	(44)
	RadStd		83	103	96	148	119	114	55	56	93	68	72	85	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+1.12	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-112	N/A	N/A

Nomenclature: See separate page