

MUGLA, Turkey

WMO: 172920

Lat: 37.2094N

Lon: 28.3669E

Elev: 646

StdP: 93.80

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.1	-1.7	-10.6	1.6	0.5	-8.3	2.0	1.5	5.8	7.6	5.0	7.0	1.8	290	0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	37.0	19.4	35.6	19.3	34.2	19.2	22.1	32.6	21.2	31.6	20.5	30.7	2.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	14.8	26.8	17.8	13.8	25.8	16.9	13.0	25.2	67.9	32.4	64.8	31.5	62.0	30.7	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.5	4.1	3.5	DB	-5.0	39.3	1.6	1.2	-6.1	40.2	-7.1	41.0	-7.9	41.6	-9.1	42.5	(4)
			WB	-6.1	23.5	1.6	1.4	-7.3	24.5	-8.3	25.3	-9.2	26.0	-10.4	27.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	5.9	6.9	9.5	13.3	18.6	24.0	27.7	27.6	22.7	17.0	11.2	7.1	(6)
		DBStd	8.35	3.00	2.97	3.02	3.34	3.30	3.30	2.44	2.37	3.08	3.22	3.21	3.02	(7)
		HDD10.0	395	129	91	45	9	0	0	0	0	1	23	97		(8)
		HDD18.3	1799	385	320	273	154	38	1	0	2	63	214	348		(9)
		CDD10.0	2591	2	4	30	107	267	422	548	546	381	217	59	7	(10)
		CDD18.3	954	0	0	0	3	47	173	290	287	134	21	0	0	(11)
		CDH23.3	10291	0	0	1	56	491	1805	3323	3191	1229	192	3	0	(12)
		CDH26.7	4987	0	0	0	8	139	827	1782	1682	513	35	0	0	(13)
(14)	Wind	WSAvg	1.5	1.4	1.5	1.6	1.5	1.5	1.7	1.9	1.9	1.7	1.3	1.2	1.4	(14)
(15)	Precipitation	PrecAvg	1179	227	180	125	68	49	23	9	8	18	70	142	270	(15)
(16)		PrecMax	1805	645	372	277	228	168	95	89	89	116	231	361	629	(16)
(17)		PrecMin	655	1	23	11	3	2	0	0	0	0	19	11		(17)
(18)		PrecStd	300	135	102	69	43	43	26	15	15	26	53	73	147	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	14.7	17.8	21.7	27.7	31.7	37.6	39.4	38.3	35.7	30.0	23.4	16.9		(19)
(20)		MCWB	9.3	10.6	11.9	15.1	17.2	18.6	19.6	19.8	18.2	16.8	14.3	10.2		(20)
(21)		DB	13.0	15.4	19.3	24.7	29.8	35.1	37.2	36.7	33.6	27.3	20.6	14.3		(21)
(22)		MCWB	9.2	9.4	11.0	14.0	16.7	19.1	19.7	19.4	18.2	16.0	12.9	10.0		(22)
(23)		DB	11.7	13.5	17.5	22.4	28.3	33.1	35.7	35.4	31.7	25.4	18.6	12.8		(23)
(24)		MCWB	8.8	8.8	10.5	13.3	16.5	18.7	19.5	19.3	18.0	15.3	12.6	9.9		(24)
(25)		DB	10.5	11.8	15.6	20.1	26.3	31.4	34.2	34.1	29.8	23.6	16.7	11.7		(25)
(26)		MCWB	8.2	8.3	9.8	12.4	16.0	18.4	19.2	19.4	17.5	14.8	12.1	9.5		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	11.3	11.6	13.1	16.2	19.6	21.7	23.6	23.6	21.2	18.6	17.1	12.5		(27)
(28)		MCDB	12.5	16.1	19.3	24.7	28.8	32.2	34.1	33.3	29.7	25.0	18.5	13.7		(28)
(29)		WB	10.1	10.3	11.9	15.0	18.2	20.8	22.2	22.2	20.0	17.5	14.6	11.4		(29)
(30)		MCDB	11.8	13.5	17.1	23.1	27.0	31.2	32.7	32.6	29.2	23.3	17.9	12.8		(30)
(31)		WB	9.3	9.6	11.2	13.9	17.3	19.8	21.2	21.3	19.1	16.6	13.6	10.5		(31)
(32)		MCDB	10.9	12.2	16.0	21.0	25.6	29.9	32.0	31.5	28.3	22.3	16.9	12.0		(32)
(33)		WB	8.6	8.9	10.4	12.9	16.4	19.0	20.4	20.5	18.4	15.7	12.7	9.8		(33)
(34)		MCDB	10.1	11.2	14.6	18.8	24.3	29.0	31.1	30.5	27.1	21.3	15.5	11.3		(34)
(35)	Mean Daily Temperature Range	MDBR	7.7	8.5	10.0	10.9	12.5	12.7	12.9	12.7	12.8	11.8	10.3	7.9		(35)
(36)		5% DB	10.0	12.0	13.6	15.0	15.1	14.0	14.2	14.0	14.8	14.6	13.9	10.7		(36)
(37)		MCWBR	6.4	7.1	7.0	6.6	5.7	4.7	4.5	4.3	5.0	5.8	7.3	6.6		(37)
(38)		5% WB	7.5	9.4	11.7	13.6	13.5	13.1	13.2	12.7	13.1	12.2	10.2	7.2		(38)
(39)	Clear-Sky Solar Irradiance	MCWBR	5.3	5.9	6.5	6.5	6.0	5.2	5.0	4.6	5.2	5.8	6.1	5.0		(39)
(40)		taub	0.320	0.348	0.382	0.413	0.400	0.368	0.364	0.377	0.357	0.356	0.334	0.322		(40)
(41)		taud	2.476	2.385	2.271	2.213	2.306	2.425	2.429	2.382	2.445	2.439	2.478	2.499		(41)
(42)		Ebn at Noon	868	881	878	869	884	910	910	892	895	860	843	840		(42)
(43)	All-Sky Solar Radiation	Edh at Noon	82	102	125	140	130	115	114	117	104	95	82	76		(43)
(44)		RadAvg	2.26	3.07	4.45	5.71	6.83	7.80	7.97	7.06	5.77	4.13	2.84	2.09		(44)
(45)		RadStd	0.26	0.32	0.30	0.47	0.37	0.36	0.17	0.18	0.29	0.21	0.23	0.27		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	+0.62	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-62	N/A	N/A	(47)

Nomenclature: See separate page