

ANTALYA HAVALIMANI, Turkey

WMO: 173000

Lat: 36.899N

Lon: 30.800E

Elev: 177

StdP: 14.60

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.3	38.9	10.1	9.3	43.4	15.4	12.1	45.6	31.6	52.2	27.6	50.4	10.8	330	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.2	101.5	68.2	98.5	68.2	95.1	68.5	79.7	87.3	78.7	86.4	77.6	85.6	9.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.3	143.1	85.1	76.3	138.3	84.7	75.1	132.6	84.1	43.5	87.6	42.3	86.8	41.3	86.0	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.3	20.0	16.9	DB	31.5	107.0	3.2	2.5	29.2	108.8	27.3	110.3	25.5	111.8	23.1	113.6	(4)
			WB	26.5	81.4	2.5	1.5	24.7	82.5	23.2	83.3	21.7	84.1	19.9	85.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.0	51.0	52.5	56.2	62.0	70.1	78.7	84.5	84.7	78.4	70.5	60.9	53.7	(6)
(7)		DBStd	12.90	4.32	4.63	4.33	4.74	5.05	5.72	4.69	4.14	3.98	4.86	4.97	4.52	(7)
(8)		HDD50	93	40	25	6	1	0	0	0	0	0	0	2	19	(8)
(9)		HDD65	1679	435	349	275	114	10	0	0	0	0	10	136	350	(9)
(10)		CDD50	6308	70	97	198	360	624	862	1068	1076	853	636	330	134	(10)
(11)		CDD65	2419	0	0	1	23	169	412	603	611	403	182	15	0	(11)
(12)		CDH74	26617	0	1	10	180	1203	4370	7787	7833	3927	1216	89	1	(12)
(13)		CDH80	12418	0	0	0	36	352	1957	4083	4061	1615	307	7	0	(13)
(14)	Wind	WSAvg	7.1	8.4	8.3	7.9	6.9	6.3	7.0	6.8	6.3	6.7	6.6	7.6	(14)	
(15)	Precipitation	PrecAvg	42.6	8.9	6.1	4.2	2.1	1.3	0.3	0.0	0.1	0.6	2.7	5.6	10.1	(15)
(16)		PrecMax	75.4	31.4	24.6	15.7	6.6	4.7	1.9	0.7	1.1	3.1	19.5	35.7	25.7	(16)
(17)		PrecMin	21.8	0.0	0.2	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	(17)
(18)		PrecStd	13.0	6.3	4.4	3.0	1.7	1.2	0.4	0.2	0.2	0.9	3.3	6.3	6.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	66.0	69.6	75.3	84.6	92.2	103.4	105.5	105.1	99.0	91.3	80.6	69.9	(19)	
(20)		MCWB	54.3	54.1	56.8	61.8	64.7	68.5	69.5	68.9	66.6	63.6	60.5	55.8	(20)	
(21)		DB	63.2	66.2	71.0	78.7	87.8	98.3	101.7	100.8	93.5	86.2	76.6	66.6	(21)	
(22)		MCWB	53.8	53.6	55.3	59.8	64.8	67.3	68.4	68.2	66.7	63.8	59.7	55.7	(22)	
(23)		DB	61.2	63.7	67.8	75.1	83.9	93.8	98.5	98.0	90.3	83.0	73.4	64.6	(23)	
(24)		MCWB	52.9	53.5	55.2	59.4	64.7	67.4	68.6	68.4	68.6	64.0	59.4	54.9	(24)	
(25)		DB	59.3	61.2	65.2	71.7	80.4	89.8	95.0	94.4	87.8	80.6	70.6	62.5	(25)	
(26)		MCWB	51.4	53.0	54.7	59.1	65.2	67.9	68.7	70.1	70.1	64.9	58.5	54.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	59.0	59.1	61.0	65.8	72.7	77.7	81.0	81.3	78.3	72.7	66.2	60.8	(27)	
(28)		MCDWB	63.0	65.0	67.1	74.5	79.7	85.4	88.3	88.7	86.3	80.3	72.3	65.6	(28)	
(29)		WB	56.4	57.0	59.2	63.7	70.3	75.8	79.6	80.0	76.5	70.4	63.9	58.9	(29)	
(30)		MCDWB	61.0	62.3	65.3	72.4	78.4	83.7	87.2	87.6	84.8	78.3	70.9	63.7	(30)	
(31)		WB	54.7	55.5	57.9	62.3	68.8	74.4	78.6	79.1	75.1	68.9	62.1	57.0	(31)	
(32)		MCDWB	59.6	60.8	64.3	70.6	77.3	82.8	86.1	86.8	83.7	77.2	69.0	62.2	(32)	
(33)		WB	53.1	54.1	56.6	60.9	67.4	72.9	77.4	78.2	73.9	67.2	60.4	55.4	(33)	
(34)		MCDWB	57.8	59.9	63.3	69.0	76.3	81.9	85.2	86.2	82.7	75.9	67.3	60.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	15.3	15.9	17.0	17.5	17.9	19.0	18.6	18.2	18.9	18.7	18.2	15.7	(35)	
(36)		5% DB	18.2	18.8	20.4	22.8	23.4	24.4	24.0	23.8	22.4	21.9	21.8	19.0	(36)	
(37)		MCWBR	11.6	11.4	11.7	11.5	11.0	11.2	12.2	13.6	13.6	12.1	12.1	11.7	(37)	
(38)		5% WB	14.8	15.4	16.9	18.4	18.4	18.2	16.9	16.9	18.5	18.0	17.4	15.3	(38)	
(39)		MCWBR	10.5	10.5	11.1	11.0	10.8	11.2	11.0	10.8	12.5	12.0	10.9	10.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.344	0.370	0.407	0.446	0.434	0.402	0.408	0.420	0.395	0.384	0.356	0.346	(40)	
(41)		taud	2.435	2.349	2.237	2.157	2.257	2.377	2.364	2.318	2.391	2.402	2.441	2.457	(41)	
(42)		Ebn at Noon	266	272	271	266	271	279	276	270	272	264	259	257	(42)	
(43)		Edh at Noon	28	34	41	47	43	38	39	40	35	32	27	25	(43)	
(44)	All-Sky Solar Radiation	RadAvg	725	999	1442	1821	2124	2442	2467	2194	1812	1305	917	677	(44)	
(45)		RadStd	94	98	96	130	115	109	59	47	88	78	74	88	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) -131	(l) N/A	(46)
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page