

ANTALYA HAVALIMANI, Turkey

WMO: 173000

Lat: **36.899N**Lon: **30.800E**Elev: **54**StdP: **100.68**Time Zone: **3.00 (E03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.4	3.8	-12.2	1.3	6.3	-9.2	1.7	7.6	14.1	11.2	12.3	10.2	4.8	330	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.1	38.6	20.1	36.9	20.1	35.1	20.3	26.5	30.7	26.0	30.2	25.4	29.8	4.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	20.4	29.5	24.6	19.8	29.3	23.9	18.9	28.9	83.3	30.9	80.6	30.5	78.1	30.0	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
10.4	8.9	7.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-0.3	41.7	1.8	1.4	-1.6	42.7	-2.6	43.5	-3.6	44.3	-4.9	45.3
			-3.1	27.4	1.4	0.8	-4.1	28.0	-4.9	28.5	-5.7	29.0	-6.7	29.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.5	10.5	11.4	13.4	16.7	21.2	26.0	29.1	29.3	25.8	21.4	16.1	12.1
	DBStd	7.17	2.40	2.57	2.41	2.64	2.81	3.18	2.60	2.30	2.21	2.70	2.76	2.51
	HDD10.0	52	22	14	3	1	0	0	0	0	0	0	1	11
	HDD18.3	933	242	194	153	63	6	0	0	0	0	6	76	194
	CDD10.0	3504	39	54	110	200	347	479	593	598	474	353	183	74
	CDD18.3	1344	0	0	1	13	94	229	335	339	224	101	8	0
	CDH23.3	14787	0	1	6	100	668	2428	4326	4352	2182	676	49	1
	CDH26.7	6899	0	0	0	20	196	1087	2268	2256	897	171	4	0
Wind	WSAvg	3.2	3.7	3.7	3.6	3.1	2.8	3.1	3.0	2.8	3.0	3.0	3.0	3.4
Precipitation	PrecAvg	1083	225	155	107	53	33	8	1	2	16	69	143	257
	PrecMax	1914	798	625	399	167	120	48	19	29	79	495	907	652
	PrecMin	553	0	4	9	0	0	0	0	0	0	0	1	15
	PrecStd	331	159	111	77	42	30	10	4	5	22	84	161	171
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.9	20.9	24.0	29.2	33.4	39.6	40.8	40.6	37.2	32.9	27.0	21.0
		MCWB	12.4	12.3	13.8	16.6	18.2	20.3	20.8	20.5	19.2	17.5	15.9	13.2
	2%	DB	17.4	19.0	21.7	25.9	31.0	36.8	38.7	38.2	34.2	30.1	24.8	19.2
		MCWB	12.1	12.0	12.9	15.4	18.2	19.6	20.2	20.1	19.3	17.7	15.4	13.2
	5%	DB	16.2	17.6	19.9	23.9	28.8	34.3	37.0	36.7	32.4	28.3	23.0	18.1
		MCWB	11.6	11.9	12.9	15.2	18.2	19.7	20.4	20.2	20.4	17.8	15.2	12.7
	10%	DB	15.2	16.2	18.4	22.1	26.9	32.1	35.0	34.7	31.0	27.0	21.4	16.9
		MCWB	10.8	11.7	12.6	15.1	18.5	20.0	20.4	21.2	21.1	18.3	14.7	12.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.0	15.1	16.1	18.8	22.6	25.4	27.2	27.4	25.7	22.6	19.0	16.0
		MCDB	17.2	18.4	19.5	23.6	26.5	29.7	31.3	31.5	30.2	26.8	22.4	18.7
	2%	WB	13.5	13.9	15.1	17.6	21.3	24.3	26.5	26.7	24.7	21.3	17.7	14.9
		MCDB	16.1	16.9	18.5	22.5	25.8	28.7	30.7	30.9	29.3	25.7	21.6	17.6
	5%	WB	12.6	13.1	14.4	16.8	20.5	23.6	25.9	26.2	24.0	20.5	16.7	13.9
		MCDB	15.3	16.0	18.0	21.5	25.2	28.2	30.1	30.4	28.7	25.1	20.6	16.8
	10%	WB	11.7	12.3	13.7	16.1	19.6	22.7	25.2	25.7	23.3	19.6	15.8	13.0
		MCDB	14.3	15.5	17.4	20.6	24.6	27.7	29.5	30.1	28.1	24.4	19.6	15.8
Mean Daily Temperature Range	5% DB	MDBR	8.5	8.9	9.4	9.7	9.9	10.5	10.4	10.1	10.5	10.4	10.1	8.7
		MCDBR	10.1	10.4	11.3	12.6	13.0	13.6	13.3	13.2	12.5	12.2	12.1	10.6
		MCWBR	6.4	6.3	6.5	6.4	6.1	6.2	6.8	7.6	7.5	6.7	6.7	6.5
	5% WB	MCDBR	8.2	8.6	9.4	10.2	10.2	10.1	9.4	9.4	10.3	10.0	9.7	8.5
		MCWBR	5.8	5.9	6.1	6.1	6.0	6.2	6.1	6.0	6.9	6.7	6.0	5.8
Clear-Sky Solar Irradiance	taub	0.344	0.370	0.407	0.446	0.434	0.402	0.408	0.420	0.395	0.384	0.356	0.346	
	taud	2.435	2.349	2.237	2.157	2.257	2.377	2.364	2.318	2.391	2.402	2.441	2.457	
	Ebn at Noon	838	856	854	839	853	878	870	852	857	831	817	811	
	Edh at Noon	87	106	130	149	137	121	122	125	110	100	86	80	
All-Sky Solar Radiation	RadAvg	2.28	3.15	4.54	5.74	6.70	7.70	7.78	6.92	5.71	4.11	2.89	2.13	
	RadStd	0.30	0.31	0.30	0.41	0.36	0.34	0.19	0.15	0.28	0.24	0.23	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-73	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page