

ANTALYA BOLGE, Turkey

WMO: 173020

Lat: 36.8850N

Lon: 30.6829E

Elev: 154

StdP: 14.61

Time Zone: 3.00 (E03)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.4	43.0	7.4	8.1	42.0	12.2	10.3	47.5	34.1	59.3	28.1	59.5	7.4	350	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.9	99.5	67.2	95.6	68.9	92.4	70.4	80.4	86.6	79.5	86.0	78.4	85.3	4.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.6	149.4	85.6	77.5	144.0	85.0	76.3	138.1	84.3	44.3	86.7	43.3	86.0	42.2	85.4	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.1	10.0	8.8	DB	37.1	107.4	4.3	2.5	34.0	109.2	31.6	110.7	29.2	112.0	26.1	113.8
			WB	28.9	82.0	3.6	1.1	26.3	82.8	24.2	83.4	22.2	84.1	19.6	84.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	69.0	53.3	55.8	58.8	64.3	70.6	78.5	84.9	85.8	80.0	72.8	65.1	56.7	(6)
(7)		DBStd	11.99	4.53	4.45	3.73	4.52	4.63	6.15	5.15	4.13	3.97	4.54	3.72	4.47	(7)
(8)		HDD50	41	25	7	2	0	0	0	0	0	0	0	0	7	(8)
(9)		HDD65	1185	362	259	196	63	5	0	0	0	0	1	42	257	(9)
(10)		CDD50	6961	128	170	274	430	639	855	1081	1111	899	706	453	215	(10)
(11)		CDD65	2628	0	1	2	44	178	405	616	646	449	242	45	0	(11)
(12)		CDH74	26092	0	3	3	142	668	3554	7606	8414	4405	1218	79	0	(12)
(13)		CDH80	10728	0	0	0	37	122	1313	3516	4091	1428	215	6	0	(13)
(14)	Wind	WSAvg	3.8	4.6	4.1	4.1	3.7	3.7	3.7	3.5	3.6	3.5	3.4	3.7	(14)	
(15)	Precipitation	PrecAvg	42.6	8.9	6.1	4.2	2.1	1.3	0.3	0.0	0.6	2.7	5.6	10.1	(15)	
(16)		PrecMax	75.4	31.4	24.6	15.7	6.6	4.7	1.9	0.7	1.1	3.1	19.5	35.7	25.7	(16)
(17)		PrecMin	21.8	0.0	0.2	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	(17)
(18)		PrecStd	13.0	6.3	4.4	3.0	1.7	1.2	0.4	0.2	0.2	0.9	3.3	6.3	6.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	67.1	71.4	73.4	84.7	88.7	102.8	104.3	102.6	96.2	90.2	79.2	70.4	(19)	
(20)		MCWB	52.9	54.3	54.0	59.5	64.3	68.9	66.5	67.0	66.0	64.0	59.7	56.7	(20)	
(21)		DB	63.9	67.0	69.5	77.2	82.9	96.7	100.0	98.4	91.5	85.1	76.3	67.8	(21)	
(22)		MCWB	53.1	56.7	54.4	60.4	66.3	68.0	67.3	67.2	67.6	63.1	60.2	56.7	(22)	
(23)		DB	62.0	64.5	67.2	73.8	79.8	90.9	95.4	94.8	88.2	81.7	74.2	65.7	(23)	
(24)		MCWB	52.9	55.3	55.2	59.9	65.4	68.2	69.4	70.2	70.8	65.0	60.3	55.3	(24)	
(25)		DB	60.3	62.6	65.1	70.9	77.2	86.9	91.5	92.1	86.2	79.6	72.1	63.8	(25)	
(26)		MCWB	52.2	54.1	55.3	60.2	65.2	69.1	71.2	71.9	72.1	65.2	59.8	54.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	59.9	62.1	61.1	68.5	72.5	79.2	81.1	82.1	79.7	72.1	66.2	61.4	(27)	
(28)		MCDWB	62.2	65.1	64.9	71.9	78.0	84.2	87.1	87.8	86.2	79.6	72.8	66.6	(28)	
(29)		WB	56.4	59.9	59.6	65.8	70.8	76.8	80.1	80.8	78.3	70.7	64.2	59.5	(29)	
(30)		MCDWB	60.2	63.4	64.6	70.0	76.9	82.9	86.4	86.9	85.3	78.4	72.3	64.6	(30)	
(31)		WB	55.1	57.9	58.5	64.0	69.5	75.2	79.0	79.9	76.9	69.3	62.7	58.0	(31)	
(32)		MCDWB	59.3	62.0	63.9	69.6	75.5	81.7	85.5	86.4	84.3	77.4	70.9	63.3	(32)	
(33)		WB	53.7	56.2	57.4	62.4	68.1	73.8	78.0	79.1	75.3	68.0	61.4	56.4	(33)	
(34)		MCDWB	58.3	60.7	62.9	69.1	74.7	81.0	84.7	85.8	83.4	77.0	69.6	61.7	(34)	
(35)	Mean Daily Temperature Range	MDBR	11.8	12.1	12.1	11.4	10.8	12.1	12.4	11.9	12.0	13.0	12.6	12.2	(35)	
(36)		5% DB	13.7	14.0	15.0	15.5	14.7	20.0	19.5	17.1	14.8	14.8	14.2	14.0	(36)	
(37)		MCWBR	9.3	9.4	10.4	11.5	11.5	10.9	13.1	14.2	13.4	11.6	10.7	10.2	(37)	
(38)		5% WB	11.5	12.1	11.5	11.7	10.7	12.1	11.5	10.0	11.4	11.8	12.3	11.4	(38)	
(39)		MCWBR	8.7	9.0	9.8	10.9	10.8	10.7	10.8	10.5	11.8	10.8	10.2	9.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.350	0.379	0.419	0.459	0.446	0.412	0.418	0.432	0.405	0.393	0.363	0.352	(40)	
(41)		taud	2.411	2.314	2.192	2.110	2.212	2.347	2.333	2.282	2.359	2.367	2.413	2.432	(41)	
(42)		Ebn at Noon	263	268	267	262	267	276	273	267	269	260	256	254	(42)	
(43)		Edh at Noon	28	35	43	49	45	40	40	41	36	33	28	26	(43)	
(44)	All-Sky Solar Radiation	RadAvg	727	1000	1440	1819	2119	2437	2465	2191	1811	1305	919	679	(44)	
(45)		RadStd	94	97	95	128	113	111	59	48	89	76	73	86	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-130	N/A	N/A

Nomenclature: See separate page