

ALANYA, Turkey

WMO: 173100

Lat: 36.5500N

Lon: 31.9799E

Elev: 20

StdP: 14.69

Time Zone: 3.00 (E03)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	42.6	45.4	7.6	8.1	47.5	15.2	11.9	49.5	16.8	57.3	13.9	58.6	4.8	60	0.296

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.3	94.2	77.5	92.5	78.4	91.1	78.4	82.3	91.0	81.3	89.9	80.3	89.0	4.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.9	155.2	89.4	78.7	148.9	88.8	77.6	143.6	88.0	46.3	90.9	45.1	90.3	44.0	89.0	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.9	8.6	7.4	DB	39.7	98.8	3.4	4.2	37.3	101.8	35.3	104.3	33.4	106.6	31.0	109.7
			WB	31.3	83.9	3.3	1.6	28.9	85.0	27.0	85.9	25.2	86.8	22.8	87.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.1	55.6	56.8	60.5	65.3	72.4	79.4	85.1	85.8	81.6	74.3	65.5	58.5
	DBStd	11.30	4.09	4.24	3.69	3.59	3.70	3.79	2.17	1.72	2.96	4.01	4.30	4.47
	HDD50	20	10	5	1	0	0	0	0	0	0	0	0	4
	HDD65	952	292	231	145	37	0	0	0	0	0	2	41	204
	CDD50	7367	183	195	325	458	694	882	1087	1110	949	753	465	266
	CDD65	2824	0	0	4	46	229	432	622	645	499	289	57	1
	CDH74	28948	0	0	4	96	1024	4145	8119	8570	5290	1594	106	0
	CDH80	11718	0	0	0	9	160	1335	3809	4156	1963	284	2	0
(14) Wind	WSAvg	3.1	3.1	3.2	3.3	3.1	3.0	3.0	3.2	3.0	3.0	2.9	2.9	3.1
(15) Precipitation	PrecAvg	40.3	7.3	5.4	3.5	2.4	1.3	0.4	0.2	0.2	1.1	3.9	5.8	9.2
	PrecMax	62.2	18.5	12.2	7.7	9.9	4.1	2.0	1.4	1.9	4.6	11.4	17.8	22.4
	PrecMin	21.7	1.9	1.5	0.3	0.4	0.0	0.0	0.0	0.0	0.0	0.2	0.8	0.4
	PrecStd	10.0	3.7	2.2	2.0	2.1	1.1	0.5	0.3	0.4	1.3	3.0	3.6	6.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.5	70.0	73.5	80.2	87.1	95.2	97.2	96.7	93.3	87.0	79.7	71.3
		MCWB	58.3	58.8	59.4	65.4	71.6	73.7	74.8	76.9	77.7	71.4	65.8	59.8
	2%	DB	65.2	67.1	70.5	76.5	84.0	90.8	94.1	94.3	91.2	84.7	77.1	68.8
		MCWB	56.2	56.8	59.2	64.4	71.7	74.5	77.7	78.0	77.6	71.0	63.9	58.3
	5%	DB	63.6	65.4	68.8	73.9	81.4	88.3	92.4	92.5	89.7	83.0	74.7	66.9
		MCWB	55.1	55.7	59.0	63.5	70.7	75.1	78.0	79.5	76.3	70.2	62.7	57.4
	10%	DB	62.0	63.8	67.1	71.9	79.1	86.2	90.9	91.2	88.2	81.5	72.3	64.9
		MCWB	54.1	54.8	58.0	62.3	69.6	75.0	78.1	79.6	75.2	69.1	61.0	56.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.2	61.2	64.0	70.0	79.4	80.6	83.5	83.7	81.8	75.2	68.3	62.5
		MCDB	64.8	66.9	69.3	76.0	80.2	88.8	91.5	91.9	91.1	84.2	77.1	67.3
	2%	WB	59.0	58.8	61.9	66.8	74.2	78.8	82.1	82.6	79.9	73.2	66.2	60.9
		MCDB	63.3	65.5	68.1	73.7	81.0	86.7	90.7	91.3	89.2	82.9	75.4	66.9
	5%	WB	57.0	57.3	60.4	65.2	71.9	77.4	81.1	81.6	78.5	72.0	64.4	59.3
		MCDB	61.6	63.7	66.9	72.1	79.6	85.7	89.7	90.4	88.0	81.9	72.6	65.0
	10%	WB	55.5	55.8	59.2	63.7	70.2	76.1	80.1	80.7	77.1	70.6	62.6	57.8
		MCDB	60.4	62.1	65.7	70.5	78.0	84.6	88.8	89.4	86.7	80.4	70.4	63.5
(35) Mean Daily Temperature Range	5% DB	MDBR	10.6	11.3	11.8	11.6	11.4	11.6	11.7	11.3	12.0	12.3	11.5	10.6
		MCDBR	12.0	12.6	13.1	13.5	13.5	13.6	13.7	13.0	12.8	13.0	13.0	12.1
		MCWBR	9.0	9.4	10.2	10.5	11.2	11.8	12.7	11.8	12.0	11.8	9.8	8.9
	5% WB	MCDBR	10.3	11.5	11.9	12.4	12.8	12.1	11.7	11.8	12.1	12.1	11.9	10.9
		MCWBR	8.7	8.9	9.9	10.2	11.2	11.0	11.3	10.5	11.9	11.4	9.9	8.5
(40) Clear-Sky Solar Irradiance	taub		0.352	0.378	0.418	0.461	0.447	0.410	0.420	0.432	0.401	0.396	0.365	0.351
	taud		2.408	2.318	2.203	2.110	2.217	2.366	2.346	2.302	2.390	2.374	2.414	2.437
	Ebn at Noon		264	269	268	262	267	276	273	267	271	260	256	256
	Edh at Noon		29	35	43	49	45	39	39	40	35	33	28	26
(44) All-Sky Solar Radiation	RadAvg		714	993	1449	1834	2178	2492	2496	2227	1830	1308	915	670
	RadStd		97	102	96	128	104	87	57	47	84	79	78	93

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	+0.65	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page