

ALANYA, Turkey

WMO: 173100

Lat: 36.5500N

Lon: 31.9799E

Elev: 6

StdP: 101.25

Time Zone: 3.00 (E03)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.9	7.5	-13.5	1.2	8.6	-9.3	1.7	9.7	7.5	14.1	6.2	14.8	2.1	60	0.296

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.3	34.6	25.3	33.6	25.8	32.8	25.8	28.0	32.8	27.4	32.2	26.8	31.7	2.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.2	31.9	25.9	21.3	31.6	25.3	20.5	31.1	89.8	32.7	87.0	32.4	84.6	31.7	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.9	3.9	3.3	DB	4.3	37.1	1.9	2.3	2.9	38.8	1.8	40.2	0.8	41.5	-0.6	43.1	(4)
			WB	-0.4	28.8	1.8	0.9	-1.7	29.4	-2.8	29.9	-3.8	30.4	-5.1	31.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.2	13.1	13.8	15.8	18.5	22.4	26.3	29.5	29.9	27.6	23.5	18.6	14.7	(6)
		DBStd	6.28	2.27	2.35	2.05	2.00	2.05	2.11	1.21	0.96	1.64	2.23	2.39	2.48	(7)
		HDD10.0	11	6	3	1	0	0	0	0	0	0	0	0	2	(8)
		HDD18.3	529	162	128	81	21	0	0	0	0	0	1	23	113	(9)
		CDD10.0	4093	102	108	181	254	386	490	604	617	527	418	258	148	(10)
		CDD18.3	1569	0	0	2	26	127	240	346	358	277	161	32	1	(11)
		CDH23.3	16082	0	0	2	53	569	2303	4511	4761	2939	886	59	0	(12)
(13)	Wind	CDH26.7	6510	0	0	0	5	89	742	2116	2309	1091	158	1	0	(13)
		WSAvg	1.4	1.4	1.5	1.5	1.4	1.3	1.4	1.4	1.4	1.4	1.3	1.3	1.4	(14)
		PrecAvg	1024	185	136	89	61	32	10	4	4	28	100	148	233	(15)
		PrecMax	1580	469	310	196	251	103	51	36	48	116	290	452	570	(16)
		PrecMin	551	48	39	8	9	0	0	0	0	6	21	11	11	(17)
		PrecStd	255	94	55	50	53	27	12	8	9	33	77	91	158	(18)
		DB	19.7	21.1	23.1	26.8	30.6	35.1	36.2	36.0	34.1	30.5	26.5	21.8		(19)
(20)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	MCWB	14.6	14.9	15.2	18.6	22.0	23.2	23.8	24.9	25.4	21.9	18.8	15.4		(20)
		DB	18.4	19.5	21.4	24.7	28.9	32.7	34.5	34.6	32.9	29.3	25.0	20.4		(21)
		MCWB	13.5	13.8	15.1	18.0	22.0	23.6	25.4	25.5	25.3	21.7	17.7	14.6		(22)
		DB	17.6	18.6	20.4	23.3	27.4	31.3	33.6	33.6	32.1	28.3	23.7	19.4		(23)
		MCWB	12.8	13.2	15.0	17.5	21.5	23.9	25.6	26.4	24.6	21.2	17.1	14.1		(24)
		DB	16.7	17.7	19.5	22.1	26.2	30.1	32.7	32.9	31.2	27.5	22.4	18.3		(25)
		MCWB	12.3	12.7	14.5	16.9	20.9	23.9	25.6	26.4	24.0	20.6	16.1	13.6		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	16.2	16.2	17.8	21.1	26.3	27.0	28.6	28.7	27.7	24.0	20.2	16.9		(27)
		MCDB	18.2	19.4	20.7	24.5	26.8	31.5	33.1	33.3	32.8	29.0	25.1	19.6		(28)
		WB	15.0	14.9	16.6	19.3	23.4	26.0	27.9	28.1	26.6	22.9	19.0	16.1		(29)
		MCDB	17.4	18.6	20.1	23.2	27.2	30.4	32.6	32.9	31.8	28.3	24.1	19.4		(30)
		WB	13.9	14.0	15.8	18.4	22.2	25.2	27.3	27.6	25.8	22.2	18.0	15.2		(31)
		MCDB	16.4	17.6	19.4	22.3	26.5	29.8	32.0	32.4	31.1	27.7	22.5	18.3		(32)
		WB	13.1	13.2	15.1	17.6	21.2	24.5	26.7	27.1	25.0	21.4	17.0	14.4		(33)
(34)	Mean Daily Temperature Range	MCDB	15.8	16.7	18.7	21.4	25.5	29.2	31.6	31.9	30.4	26.9	21.3	17.5		(34)
		MDBR	5.9	6.3	6.6	6.5	6.3	6.4	6.5	6.3	6.6	6.8	6.4	5.9		(35)
		5% DB	6.7	7.0	7.3	7.5	7.5	7.5	7.6	7.2	7.1	7.2	7.2	6.7		(36)
		MCDBR	5.0	5.2	5.6	5.8	6.2	6.5	7.1	6.6	6.6	6.6	5.5	4.9		(37)
		5% WB	5.7	6.4	6.6	6.9	7.1	6.7	6.5	6.5	6.7	6.7	6.6	6.1		(38)
		MCWBR	4.9	4.9	5.5	5.7	6.2	6.1	6.3	5.9	6.6	6.4	5.5	4.7		(39)
		taub	0.352	0.378	0.418	0.461	0.447	0.410	0.420	0.432	0.401	0.396	0.365	0.351		(40)
(41)	Clear-Sky Solar Irradiance	taud	2.408	2.318	2.203	2.110	2.217	2.366	2.346	2.302	2.390	2.374	2.414	2.437		(41)
		Ebn at Noon	831	848	844	826	842	871	860	842	853	819	808	806		(42)
		Edh at Noon	90	110	135	156	142	123	124	127	111	103	89	83		(43)
		RadAvg	2.25	3.13	4.57	5.78	6.87	7.86	7.87	7.02	5.77	4.12	2.88	2.11		(44)
(45)	All-Sky Solar Radiation	RadStd	0.31	0.32	0.30	0.41	0.33	0.27	0.18	0.15	0.27	0.25	0.25	0.29		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	+0.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page