

ADANA INCIRLIK, Turkey

WMO: 173500

Lat: 37.001N

Lon: 35.418E

Elev: 66

StdP: 100.53

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 33308

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.9	2.2	-11.1	1.5	6.6	-8.6	1.8	7.6	10.5	8.6	9.4	9.4	3.0	30	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.9	36.8	22.4	35.2	22.9	34.1	23.2	26.5	32.0	26.0	31.3	25.5	30.5	4.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.4	28.5	24.6	19.8	28.3	24.1	19.1	28.1	83.6	31.9	80.8	31.5	78.7	30.7	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
8.7	7.6	6.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-2.0	40.3	1.9	1.8	-3.3	41.6	-4.4	42.7	-5.5	43.7	-6.8	45.0
			-4.1	27.5	1.9	1.1	-5.4	28.2	-6.5	28.9	-7.5	29.5	-8.9	30.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.5	9.7	11.0	13.7	17.4	21.8	25.6	28.4	29.1	26.4	22.3	16.2	11.4
	DBStd	7.28	2.62	3.05	2.92	3.09	2.85	2.16	1.41	1.33	2.04	3.06	3.38	2.77
	HDD10.0	84	36	22	5	1	0	0	0	0	0	0	2	18
	HDD18.3	975	267	204	146	53	4	0	0	0	0	6	79	217
	CDD10.0	3539	28	52	119	222	364	469	571	592	493	382	187	60
	CDD18.3	1388	0	0	2	24	110	219	313	333	243	129	14	0
	CDH23.3	15246	0	3	29	286	1078	2274	3732	4057	2505	1135	142	4
	CDH26.7	6967	0	0	3	87	431	1011	1784	2029	1171	429	22	1
Wind	WSAvg	3.0	3.3	3.2	3.1	2.9	2.8	3.0	3.1	2.9	2.8	2.7	2.8	3.2
Precipitation	PrecAvg	709	107	93	73	63	55	26	9	11	25	41	62	125
	PrecMax	1093	288	140	146	146	134	98	56	46	64	129	185	365
	PrecMin	406	14	5	6	17	14	5	1	1	0	6	0	9
	PrecStd	150	70	35	37	36	31	23	13	11	17	32	49	91
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.1	22.8	26.2	32.2	36.1	38.1	38.0	39.0	37.9	35.5	29.1	22.2
		MCWB	11.8	12.2	14.7	18.1	19.7	20.7	23.5	24.2	20.9	18.7	15.0	12.3
	2%	DB	17.3	20.2	23.7	29.1	33.7	35.4	35.8	36.1	35.1	32.9	26.9	19.9
		MCWB	11.1	12.3	14.1	17.4	19.6	21.4	23.8	24.1	21.5	18.2	15.0	11.9
	5%	DB	16.2	18.7	21.8	26.7	31.1	33.2	34.2	35.0	33.8	30.8	24.9	18.1
		MCWB	10.4	11.8	13.8	16.5	19.5	21.5	24.2	24.5	22.2	18.4	14.5	11.2
	10%	DB	14.9	17.0	19.9	24.1	28.9	31.7	33.1	34.0	32.2	29.0	22.9	16.5
		MCWB	9.7	11.0	13.3	16.3	19.2	22.1	24.2	24.6	22.2	18.1	14.2	10.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.9	15.1	16.8	19.9	22.7	25.7	27.4	27.5	25.6	23.2	18.2	15.0
		MCDB	16.7	19.3	21.8	27.8	30.2	31.7	33.2	34.1	32.1	28.4	23.4	18.7
	2%	WB	12.6	13.6	15.7	18.7	21.7	24.7	26.5	26.6	25.0	21.9	17.1	13.7
		MCDB	15.6	17.9	20.2	25.9	28.4	30.0	31.8	32.2	31.1	27.2	22.6	17.0
	5%	WB	11.6	12.7	14.9	17.8	20.9	24.1	25.9	26.2	24.4	21.0	16.2	12.8
		MCDB	14.6	17.1	19.5	24.1	27.5	29.2	30.9	31.5	30.2	26.6	21.5	16.2
	10%	WB	10.7	11.8	14.1	17.0	20.2	23.4	25.4	25.7	23.9	20.1	15.2	11.9
		MCDB	13.4	16.0	18.6	22.4	26.4	28.4	30.1	30.8	29.3	25.7	20.4	15.2
Mean Daily Temperature Range	5% DB	MDBR	9.1	10.1	10.9	11.8	12.5	11.7	10.4	10.9	12.3	12.3	11.4	9.4
		MCDBR	11.1	12.3	13.7	15.8	16.6	14.8	12.0	12.4	13.9	14.5	14.2	12.0
		MCWBR	6.6	6.5	6.7	6.9	6.2	5.5	4.2	4.2	5.0	5.8	6.5	6.5
	5% WB	MCDBR	8.6	10.4	11.3	12.8	13.4	11.6	10.2	10.5	11.7	11.4	10.7	8.9
		MCWBR	5.8	6.1	6.2	6.4	5.7	4.6	3.6	3.7	4.4	5.5	5.8	5.5
Clear-Sky Solar Irradiance	taub		0.371	0.392	0.426	0.478	0.461	0.430	0.441	0.452	0.415	0.413	0.380	0.365
	taud		2.285	2.222	2.132	2.026	2.135	2.262	2.252	2.207	2.305	2.269	2.307	2.326
	Ebn at Noon		797	827	833	809	829	853	841	823	835	795	780	777
	Edh at Noon		100	120	144	169	154	136	136	140	120	113	97	91
All-Sky Solar Radiation	RadAvg		2.24	3.15	4.45	5.53	6.58	7.57	7.65	6.82	5.62	4.06	2.86	2.10
	RadStd		0.30	0.41	0.26	0.46	0.35	0.33	0.26	0.23	0.24	0.27	0.22	0.31

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-2.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page