

HATAY, Turkey

WMO: 173725

Lat: 36.365N

Lon: 36.284E

Elev: 259

StdP: 14.56

Time Zone: 3.00 (E03)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.2	33.7	17.3	13.3	44.1	21.3	16.2	45.2	25.5	41.8	23.0	43.2	2.8	160	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.3	97.1	70.4	94.8	71.5	93.0	73.2	78.2	90.4	77.3	89.1	76.4	87.9	13.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.0	132.5	85.3	73.6	126.5	84.1	73.2	124.6	83.9	41.7	90.6	40.8	88.8	40.0	88.9	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
27.5	25.3	23.2	DB	26.2	104.2	4.1	4.6	23.2	107.5	20.9	110.2	18.6	112.7	15.6	116.0
			WB	24.7	79.8	4.3	1.0	21.6	80.5	19.1	81.1	16.7	81.7	13.6	82.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.6	46.7	51.5	57.6	64.2	72.6	80.1	84.7	85.7	80.2	69.2	57.4	48.9
	DBStd	14.31	4.72	4.98	4.06	4.87	4.83	3.83	2.25	1.91	4.21	5.18	5.82	4.94
	HDD50	253	120	40	3	0	0	0	0	0	0	0	12	78
	HDD65	2004	568	379	230	72	2	0	0	0	0	20	233	500
	CDD50	6328	17	81	239	426	702	904	1076	1105	906	596	234	42
	CDD65	2605	0	0	1	48	239	454	611	640	456	151	5	0
	CDH74	29453	0	5	39	618	2102	4581	7448	8055	5011	1499	95	0
	CDH80	12971	0	0	1	176	833	1994	3513	3854	2118	478	4	0
Wind	WSAvg	9.9	6.5	6.4	8.1	9.1	11.5	15.7	17.2	16.2	12.1	6.3	4.2	5.1
Precipitation	PrecAvg	30.4	4.4	4.5	3.5	2.7	1.9	0.8	0.4	0.4	1.5	2.2	3.3	4.7
	PrecMax	43.0	9.3	8.2	8.8	6.1	4.1	2.7	0.9	1.1	4.7	5.8	7.1	10.9
	PrecMin	20.1	1.6	1.8	0.6	0.9	0.3	0.0	0.0	0.0	0.0	0.3	0.5	0.7
	PrecStd	5.0	2.2	1.8	1.9	1.3	1.1	0.6	0.2	0.4	1.1	1.3	1.7	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.4	73.5	78.5	91.1	98.6	102.4	100.2	100.0	98.8	91.8	80.5	67.8
		MCWB	53.4	57.1	58.8	61.9	67.0	68.8	74.9	74.0	68.6	64.8	60.0	52.5
	2%	DB	59.2	68.1	73.6	84.6	93.2	96.5	95.3	95.1	93.6	88.1	77.0	62.7
		MCWB	51.3	55.5	57.3	61.3	66.0	69.8	72.1	73.8	72.4	65.9	57.4	53.7
	5%	DB	57.1	64.4	71.2	80.6	88.0	91.7	93.4	93.4	91.4	85.6	73.5	59.4
		MCWB	50.3	54.0	57.3	60.2	65.4	69.7	73.5	74.9	72.6	66.1	57.2	52.4
	10%	DB	54.0	61.1	68.0	77.0	84.2	89.3	91.6	91.8	89.6	82.3	70.1	57.4
		MCWB	48.6	52.8	56.4	60.1	65.0	70.4	74.2	75.3	72.5	64.7	56.5	51.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.9	59.8	61.1	66.3	70.9	76.4	79.2	80.0	77.8	72.3	63.1	57.8
		MCDB	60.3	70.1	71.4	80.0	86.0	89.0	91.8	93.2	89.5	83.4	73.1	61.2
	2%	WB	52.9	56.8	59.7	64.1	69.1	74.8	77.7	78.7	76.5	70.4	61.3	55.8
		MCDB	57.6	65.0	69.6	76.5	83.7	87.2	90.2	90.9	87.7	81.1	70.9	59.3
	5%	WB	51.3	55.1	58.4	62.8	67.6	73.7	76.8	77.7	75.5	69.2	59.7	54.7
		MCDB	55.4	62.2	67.9	76.2	81.8	85.7	88.9	89.6	86.5	79.8	69.0	58.5
	10%	WB	49.9	53.5	57.0	61.4	66.5	72.6	76.0	77.0	74.5	67.6	57.9	52.9
		MCDB	52.8	60.1	65.8	73.1	79.9	84.0	87.8	88.5	85.2	77.8	67.0	56.9
Mean Daily Temperature Range	5% DB	MDBR	13.2	18.3	19.6	22.6	21.7	18.3	15.7	15.3	19.9	25.1	24.6	15.7
		MCDBR	18.9	24.8	25.0	31.6	29.8	23.8	18.0	16.6	22.0	29.0	29.3	20.9
		MCWBR	11.5	13.7	12.2	13.1	10.4	8.1	7.6	7.0	8.8	12.1	13.7	13.0
	5% WB	MCDBR	15.8	20.6	21.7	25.2	23.3	18.3	16.0	15.4	18.6	23.7	23.6	15.5
		MCWBR	10.5	12.2	11.3	11.4	9.5	7.3	7.0	6.7	8.0	11.2	12.8	10.5
Clear-Sky Solar Irradiance	taub	0.381	0.405	0.437	0.491	0.476	0.435	0.447	0.462	0.423	0.433	0.393	0.376	
	taud	2.260	2.188	2.107	1.991	2.086	2.240	2.227	2.171	2.281	2.198	2.263	2.286	
	Ebn at Noon	250	259	261	253	259	270	265	259	263	246	244	243	
	Edh at Noon	33	40	47	56	51	44	44	46	39	39	33	30	
All-Sky Solar Radiation	RadAvg	698	979	1435	1817	2215	2519	2469	2203	1816	1309	921	662	
	RadStd	92	143	93	136	96	62	54	54	58	81	81	104	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (10 neighbors)	N/A	N/A	-3.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page