

FINIKE, Turkey

WMO: 173750

Lat: 36.3025N

Lon: 30.1459E

Elev: 2

StdP: 101.30

Time Zone: 3.00 (E03)

Period: 98-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 5.4	(c) 6.5	(d) -10.1	(e) 1.6	(f) 8.2	(g) -6.2	(h) 2.2	(i) 9.6	(j) 5.4	(k) 13.8	(l) 4.9	(m) 13.5	(n) 1.9	(o) 350	(p) 0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 9.7	(c) 37.1	(d) 21.6	(e) 35.7	(f) 21.7	(g) 34.3	(h) 22.1	(i) 27.0	(j) 31.8	(k) 26.2	(l) 31.3	(m) 25.5	(n) 30.8	(o) 2.6	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	20.8	30.8	24.7	19.7	30.4	23.8	18.7	29.8	85.4	31.8	81.9	31.1	78.7	30.9	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 5.3	(b) 4.4	(c) 3.8	(e) 3.2	(f) 40.2	(g) 2.2	(h) 1.4	(i) 1.6	(j) 41.2	(k) 0.3	(l) 42.0	(m) -1.0	(n) 42.8	(o) -2.6	(p) 43.8		
(a) 5.3	(b) 4.4	(c) 3.8	(e) -0.5	(f) 27.9	(g) 1.6	(h) 0.8	(i) -1.7	(j) 28.5	(k) -2.6	(l) 28.9	(m) -3.5	(n) 29.4	(o) -4.7	(p) 29.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.9	12.2	12.4	14.4	17.2	21.1	25.6	28.5	29.2	25.7	21.6	16.9	13.6		
	DBStd	6.37	1.99	2.11	2.23	2.13	2.24	2.64	1.81	1.85	1.84	2.24	2.33	2.35		
	HDD10.0	14	6	5	1	0	0	0	0	0	0	0	0	2		
	HDD18.3	729	190	166	122	45	3	0	0	0	0	3	54	146		
	CDD10.0	3634	74	72	138	217	344	468	572	596	471	359	206	116		
	CDD18.3	1307	0	0	2	12	89	218	314	338	221	103	10	1		
	CDH23.3	13983	0	0	6	66	519	2241	4007	4499	2062	549	32	2		
	CDH26.7	6278	0	0	0	14	102	922	1999	2364	783	91	3	0		
(14) Wind	WSAvg	1.4	1.3	1.5	1.5	1.5	1.4	1.5	1.5	1.5	1.5	1.3	1.3	1.4		
(15) Precipitation	PrecAvg	894	175	128	72	48	25	13	4	4	15	66	115	204		
	PrecMax	1382	562	246	160	111	100	65	23	34	122	314	538	454		
	PrecMin	542	5	14	0	5	2	0	0	0	0	0	11	20		
	PrecStd	238	118	56	43	31	21	15	5	7	29	63	99	124		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.6	20.4	24.2	28.2	32.0	37.4	38.7	39.6	35.8	30.6	26.5	22.2		
		MCWB	13.5	13.3	14.6	16.2	18.7	20.4	22.3	21.9	20.8	19.1	17.7	14.7		
	2%	DB	18.1	18.7	21.7	25.0	29.2	35.2	36.7	37.6	33.1	28.8	23.9	20.3		
		MCWB	12.8	13.1	14.3	16.2	19.4	20.2	21.9	21.8	22.2	20.0	17.1	14.2		
	5%	DB	17.1	17.7	20.2	23.2	27.5	33.6	35.2	36.1	31.6	27.5	22.4	18.9		
		MCWB	12.3	12.7	14.2	15.9	19.1	20.4	22.1	22.1	22.6	19.8	16.5	13.6		
	10%	DB	16.1	16.7	19.1	21.8	26.1	31.4	33.9	34.6	30.5	26.4	21.3	17.6		
		MCWB	11.6	12.2	13.9	15.5	19.0	20.7	22.4	22.8	22.6	19.4	15.7	12.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.9	15.2	16.8	18.5	22.2	25.2	27.5	28.3	26.1	23.0	19.8	16.8		
		MCDB	18.0	18.2	20.6	24.2	27.0	29.6	32.2	32.5	31.5	27.5	24.0	20.2		
	2%	WB	13.8	14.2	15.8	17.7	21.4	24.4	26.6	27.4	24.9	22.0	18.2	15.3		
		MCDB	17.0	17.5	19.8	22.5	26.0	29.0	31.5	31.9	30.4	26.5	22.4	18.7		
	5%	WB	13.0	13.4	15.1	17.0	20.6	23.7	25.9	26.7	24.1	21.0	17.3	14.4		
		MCDB	16.1	16.9	19.3	21.5	25.3	28.6	31.0	31.6	29.7	26.0	21.5	17.9		
	10%	WB	12.2	12.6	14.3	16.3	19.9	22.9	25.3	26.0	23.3	20.0	16.3	13.5		
		MCDB	15.1	16.1	18.4	20.8	24.7	28.0	30.5	31.2	29.2	25.1	20.3	16.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	7.4	8.3	8.6	9.2	10.1	10.0	9.7	9.5	9.0	8.2	7.3		
		MCDBR	8.5	8.8	9.6	10.7	11.0	12.7	12.5	12.1	11.2	10.3	9.5	8.9		
		MCWBR	5.8	6.0	6.0	5.9	6.0	5.8	6.2	6.1	6.9	6.6	6.5	6.0		
	5% WB	MCDBR	7.6	7.9	8.8	9.3	9.5	10.1	9.7	9.1	9.5	9.2	8.7	8.1		
		MCWBR	5.6	5.9	6.0	5.9	6.0	6.5	6.5	6.5	6.8	6.7	6.2	5.9		
(40) Clear-Sky Solar Irradiance	taub		0.353	0.384	0.423	0.462	0.451	0.416	0.427	0.444	0.411	0.400	0.370	0.356		
	taud		2.415	2.303	2.185	2.104	2.200	2.346	2.320	2.262	2.350	2.354	2.400	2.427		
	Ebn at Noon		832	843	840	826	839	867	854	832	843	816	803	801		
	Edh at Noon		90	112	137	157	145	125	128	133	115	105	90	84		
(44) All-Sky Solar Radiation	RadAvg		2.43	3.29	4.70	5.99	6.95	7.90	7.91	7.05	5.86	4.24	3.01	2.25		
	RadStd		0.26	0.28	0.28	0.38	0.29	0.26	0.16	0.14	0.24	0.23	0.21	0.23		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	N/A	N/A	N/A	+0.37	N/A	N/A	N/A	-62	N/A	N/A

Nomenclature: See separate page