

LEFKOSA, Cyprus

WMO: 175150

Lat: 35.200N

Lon: 33.350E

Elev: 131

StdP: 99.76

Time Zone: 2.00 (EUE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.4	3.0	-6.2	2.3	10.7	-4.3	2.7	11.4	10.7	9.8	9.2	11.7	0.5	210	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.4	39.0	19.8	37.8	19.8	36.7	19.7	24.1	29.9	23.5	29.4	23.0	29.0	3.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.6	17.6	27.0	21.9	16.9	26.7	21.2	16.1	26.4	73.4	30.0	71.1	29.3	68.9	28.9	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.0	7.7	6.6	-1.5	41.9	1.4	1.8	-2.6	43.2	-3.4	44.3	-4.2	45.3	-5.2	46.6	
			DB												
			WB	-2.4	25.7	1.5	1.2	-3.5	26.6	-4.3	27.2	-5.2	27.9	-6.2	28.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.8	10.1	11.0	13.6	17.8	22.0	26.6	29.6	29.7	26.4	21.8	16.3	12.0
	DBStd	7.38	2.39	2.50	2.54	2.93	2.98	2.87	1.93	1.64	2.12	2.44	2.54	2.37
	HDD10.0	58	28	17	4	0	0	0	0	0	0	0	0	10
	HDD18.3	927	255	205	149	44	3	0	0	0	3	71	197	
	CDD10.0	3632	31	45	114	234	373	499	607	612	492	367	188	72
	CDD18.3	1461	0	0	1	28	118	249	348	353	242	111	9	0
	CDH23.3	17249	0	4	31	394	1223	2905	4581	4573	2519	909	108	3
CDH26.7	9093	0	0	4	122	519	1572	2684	2624	1256	298	12	0	
Wind	WSAvg	2.3	1.8	2.0	2.4	2.5	2.7	3.1	3.0	2.7	2.5	2.0	1.6	1.6
Precipitation	PrecAvg	321	51	50	39	23	23	6	2	6	8	21	32	58
	PrecMax	501	137	124	102	82	112	53	27	63	72	121	127	146
	PrecMin	190	16	8	2	0	0	0	0	0	0	0	0	7
	PrecStd	76	29	34	28	23	30	12	6	14	16	26	29	34
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.1	22.7	26.3	32.6	36.8	39.9	41.1	40.3	38.6	33.5	28.3	22.1
		MCWB	12.8	13.4	14.2	15.4	17.2	19.1	19.9	20.5	19.5	17.2	15.8	13.4
	2%	DB	17.8	19.9	23.7	29.8	34.3	37.8	39.0	38.6	36.2	31.5	26.2	20.3
		MCWB	12.0	12.9	12.9	14.9	16.9	19.1	19.8	20.2	19.2	17.3	15.3	13.5
	5%	DB	16.8	18.2	21.9	27.9	32.0	36.0	37.7	37.6	34.6	29.8	24.3	19.0
		MCWB	11.5	12.2	13.0	14.4	16.8	18.7	19.8	20.0	19.3	17.2	15.2	13.0
	10%	DB	15.6	16.9	20.1	25.5	29.7	34.2	36.5	36.4	33.1	28.2	22.7	17.7
		MCWB	10.9	11.6	12.4	14.2	16.5	18.7	20.0	20.2	19.6	17.1	14.4	12.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.1	14.8	15.7	17.5	20.0	23.2	24.7	25.2	23.7	20.8	18.4	15.7
		MCDB	17.8	19.7	22.5	26.4	27.3	30.1	31.2	31.2	29.0	27.0	24.0	19.3
	2%	WB	12.9	13.8	14.7	16.4	18.9	22.2	23.9	24.4	22.7	19.9	17.3	14.7
		MCDB	16.7	18.4	20.7	24.9	26.5	29.1	30.3	29.8	28.1	25.8	23.0	18.5
	5%	WB	12.1	13.0	13.8	15.7	18.3	21.3	23.2	23.8	22.1	19.3	16.2	13.8
		MCDB	15.8	17.4	19.3	23.6	25.9	28.8	29.6	29.3	27.8	25.2	21.9	17.8
	10%	WB	11.3	12.1	13.1	15.1	17.7	20.6	22.7	23.3	21.5	18.7	15.3	12.9
		MCDB	14.9	16.1	18.4	22.3	25.3	28.3	29.2	29.0	27.7	24.7	20.9	16.8
Mean Daily Temperature Range	5% DB	MDBR	10.2	11.2	12.6	14.1	13.9	13.9	14.4	14.4	13.7	12.6	12.4	10.8
		MCDBR	11.7	13.1	15.6	17.5	17.0	15.6	15.6	15.4	15.9	14.4	14.5	13.0
		MCWBR	7.1	7.5	7.5	6.6	5.5	5.2	5.5	5.5	5.6	5.3	6.8	7.4
	5% WB	MCDBR	10.7	12.1	13.8	15.4	14.5	14.9	14.9	14.8	14.9	12.9	13.0	11.3
		MCWBR	6.9	7.5	7.2	6.3	5.0	5.3	5.3	5.1	5.3	5.1	6.6	7.0
Clear-Sky Solar Irradiance	taub	0.365	0.390	0.422	0.462	0.452	0.411	0.427	0.436	0.408	0.405	0.378	0.362	
	taud	2.358	2.266	2.169	2.075	2.165	2.333	2.296	2.264	2.346	2.329	2.362	2.390	
	Ebn at Noon	823	842	845	827	840	872	856	841	850	816	801	802	
	Edh at Noon	96	118	141	162	150	127	131	133	117	109	95	89	
All-Sky Solar Radiation	RadAvg	2.49	3.40	4.83	6.05	7.03	7.83	7.62	6.82	5.80	4.27	3.04	2.27	
	RadStd	0.19	0.29	0.26	0.30	0.34	0.16	0.15	0.11	0.17	0.21	0.18	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Regional (13 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-80	+162	+80

Nomenclature: See separate page