

GECITKALE, Cyprus

WMO: 175300

Lat: 35.233N

Lon: 33.733E

Elev: 148

StdP: 14.62

Time Zone: 2.00 (EUE)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.0	36.0	24.4	18.6	46.3	27.3	21.4	46.4	26.3	53.1	22.9	54.3	3.6	270	0.417

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	26.2	100.8	70.3	98.8	70.9	97.0	71.0	77.2	90.8	76.2	89.9	75.2	88.9	8.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.6	125.9	83.0	72.4	120.4	82.9	71.1	115.1	82.9	40.8	90.4	39.8	89.8	38.9	88.6	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.8	17.5	14.9	27.8	105.9	2.2	2.4	26.2	107.6	24.9	109.0	23.7	110.3	22.1	112.0		
(5)			26.7	79.3	2.2	1.3	25.2	80.2	23.9	80.9	22.6	81.6	21.0	82.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.2	51.2	52.3	55.8	62.7	70.9	78.1	83.9	84.6	78.7	71.0	61.7	54.6		
	DBStd	12.57	4.38	4.73	4.42	4.79	5.00	4.42	3.29	2.82	3.63	4.22	4.61	4.24		
	HDD50	85	37	29	8	0	0	0	0	0	0	0	0	11		
	HDD65	1622	428	356	287	100	7	0	0	0	0	6	117	321		
	CDD50	6364	75	93	187	380	646	843	1052	1072	861	650	351	154		
	CDD65	2425	0	0	1	30	188	393	587	607	411	190	18	0		
	CDH74	32177	0	9	48	788	2486	5036	8226	8345	4875	2051	303	10		
	CDH80	17075	0	0	0	220	1024	2646	4880	4968	2561	736	40	0		
(14) Wind	WSAvg	5.3	5.4	5.5	5.5	4.9	5.1	5.4	5.3	5.0	4.7	5.2	5.5	5.4		
(15) Precipitation	PrecAvg	14.1	3.0	2.0	1.1	0.7	0.8	0.2	0.1	0.0	0.3	0.8	1.7	3.1		
	PrecMax	20.7	9.1	5.9	3.9	2.1	2.5	1.0	0.8	0.2	0.9	2.6	5.8	10.8		
	PrecMin	7.1	0.7	0.6	0.0	0.1	0.2	0.0	0.0	0.0	0.0	0.1	0.0	0.3		
	PrecStd	3.8	1.7	1.3	0.8	0.5	0.6	0.3	0.2	0.1	0.3	0.6	1.4	2.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.2	75.2	78.3	90.7	98.4	102.2	104.6	103.7	100.8	92.6	83.9	73.4		
		MCWB	57.9	59.5	58.3	61.6	65.4	69.7	70.7	71.4	69.8	64.7	63.0	59.9		
	2%	DB	66.1	69.8	75.2	85.7	93.3	98.1	100.6	100.7	96.9	89.5	80.6	69.8		
		MCWB	56.7	58.2	57.6	59.8	65.1	69.5	70.6	70.9	69.9	66.1	61.5	58.5		
	5%	DB	64.2	66.5	72.4	82.5	89.2	95.0	98.4	98.7	94.3	86.9	77.3	67.7		
		MCWB	55.4	56.3	57.4	60.3	65.1	69.5	71.0	71.7	70.6	66.0	61.9	57.5		
	10%	DB	62.0	64.3	69.9	79.1	85.6	92.1	96.6	96.9	91.8	84.3	74.6	65.5		
		MCWB	54.3	55.3	57.0	59.9	64.7	69.1	71.9	71.7	70.6	66.0	60.6	56.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.2	61.2	62.5	65.5	70.3	76.3	78.3	79.1	76.2	71.9	66.8	62.5		
		MCDB	65.2	70.1	71.7	80.6	86.2	90.7	92.7	91.1	91.1	83.0	77.9	69.4		
	2%	WB	57.9	59.3	60.7	63.9	68.7	74.5	77.0	77.6	74.7	70.1	64.7	60.6		
		MCDB	64.4	68.2	70.1	78.8	83.8	87.8	90.4	90.7	89.3	82.4	75.7	67.7		
	5%	WB	56.3	57.6	59.1	62.4	67.3	73.1	76.0	76.5	73.6	68.8	63.0	59.0		
		MCDB	62.8	65.3	68.6	76.5	81.9	86.3	89.5	90.2	88.4	81.4	74.1	66.1		
	10%	WB	54.8	56.0	57.5	61.0	66.1	71.7	75.0	75.6	72.5	67.5	61.7	57.3		
		MCDB	60.9	63.2	67.5	74.5	80.6	85.3	88.7	89.2	86.8	80.1	72.4	63.7		
(35) Mean Daily Temperature Range	MDBR		20.9	23.5	27.0	29.0	27.6	26.5	25.8	26.2	27.1	26.3	25.1	21.4		
	5% DB	MCDBR	24.1	26.8	30.4	34.4	32.3	29.1	27.5	28.1	29.8	29.2	28.5	24.8		
		MCWBR	15.8	16.8	16.9	15.8	12.5	11.2	10.7	11.2	12.3	13.3	15.2	15.5		
	5% WB	MCDBR	22.8	25.5	27.1	29.5	27.5	26.3	25.5	25.7	27.5	26.1	26.0	21.7		
		MCWBR	15.6	16.9	16.4	15.5	12.2	10.8	10.0	10.2	11.9	12.8	14.5	14.2		
(40) Clear-Sky Solar Irradiance	taub		0.371	0.394	0.427	0.472	0.461	0.419	0.438	0.447	0.417	0.413	0.385	0.368		
	taud		2.346	2.263	2.165	2.061	2.151	2.323	2.279	2.246	2.331	2.309	2.342	2.372		
	Ebn at Noon		259	266	266	260	264	274	268	264	267	256	251	252		
	Edh at Noon		31	37	45	52	48	41	42	43	37	35	31	29		
(44) All-Sky Solar Radiation	RadAvg		789	1080	1529	1911	2232	2477	2408	2156	1836	1350	960	717		
	RadStd		57	91	79	96	106	49	45	37	54	67	56	65		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (13 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	-144	+292	+144	

Nomenclature: See separate page