

GAZIMAGUSA, Cyprus

WMO: 175400

Lat: 35.133N

Lon: 33.933E

Elev: 0

StdP: 14.70

Time Zone: 2.00 (EUE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	40.7	43.7	28.4	22.3	46.4	31.6	26.0	47.9	33.3	54.3	29.3	56.7	8.1	250	0.417

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.4	93.2	74.4	91.2	74.9	89.6	74.3	79.6	87.2	78.6	85.9	77.7	85.2	10.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.4	142.4	84.8	76.3	137.5	84.2	75.4	132.9	83.6	43.2	87.3	42.1	85.8	41.2	85.3	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.8	22.2	18.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.6	54.7	55.6	58.4	63.6	70.7	78.0	82.8	83.5	79.6	72.7	65.2	57.5
	DBStd	10.93	4.45	4.29	3.73	3.70	3.91	3.48	2.47	1.90	2.96	3.35	4.20	4.04
	HDD50	27	16	7	1	0	0	0	0	0	0	0	0	3
	HDD65	1140	318	263	206	69	3	0	0	0	0	0	47	234
	CDD50	6815	163	165	261	408	641	840	1016	1038	888	703	457	235
	CDD65	2450	0	0	1	27	178	390	551	573	438	238	53	1
	CDH74	23436	0	0	0	54	612	3197	6431	7132	4467	1425	118	0
	CDH80	8150	0	0	0	4	81	839	2541	3047	1463	172	3	0
(14) Wind	WSAvg	8.5	9.8	9.6	9.0	7.6	7.6	8.0	8.1	7.9	7.8	7.8	9.1	9.3
(15) Precipitation	PrecAvg	13.6	3.1	2.0	1.0	0.7	0.6	0.1	0.0	0.0	0.2	0.7	1.7	3.3
	PrecMax	23.3	9.4	6.0	3.7	1.9	2.3	0.5	0.4	0.3	0.8	2.1	5.6	12.5
	PrecMin	6.7	0.5	0.4	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
	PrecStd	4.1	1.9	1.4	0.8	0.4	0.6	0.2	0.1	0.1	0.3	0.6	1.4	2.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.5	68.1	70.5	79.2	86.4	92.7	96.7	96.3	93.0	85.8	79.1	70.7
		MCWB	58.9	59.3	58.6	61.1	66.6	70.8	73.7	74.4	73.8	71.6	67.3	61.7
	2%	DB	64.8	65.6	68.0	75.3	82.0	89.4	93.1	93.3	90.0	83.6	76.7	68.4
		MCWB	57.7	58.4	58.7	61.1	67.1	71.4	74.4	75.1	74.7	71.4	67.4	60.5
	5%	DB	63.7	64.5	66.6	72.9	79.4	86.9	91.0	91.4	88.0	82.0	75.3	67.3
		MCWB	56.7	57.8	58.7	61.6	66.8	71.5	74.6	75.7	74.2	70.5	66.7	59.7
	10%	DB	62.4	63.4	65.6	70.9	77.3	84.6	89.1	89.7	86.2	80.5	73.7	65.7
		MCWB	55.5	56.9	58.3	61.8	66.2	71.0	74.2	75.1	73.7	69.7	64.3	58.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.0	61.7	63.2	67.3	72.7	78.3	80.6	81.5	79.2	76.7	70.9	63.4
		MCDB	65.2	65.2	66.6	71.5	78.1	84.1	89.3	89.6	86.6	83.0	76.0	68.5
	2%	WB	59.3	60.1	61.6	65.5	70.6	76.5	79.1	80.0	77.9	74.0	69.3	61.8
		MCDB	64.0	64.8	65.9	70.7	77.2	82.8	86.4	87.9	86.0	81.0	75.7	67.4
	5%	WB	57.6	58.8	60.4	64.0	69.2	75.2	78.2	79.0	76.8	72.3	67.4	60.5
		MCDB	62.8	63.8	65.4	70.1	76.2	82.1	85.4	86.4	85.1	80.1	74.6	66.4
	10%	WB	56.2	57.5	59.2	62.8	68.1	74.0	77.3	78.1	75.6	70.9	65.3	59.2
		MCDB	61.7	62.7	64.6	69.1	75.1	81.4	84.8	85.6	84.1	79.1	72.8	65.0
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	12.5	13.0	13.4	12.7	12.9	13.4	13.4	14.0	14.1	14.0	13.2
		MCDBR	13.1	13.2	14.0	16.3	15.4	16.2	17.3	17.0	16.5	16.3	15.8	15.6
		MCWBR	8.9	9.0	9.5	10.5	9.5	10.2	10.3	10.2	9.2	10.6	10.6	11.0
	5% WB	MCDBR	11.9	11.4	11.6	14.3	13.9	14.3	15.0	14.5	14.6	14.2	13.9	13.4
		MCWBR	8.8	8.8	9.1	10.4	9.4	9.6	9.3	8.9	9.2	11.1	11.0	10.2
(40) Clear-Sky Solar Irradiance	taub		0.373	0.397	0.432	0.478	0.467	0.424	0.444	0.453	0.422	0.419	0.389	0.371
	taud		2.346	2.260	2.159	2.052	2.140	2.317	2.269	2.239	2.326	2.300	2.338	2.369
	Ebn at Noon		258	265	265	258	262	273	266	262	265	254	250	251
	Edh at Noon		31	38	45	53	49	41	43	43	38	36	31	29
(44) All-Sky Solar Radiation	RadAvg		801	1096	1543	1920	2250	2484	2410	2162	1846	1360	969	726
	RadStd		55	90	75	99	105	48	42	36	54	66	56	67

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-144	+292	+144

Nomenclature: See separate page