

GAZIMAGUSA, Cyprus

WMO: 175400

Lat: 35.133N

Lon: 33.933E

Elev: 0

StdP: 101.33

Time Zone: 2.00 (EUE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.8	6.5	-2.0	3.2	8.0	-0.2	3.7	8.8	14.9	12.4	13.1	13.7	3.6	250	0.417

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	34.0	23.6	32.9	23.8	32.0	23.5	26.4	30.6	25.9	29.9	25.4	29.6	4.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	20.3	29.3	24.6	19.6	29.0	24.1	19.0	28.7	82.5	30.7	80.1	29.9	78.0	29.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.5	9.9	8.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.3	12.6	13.1	14.7	17.6	21.5	25.6	28.2	28.6	26.4	22.6	18.5	14.2
	DBStd	6.07	2.47	2.39	2.07	2.05	2.17	1.93	1.37	1.05	1.64	1.86	2.33	2.24
	HDD10.0	15	9	4	1	0	0	0	0	0	0	0	0	2
	HDD18.3	633	177	146	114	38	2	0	0	0	0	0	26	130
	CDD10.0	3786	91	92	145	227	356	467	564	577	493	391	254	131
	CDD18.3	1361	0	0	1	15	99	217	306	318	243	132	29	1
	CDH23.3	13020	0	0	0	30	340	1776	3573	3962	2482	792	66	0
	CDH26.7	4528	0	0	0	2	45	466	1412	1693	813	96	2	0
Wind	WSAvg	3.8	4.4	4.3	4.0	3.4	3.4	3.6	3.6	3.5	3.5	3.5	4.1	4.2
Precipitation	PrecAvg	346	79	50	26	17	15	3	1	1	6	19	43	83
	PrecMax	592	238	153	95	48	59	12	9	8	20	54	142	318
	PrecMin	170	12	11	0	2	1	0	0	0	0	1	0	6
	PrecStd	104	47	35	20	11	15	4	3	2	7	15	36	67
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.2	20.1	21.4	26.2	30.2	33.7	35.9	35.7	33.9	29.9	26.1	21.5
		MCWB	15.0	15.1	14.8	16.2	19.2	21.6	23.2	23.6	23.2	22.0	19.6	16.5
	2%	DB	18.2	18.7	20.0	24.1	27.8	31.9	34.0	34.1	32.2	28.7	24.8	20.2
		MCWB	14.3	14.7	14.8	16.2	19.5	21.9	23.6	23.9	23.7	21.9	19.7	15.8
	5%	DB	17.6	18.0	19.2	22.7	26.3	30.5	32.8	33.0	31.1	27.8	24.1	19.6
		MCWB	13.7	14.3	14.8	16.4	19.3	21.9	23.7	24.3	23.4	21.4	19.3	15.4
	10%	DB	16.9	17.4	18.7	21.6	25.1	29.2	31.7	32.1	30.1	26.9	23.2	18.7
		MCWB	13.1	13.8	14.6	16.5	19.0	21.7	23.4	24.0	23.2	20.9	17.9	14.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.1	16.5	17.3	19.6	22.6	25.7	27.0	27.5	26.2	24.9	21.6	17.5
		MCDB	18.4	18.4	19.2	22.0	25.6	29.0	31.8	32.0	30.3	28.4	24.5	20.3
	2%	WB	15.1	15.6	16.5	18.6	21.5	24.7	26.2	26.7	25.5	23.3	20.7	16.6
		MCDB	17.8	18.2	18.8	21.5	25.1	28.2	30.2	31.0	30.0	27.2	24.3	19.7
	5%	WB	14.2	14.9	15.8	17.8	20.7	24.0	25.7	26.1	24.9	22.4	19.7	15.9
		MCDB	17.1	17.7	18.5	21.2	24.5	27.8	29.7	30.2	29.5	26.7	23.7	19.1
	10%	WB	13.5	14.2	15.1	17.1	20.1	23.3	25.2	25.6	24.2	21.6	18.5	15.1
		MCDB	16.5	17.0	18.1	20.6	23.9	27.5	29.3	29.8	29.0	26.2	22.7	18.3
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.0	7.2	7.4	7.0	7.2	7.5	7.5	7.8	7.8	7.8	7.3
		MCDBR	7.3	7.4	7.8	9.0	8.5	9.0	9.6	9.5	9.2	9.1	8.8	8.6
		MCWBR	5.0	5.0	5.3	5.8	5.3	5.7	5.7	5.6	5.1	5.9	5.9	6.1
	5% WB	MCDBR	6.6	6.3	6.5	8.0	7.7	8.0	8.3	8.1	7.9	7.7	7.7	7.5
		MCWBR	4.9	4.9	5.1	5.8	5.2	5.3	5.2	4.9	5.1	6.2	6.1	5.6
Clear-Sky Solar Irradiance	taub	0.373	0.397	0.432	0.478	0.467	0.424	0.444	0.453	0.422	0.419	0.389	0.371	
	taud	2.346	2.260	2.159	2.052	2.140	2.317	2.269	2.239	2.326	2.300	2.338	2.369	
	Ebn at Noon	814	834	835	814	827	860	840	826	836	802	788	791	
	Edh at Noon	98	119	142	166	154	129	135	136	119	113	98	91	
All-Sky Solar Radiation	RadAvg	2.52	3.45	4.87	6.05	7.09	7.83	7.60	6.82	5.82	4.29	3.06	2.29	
	RadStd	0.17	0.28	0.24	0.31	0.33	0.15	0.13	0.11	0.17	0.21	0.17	0.21	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-80	+162	+80

Nomenclature: See separate page