

YENIERENKOY, Cyprus

WMO: 175500

Lat: 35.533N

Lon: 34.170E

Elev: 404

StdP: 14.48

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 42.1	(c) 44.5	(d) 22.8	(e) 17.4	(f) 46.1	(g) 26.1	(h) 20.4	(i) 47.4	(j) 25.4	(k) 51.6	(l) 22.7	(m) 51.2	(n) 9.1	(o) 320	(p) 0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 15.3	(c) 94.5	(d) 72.1	(e) 92.5	(f) 73.3	(g) 90.8	(h) 73.8	(i) 78.2	(j) 87.6	(k) 77.4	(l) 86.7	(m) 76.7	(n) 85.8	(o) 6.2	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.9	137.4	82.7	74.9	132.6	82.4	74.0	128.6	82.3	42.1	87.9	41.3	86.6	40.6	85.9	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 21.5	(b) 18.4	(c) 15.9	(e) 37.7	(f) 101.0	(g) 4.1	(h) 1.4	(i) 34.8	(j) 102.0	(k) 32.4	(l) 102.8	(m) 30.1	(n) 103.6	(o) 27.1	(p) 104.7		
(a) 21.5	(b) 18.4	(c) 15.9	(e) 33.1	(f) 80.1	(g) 3.5	(h) 1.3	(i) 30.6	(j) 81.1	(k) 28.5	(l) 81.8	(m) 26.6	(n) 82.6	(o) 24.0	(p) 83.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.8	54.3	55.6	58.6	64.3	71.1	78.0	83.4	84.7	80.1	73.1	65.0	56.8		
	DBStd	11.32	4.05	4.29	3.82	3.87	4.17	3.79	2.88	2.35	2.94	3.66	4.07	4.22		
	HDD50	32	16	8	2	0	0	0	0	0	0	0	0	6		
	HDD65	1160	332	263	199	58	3	0	0	0	0	1	49	255		
	CDD50	6905	149	165	270	429	654	839	1037	1076	902	717	451	216		
	CDD65	2557	0	0	2	37	191	389	572	611	452	253	50	0		
	CDH74	22461	0	0	3	102	878	3001	6250	7066	3963	1149	49	0		
	CDH80	8396	0	0	0	9	189	978	2670	3094	1306	149	1	0		
(14) Wind	WSAvg	6.5	7.0	7.3	7.5	6.4	6.3	6.8	6.6	6.4	6.2	5.7	5.8	6.7		
(15) Precipitation	PrecAvg	22.6	3.6	2.8	2.1	1.6	1.5	0.8	0.3	0.3	0.7	1.7	2.7	4.5		
	PrecMax	33.1	8.0	4.4	4.7	3.4	2.9	1.7	1.3	0.9	1.9	4.4	6.4	12.1		
	PrecMin	15.2	0.9	0.4	0.6	0.4	0.3	0.1	0.0	0.1	0.1	0.3	0.1	0.6		
	PrecStd	4.6	1.8	1.0	0.9	0.7	0.7	0.4	0.3	0.2	0.5	1.0	1.5	2.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.2	68.4	72.9	81.4	88.9	95.3	98.2	98.1	92.7	85.8	77.3	68.4		
		MCWB	55.2	59.5	58.5	62.7	65.1	68.7	70.6	72.0	71.6	68.6	63.4	58.5		
	2%	DB	62.9	65.4	69.2	77.3	84.9	91.1	94.4	94.7	90.1	83.2	75.4	66.1		
		MCWB	54.8	57.0	57.7	60.7	65.3	69.5	72.1	72.9	73.3	68.0	63.5	57.3		
	5%	DB	61.4	63.7	67.1	74.4	81.4	88.1	92.4	92.7	88.2	81.6	73.4	64.3		
		MCWB	53.8	55.7	57.3	60.9	65.7	71.0	73.5	74.3	73.4	67.7	62.1	56.3		
	10%	DB	59.9	62.0	65.3	71.7	78.6	85.5	90.5	91.0	86.5	80.0	71.5	62.9		
		MCWB	52.7	54.6	56.2	60.2	65.4	70.8	74.1	75.1	72.7	67.0	60.7	54.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.1	60.2	60.9	65.8	70.9	76.5	78.5	80.0	77.3	72.9	67.7	61.2		
		MCDB	61.9	66.2	68.2	75.1	79.9	86.0	88.7	89.4	86.3	81.9	74.3	65.5		
	2%	WB	55.9	58.7	59.7	64.0	69.2	74.8	77.7	78.8	76.2	71.1	65.6	59.5		
		MCDB	61.2	63.9	66.7	72.3	78.6	84.1	87.5	88.1	85.6	79.8	72.2	64.5		
	5%	WB	54.8	57.1	58.5	62.7	67.9	73.7	77.0	78.0	75.3	70.0	64.0	57.8		
		MCDB	60.0	62.2	65.3	70.8	77.0	83.1	86.5	87.1	84.6	78.4	70.7	62.9		
	10%	WB	53.6	55.7	57.4	61.6	66.8	72.6	76.3	77.3	74.5	68.9	62.6	56.3		
		MCDB	58.7	60.7	63.7	69.4	75.8	81.7	85.5	86.2	83.4	76.9	69.4	61.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	10.9	12.3	13.9	14.8	15.1	15.6	15.3	13.8	12.8	11.2	9.8		
		MCDBR	10.7	11.7	13.7	17.2	18.0	18.0	17.5	16.7	15.2	13.5	12.2	10.8		
	5% WB	MCWBR	6.7	7.9	8.5	10.0	9.7	8.8	8.5	8.0	7.1	7.5	7.1	6.8		
		MCWBR	10.2	11.8	12.9	15.6	16.5	16.3	16.4	16.1	14.7	12.8	12.0	9.9		
(40) Clear-Sky Solar Irradiance	taub	taub	0.367	0.389	0.421	0.470	0.458	0.419	0.440	0.449	0.416	0.411	0.383	0.366		
		taud	2.367	2.295	2.201	2.085	2.182	2.346	2.298	2.264	2.360	2.330	2.358	2.383		
	Ebn at Noon	Ebn at Noon	259	267	268	260	265	274	267	263	267	256	251	252		
		Edh at Noon	30	36	43	51	47	40	42	42	36	35	30	28		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	768	1063	1509	1880	2216	2459	2386	2133	1810	1321	939	697		
	RadStd	RadStd	56	88	76	104	104	53	42	37	58	67	58	67		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (18 neighbors)	+0.65	N/A	N/A	N/A	N/A	N/A	N/A	-135	+245	+112

Nomenclature: See separate page