

YENIERENKOY, Cyprus

WMO: 175500

Lat: 35.533N

Lon: 34.170E

Elev: 123

StdP: 99.86

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.6	7.0	-5.1	2.5	7.8	-3.3	2.9	8.6	11.3	10.9	10.2	10.7	4.1	320	0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.5	34.7	22.3	33.6	23.0	32.7	23.2	25.7	30.9	25.2	30.4	24.8	29.9	2.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.4	19.6	28.2	23.8	18.9	28.0	23.3	18.4	27.9	80.1	31.0	78.3	30.4	76.5	30.0	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.6	8.2	7.1	3.2	38.3	2.3	0.8	1.5	38.9	0.2	39.4	-1.1	39.8	-2.7	40.4		
			0.6	26.7	1.9	0.7	-0.8	27.3	-1.9	27.7	-3.0	28.1	-4.4	28.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	12.4	13.1	14.8	17.9	21.7	25.5	28.6	29.3	26.7	22.8	18.3	13.8
	DBStd	6.29	2.25	2.39	2.12	2.15	2.32	2.11	1.60	1.31	1.64	2.03	2.26	2.34
	HDD10.0	18	9	4	1	0	0	0	0	0	0	0	0	3
	HDD18.3	644	184	146	111	32	2	0	0	0	1	27	142	
	CDD10.0	3836	83	92	150	238	363	466	576	598	501	398	251	120
	CDD18.3	1421	0	0	1	21	106	216	318	339	251	141	28	0
	CDH23.3	12478	0	0	2	57	488	1667	3472	3926	2202	638	27	0
CDH26.7	4664	0	0	0	5	105	543	1483	1719	726	83	1	0	
Wind	WSAvg	2.9	3.1	3.3	3.3	2.9	2.8	3.0	2.9	2.9	2.8	2.5	2.6	3.0
Precipitation	PrecAvg	574	92	71	54	41	37	21	8	8	17	43	68	114
	PrecMax	841	202	112	120	87	74	44	33	22	49	111	163	308
	PrecMin	385	23	11	16	11	7	3	1	2	2	7	3	14
	PrecStd	116	46	25	23	19	19	11	7	5	13	25	37	69
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.9	20.2	22.7	27.4	31.6	35.1	36.8	36.7	33.7	29.9	25.2	20.2
		MCWB	12.9	15.3	14.7	17.1	18.4	20.4	21.4	22.2	22.0	20.3	17.5	14.7
	2%	DB	17.2	18.6	20.7	25.2	29.4	32.8	34.7	34.8	32.3	28.4	24.1	18.9
		MCWB	12.7	13.9	14.3	16.0	18.5	20.8	22.3	22.7	22.9	20.0	17.5	14.0
	5%	DB	16.4	17.6	19.5	23.6	27.5	31.2	33.5	33.7	31.2	27.6	23.0	18.0
		MCWB	12.1	13.2	14.1	16.1	18.7	21.7	23.0	23.5	23.0	19.8	16.7	13.5
	10%	DB	15.5	16.7	18.5	22.0	25.9	29.7	32.5	32.8	30.3	26.7	21.9	17.1
		MCWB	11.5	12.6	13.5	15.7	18.5	21.5	23.4	23.9	22.6	19.4	15.9	12.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.5	15.7	16.1	18.8	21.6	24.7	25.8	26.7	25.2	22.7	19.9	16.2
		MCDB	16.6	19.0	20.1	23.9	26.6	30.0	31.5	31.9	30.2	27.7	23.5	18.6
	2%	WB	13.3	14.8	15.4	17.8	20.7	23.8	25.4	26.0	24.6	21.7	18.7	15.3
		MCDB	16.2	17.7	19.3	22.4	25.9	28.9	30.8	31.2	29.8	26.5	22.3	18.1
	5%	WB	12.6	14.0	14.7	17.1	20.0	23.2	25.0	25.6	24.1	21.1	17.8	14.3
		MCDB	15.6	16.8	18.5	21.6	25.0	28.4	30.3	30.6	29.2	25.8	21.5	17.2
	10%	WB	12.0	13.1	14.1	16.4	19.3	22.6	24.6	25.2	23.6	20.5	17.0	13.5
		MCDB	14.8	15.9	17.6	20.8	24.3	27.6	29.7	30.1	28.6	25.0	20.8	16.3
Mean Daily Temperature Range	5% DB	MDBR	5.5	6.0	6.8	7.7	8.2	8.4	8.7	8.5	7.7	7.1	6.2	5.4
		MCDBR	6.0	6.5	7.6	9.6	10.0	10.0	9.7	9.3	8.5	7.5	6.8	6.0
		MCWBR	3.7	4.4	4.7	5.6	5.4	4.9	4.7	4.4	3.9	4.1	4.0	3.8
	5% WB	MCDBR	5.6	6.5	7.2	8.7	9.1	9.1	9.1	9.0	8.2	7.1	6.7	5.5
		MCWBR	3.8	4.7	4.8	5.1	5.2	4.5	4.4	4.1	4.0	4.3	4.3	3.7
Clear-Sky Solar Irradiance	taub	0.367	0.389	0.421	0.470	0.458	0.419	0.440	0.449	0.416	0.411	0.383	0.366	
	taud	2.367	2.295	2.201	2.085	2.182	2.346	2.298	2.264	2.360	2.330	2.358	2.383	
	Ebn at Noon	818	842	845	820	834	865	843	829	841	808	792	793	
	Edh at Noon	95	114	136	161	148	125	131	133	115	109	95	89	
All-Sky Solar Radiation	RadAvg	2.42	3.35	4.76	5.93	6.99	7.75	7.52	6.72	5.71	4.17	2.96	2.20	
	RadStd	0.18	0.28	0.24	0.33	0.33	0.17	0.13	0.12	0.18	0.21	0.18	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (18 neighbors)	+0.36	N/A	N/A	N/A	N/A	N/A	N/A	-75	+136	+62

Nomenclature: See separate page