

AKROTIRI, Cyprus

WMO: 176010

Lat: 34.590N

Lon: 32.988E

Elev: 23

StdP: 101.05

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 5.4	(c) 6.9	(d) -3.4	(e) 2.8	(f) 9.2	(g) -1.2	(h) 3.4	(i) 10.4	(j) 12.5	(k) 13.7	(l) 11.6	(m) 14.0	(n) 2.3	(o) 330	(p) 0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.2	(c) 33.2	(d) 22.8	(e) 32.0	(f) 23.1	(g) 31.0	(h) 23.6	(i) 26.5	(j) 29.7	(k) 26.0	(l) 29.3	(m) 25.5	(n) 28.9	(o) 4.0	(p) 260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.6	20.9	28.5	25.0	20.2	28.3	24.3	19.3	28.0	83.1	29.8	80.8	29.5	78.8	28.9	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.8	9.7	8.9	2.7	36.6	1.8	1.3	1.4	37.5	0.4	38.2	-0.6	38.9	-1.9	39.9		
			0.5	27.7	1.8	1.0	-0.8	28.4	-1.8	28.9	-2.8	29.5	-4.1	30.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.9	12.7	13.0	14.7	17.5	21.3	24.8	27.1	27.4	25.3	22.3	18.1	14.4
	DBStd	5.67	2.20	2.23	2.21	2.43	2.39	2.09	1.51	1.37	1.51	2.11	2.51	2.23
	HDD10.0	10	5	3	1	0	0	0	0	0	0	0	0	1
	HDD18.3	638	173	148	115	43	2	0	0	0	0	1	33	122
	CDD10.0	3633	90	88	146	226	349	443	530	540	460	381	242	138
	CDD18.3	1219	0	0	2	18	93	193	272	282	210	124	25	1
	CDH23.3	10879	0	0	3	83	468	1533	2909	3158	1871	763	90	1
Wind	WSAvg	3.8	3.9	3.9	3.9	4.0	4.0	4.3	4.4	4.2	3.7	2.9	3.2	3.6
	PrecAvg	471	102	83	42	22	13	5	2	2	5	21	61	112
	PrecMax	795	360	169	97	64	53	29	12	12	28	96	247	342
	PrecMin	274	8	20	0	0	0	0	0	0	0	0	0	12
	PrecStd	144	76	40	25	14	13	7	3	4	8	22	51	75
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.5	20.9	23.6	28.5	32.2	34.2	35.0	34.9	33.1	31.2	27.3	22.0
		MCWB	14.8	15.2	15.0	16.4	18.5	20.7	22.3	23.1	22.1	20.1	19.0	16.1
	2%	DB	18.5	19.2	21.5	25.5	29.2	32.0	33.0	33.0	31.1	29.2	25.4	20.8
		MCWB	13.9	14.2	14.8	15.9	18.2	20.8	23.2	24.0	22.9	20.6	17.9	15.5
	5%	DB	17.9	18.2	20.1	23.8	27.5	30.2	31.8	31.9	30.1	28.0	24.2	19.9
		MCWB	13.4	13.6	14.5	15.9	18.6	21.2	23.7	24.4	23.0	20.5	17.5	14.9
	10%	DB	17.0	17.3	19.0	22.0	25.9	29.0	30.7	30.9	29.1	27.0	23.1	18.9
		MCWB	13.0	13.0	14.2	15.9	18.5	21.8	24.3	24.9	22.8	20.2	17.0	14.4
	0.4%	WB	16.2	16.2	17.0	19.0	22.3	25.5	27.1	27.4	26.1	23.7	20.7	17.6
		MCDB	18.5	19.2	20.7	22.8	26.1	28.6	30.4	30.3	29.4	27.7	24.9	20.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	15.0	15.2	16.1	17.9	21.2	24.5	26.3	26.7	25.2	22.6	19.6	16.4
		MCDB	17.6	18.3	19.3	21.8	25.1	28.0	29.6	29.8	28.8	26.6	23.9	19.5
	5%	WB	14.1	14.4	15.5	17.2	20.5	23.8	25.9	26.2	24.5	21.9	18.6	15.6
		MCDB	17.0	17.5	18.8	21.1	24.3	27.4	29.2	29.4	28.2	26.2	23.0	18.9
	10%	WB	13.3	13.6	14.9	16.6	19.8	23.2	25.4	25.8	23.9	21.1	17.6	14.9
		MCDB	16.4	16.8	18.3	20.5	23.6	26.8	28.8	29.1	27.8	25.7	22.0	18.3
Mean Daily Temperature Range	5% DB	MDBR	7.6	7.9	7.9	7.9	7.7	7.4	7.2	7.2	7.8	8.8	8.8	7.8
		MCDBR	8.0	8.7	9.0	10.2	10.2	9.4	8.7	8.4	8.9	9.7	9.7	8.5
		MCWBR	5.3	5.9	5.7	5.4	5.4	5.8	6.1	6.3	6.9	7.1	6.8	5.8
	5% WB	MCDBR	7.3	8.1	8.0	8.5	8.4	7.8	7.6	7.6	8.1	8.7	8.8	7.6
		MCWBR	5.4	5.9	5.5	5.0	5.0	5.0	5.3	5.5	6.7	6.8	6.6	5.6
Clear-Sky Solar Irradiance	taub		0.371	0.402	0.437	0.472	0.464	0.416	0.430	0.440	0.413	0.412	0.383	0.365
	taud		2.356	2.244	2.139	2.059	2.142	2.336	2.301	2.272	2.347	2.327	2.371	2.401
	Ebn at Noon		820	832	832	820	831	868	853	839	846	813	801	804
	Edh at Noon		98	121	146	165	154	127	130	132	117	110	96	89
All-Sky Solar Radiation		RadAvg	2.63	3.57	5.01	6.21	7.20	7.94	7.72	6.94	5.96	4.45	3.17	2.43
		RadStd	0.17	0.31	0.23	0.31	0.35	0.15	0.12	0.10	0.16	0.18	0.16	0.20

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.29	N/A	N/A	N/A	N/A	+0.22	N/A	-57	+115	N/A
Regional (11 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-80	+162	+80

Nomenclature: See separate page