

LARNACA, Cyprus

WMO: 176090

Lat: 34.875N

Lon: 33.625E

Elev: 8

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.6	42.6	24.9	19.0	48.0	28.5	22.5	50.1	29.4	56.8	24.7	57.9	7.3	310	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.2	94.7	73.2	92.8	74.0	91.1	74.5	80.5	87.5	79.4	86.8	78.5	86.2	13.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.8	149.4	84.6	77.3	141.8	84.2	76.0	136.1	83.9	44.3	88.0	43.1	86.9	42.1	86.3	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
25.0	21.8	19.3	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
			DB	35.8	99.9	2.3	2.8	34.1	101.9	32.8	103.5	31.5	105.1	29.8	107.1
			WB	32.1	82.3	2.8	1.4	30.0	83.3	28.4	84.1	26.8	84.9	24.7	86.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	68.4	54.5	55.1	58.2	63.7	71.1	77.8	82.2	82.8	78.8	73.1	64.8	57.9	(6)
		DBStd	10.91	4.03	4.20	4.09	4.63	4.56	3.95	2.68	2.56	2.84	4.02	4.77	4.13	(7)
		HDD50	26	12	9	2	0	0	0	0	0	0	0	0	3	(8)
		HDD65	1181	326	279	214	78	4	0	0	0	2	57	221		(9)
		CDD50	6742	152	151	255	410	653	835	997	1017	863	716	445	248	(10)
		CDD65	2421	0	0	3	38	192	385	532	552	413	253	52	1	(11)
		CDH74	25696	0	1	12	262	1423	3934	6524	6970	4371	1950	247	2	(12)
		CDH80	10465	0	0	0	46	375	1443	3019	3334	1747	484	17	0	(13)
(14)	Wind	WSAvg	8.4	8.4	8.3	8.3	8.4	8.6	9.0	9.3	8.8	8.1	7.5	8.0	8.1	(14)
(15)	Precipitation	PrecAvg	13.0	2.9	1.9	1.3	0.6	0.5	0.1	0.0	0.0	0.1	0.7	1.7	3.3	(15)
		PrecMax	22.0	9.3	6.3	5.5	3.5	1.8	0.9	0.2	0.6	0.9	2.8	8.8	14.5	(16)
		PrecMin	6.3	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	(17)
		PrecStd	4.2	1.9	1.4	1.1	0.6	0.6	0.2	0.0	0.1	0.2	0.7	1.8	2.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	68.2	70.9	75.5	85.5	91.7	96.5	97.0	97.3	93.3	89.9	82.4	73.0		(19)
		0.4% MCWB	59.8	59.9	60.0	63.2	66.1	69.5	72.2	74.1	72.5	69.1	67.5	62.9		(20)
		2% DB	66.4	67.9	72.2	80.4	87.6	92.1	94.3	94.6	91.1	86.8	79.0	70.1		(21)
		2% MCWB	57.8	58.6	59.7	61.6	65.7	70.1	73.3	75.0	73.4	69.8	65.0	60.5		(22)
		5% DB	64.7	66.1	69.8	76.8	84.1	89.4	92.0	92.8	89.4	84.4	76.9	68.3		(23)
		5% MCWB	56.5	57.5	59.3	61.8	66.3	70.7	74.7	75.8	73.8	69.5	64.1	59.1		(24)
		10% DB	63.0	64.4	67.9	73.7	80.9	87.1	90.4	91.0	87.7	82.6	74.8	66.5		(25)
		10% MCWB	55.6	56.3	58.4	61.4	66.4	71.6	75.5	76.3	73.5	68.8	63.0	58.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	62.2	62.6	64.5	67.4	73.1	78.9	81.8	83.2	79.8	75.8	70.2	65.2		(27)
		0.4% MCDB	66.5	66.9	70.8	74.6	79.7	85.0	87.6	88.8	87.2	84.4	78.3	70.8		(28)
		2% WB	59.7	60.3	62.5	65.5	71.1	77.1	80.1	81.0	78.0	73.5	67.8	62.6		(29)
		2% MCDB	64.5	65.9	69.0	74.3	78.9	84.4	87.0	88.1	86.5	82.8	76.8	68.0		(30)
		5% WB	58.0	58.8	60.9	64.2	69.7	75.8	79.2	79.8	76.7	71.9	65.8	60.8		(31)
		5% MCDB	63.3	64.6	67.5	72.9	78.1	83.3	86.3	87.4	85.9	81.7	74.5	66.9		(32)
		10% WB	56.5	57.2	59.4	62.9	68.5	74.6	78.3	78.9	75.4	70.2	64.1	59.3		(33)
		10% MCDB	62.0	63.0	66.2	71.4	77.2	82.4	85.8	86.7	85.0	80.3	72.6	65.1		(34)
(35)	Mean Daily Temperature Range	MDBR	16.0	17.2	18.4	18.4	17.9	17.6	17.5	17.2	18.1	18.2	17.6	15.8		(35)
		5% DB MCDBR	16.9	18.0	19.5	20.8	21.4	20.0	19.5	19.3	19.4	19.1	18.7	17.2		(36)
		5% WB MCWBR	10.9	11.7	12.5	12.9	12.8	12.5	12.3	12.7	13.0	12.6	11.9	10.8		(37)
		5% WB MCWBR	15.5	16.9	18.0	18.6	18.0	17.7	17.4	17.3	18.1	17.8	17.6	15.8		(38)
(39)			10.8	11.6	12.3	12.3	11.3	11.2	11.0	11.1	12.3	12.6	11.8	10.8		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.371	0.396	0.431	0.471	0.462	0.417	0.435	0.443	0.415	0.413	0.384	0.367		(40)
		taud	2.350	2.255	2.152	2.060	2.143	2.324	2.282	2.255	2.334	2.310	2.353	2.384		(41)
		Ebn at Noon	259	265	266	260	264	275	269	265	267	257	252	253		(42)
		Edh at Noon	31	38	46	52	49	41	42	43	37	36	31	29		(43)
(44)	All-Sky Solar Radiation	RadAvg	820	1115	1563	1943	2262	2498	2428	2183	1869	1385	988	745		(44)
(45)		RadStd	54	93	76	95	108	45	42	36	53	64	54	66		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.63	N/A	N/A	N/A	N/A	+0.76	N/A	-108	+229	N/A
(47)	Regional (12 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-144	+292	+144

Nomenclature: See separate page