

OSTROV VIZE, Russian Federation

WMO: 200690

Lat: 79.491N

Lon: 76.981E

Elev: 33

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-36.6	-32.9	-40.5	0.5	-36.5	-37.1	0.7	-32.8	43.6	5.3	38.2	0.4	8.9	10	1.200

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.1	38.8	38.0	37.7	37.0	36.5	35.9	38.4	38.8	37.2	37.5	36.0	36.3	13.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
38.1	33.7	38.6	36.8	32.1	37.3	35.5	30.5	36.1	14.6	39.0	14.0	37.6	13.5	36.4	45.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.6	31.4	28.0	DB	-35.6	40.9	6.9	2.6	-40.6	42.7	-44.6	44.3	-48.5	45.8	-53.5	47.7	(4)
(5)			WB	-35.8	39.3	6.8	2.3	-40.7	40.9	-44.7	42.3	-48.5	43.5	-53.4	45.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	-7.7	-9.0	-7.8	0.2	16.1	29.4	33.2	33.2	29.3	18.7	5.1	-3.6
	DBStd	19.53	15.58	15.34	13.42	10.69	7.53	3.40	2.05	2.43	5.19	10.90	13.12	14.64
	HDD50	14038	1789	1652	1792	1494	1052	617	521	520	622	971	1348	1660
	HDD65	19513	2254	2072	2257	1944	1517	1067	986	985	1072	1436	1798	2125
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.0	14.3	13.5	13.6	13.2	12.3	13.6	13.5	13.6	14.8	16.1	15.0	15.0
Precipitation	PrecAvg	8.1	0.5	0.5	0.5	0.4	0.6	0.5	0.8	1.0	0.9	0.9	0.7	0.7
	PrecMax	13.0	1.2	1.3	1.2	1.3	2.2	1.5	2.3	3.6	1.8	2.6	2.2	2.6
	PrecMin	5.2	0.0	0.0	0.0	0.0	0.2	0.1	0.1	0.1	0.3	0.0	0.0	0.1
	PrecStd	2.0	0.3	0.3	0.3	0.3	0.4	0.2	0.5	0.6	0.4	0.5	0.4	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.8	28.9	28.6	29.8	32.1	36.8	42.8	40.5	39.2	36.5	32.3	29.6
		MCWB	29.2	28.0	28.1	29.3	31.5	34.6	41.4	39.6	38.5	35.6	31.2	28.9
	2%	DB	27.2	24.9	24.5	25.0	30.3	34.9	39.3	38.7	37.9	33.9	30.5	27.8
		MCWB	26.5	24.3	23.9	24.3	29.7	33.6	38.2	38.1	37.5	33.5	29.5	27.3
	5%	DB	23.2	20.6	20.0	20.4	28.6	33.9	37.1	37.7	36.4	32.4	28.4	25.2
		MCWB	22.2	20.0	19.4	19.7	27.9	33.0	36.0	37.2	36.0	31.8	27.5	24.5
	10%	DB	17.6	14.4	14.2	15.8	26.5	33.2	35.9	36.7	34.9	30.7	25.5	19.8
		MCWB	16.9	13.8	13.7	15.0	25.7	32.4	35.1	36.2	34.4	29.9	24.6	19.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.3	28.0	28.2	29.3	31.8	35.0	41.9	40.0	38.7	35.8	31.7	29.2
		MCDB	29.5	28.7	28.5	29.7	31.8	35.7	42.8	40.3	38.9	36.4	32.2	29.4
	2%	WB	26.6	24.4	24.1	24.5	29.8	34.0	38.4	38.4	37.7	33.6	29.7	27.3
		MCDB	27.1	25.0	24.5	24.9	30.2	34.5	39.1	38.6	37.9	33.8	30.3	27.7
	5%	WB	22.3	20.1	19.5	19.8	28.0	33.3	36.4	37.4	36.0	32.0	27.6	24.5
		MCDB	23.1	20.7	20.1	20.4	28.5	33.7	36.9	37.6	36.2	32.2	28.3	25.2
	10%	WB	16.9	13.9	13.7	15.1	25.8	32.7	35.2	36.3	34.5	30.1	24.5	19.0
		MCDB	17.7	14.4	14.3	15.8	26.4	33.1	35.6	36.6	34.7	30.6	25.6	19.7
Mean Daily Temperature Range	5% DB	MDBR	10.8	10.4	10.3	10.1	6.6	3.7	3.2	3.1	3.7	6.5	9.2	10.0
		MCDBR	12.9	14.7	14.0	11.7	6.7	3.7	4.8	4.1	3.5	4.3	6.7	10.5
		MCWBR	13.1	14.7	14.0	11.8	6.7	3.4	4.1	3.9	3.6	4.8	7.2	10.6
	5% WB	MCDBR	13.3	14.9	13.8	11.6	6.5	3.5	4.7	4.0	3.5	4.1	6.8	10.7
		MCWBR	13.5	14.9	13.9	11.8	6.5	3.4	4.2	3.8	3.6	4.8	7.2	10.8
Clear-Sky Solar Irradiance	taub	N/A	N/A	0.248	0.288	0.312	0.305	0.324	0.321	0.266	N/A	N/A	N/A	N/A
	taud	N/A	N/A	1.924	1.999	2.039	2.215	2.367	2.441	2.289	N/A	N/A	N/A	N/A
	Ebn at Noon	0	0	152	228	249	262	251	228	168	0	0	0	0
	Edh at Noon	0	0	16	30	36	32	26	20	12	0	0	0	0
All-Sky Solar Radiation	RadAvg	0	0	256	1059	1722	1962	1504	751	233	0	0	0	0
	RadStd	0	0	27	86	79	154	202	122	38	0	0	0	0

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+3.98	+6.59	+5.67	N/A	N/A	+0.94	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page