

MYS ZHELANIYA, Russian Federation

WMO: 203530

Lat: 76.951N

Lon: 68.545E

Elev: 26

StdP: 14.68

Time Zone: 3.00 (E03)

Period: 86-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.4	-25.0	-31.9	0.9	-27.0	-29.3	1.1	-24.8	50.2	5.6	47.7	0.5	13.8	290	1.217

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	47.5	43.1	44.2	41.0	41.9	39.4	43.7	47.3	41.3	43.7	39.6	41.6	11.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
40.6	37.3	44.2	39.0	35.0	42.3	37.6	33.1	40.8	17.0	47.4	15.9	44.0	15.1	41.8	55.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	47.6	42.7	37.3	DB	-28.4	55.3	8.3	4.0	-34.4	58.2	-39.2	60.5	-43.9	62.7	-49.9	65.6
(5)				WB	-28.6	48.5	8.2	3.7	-34.5	51.2	-39.3	53.3	-43.9	55.4	-49.9	58.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.6	-2.9	-2.7	0.5	5.7	20.3	30.8	35.8	36.4	32.8	21.2	8.6	-0.2
	DBStd	18.48	13.51	15.15	14.64	12.90	7.43	4.17	3.78	3.87	5.15	9.26	12.96	14.55
	HDD50	12545	1640	1476	1533	1329	922	577	441	422	515	892	1241	1557
	HDD65	18020	2105	1896	1998	1779	1387	1027	906	887	965	1357	1691	2022
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.5	18.7	18.6	19.3	16.6	15.0	13.8	14.1	13.6	14.2	16.3	17.8	19.5
Precipitation	PrecAvg	17.8	1.3	1.3	1.2	1.1	1.1	1.2	1.6	2.1	2.0	2.2	1.4	1.3
	PrecMax	25.6	2.5	2.6	2.6	2.1	2.0	2.4	4.2	3.4	3.4	3.7	2.9	2.7
	PrecMin	10.3	0.6	0.5	0.5	0.4	0.6	0.4	0.5	0.5	0.9	0.9	0.4	0.3
	PrecStd	3.7	0.5	0.5	0.5	0.4	0.3	0.5	0.7	0.7	0.7	0.6	0.6	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.0	30.6	31.2	36.6	39.6	46.0	53.7	53.6	49.1	38.3	33.9	32.3
		MCWB	29.6	29.6	29.7	34.5	35.6	41.3	46.6	46.9	44.7	36.4	32.6	30.0
	2%	DB	27.4	27.7	29.1	30.5	34.6	41.0	48.2	46.4	44.8	35.8	31.6	29.7
		MCWB	25.7	26.4	27.7	29.0	32.4	38.2	43.3	42.5	41.2	34.1	30.2	27.9
	5%	DB	24.6	24.7	26.7	27.6	31.7	37.8	43.8	43.6	41.6	33.5	29.6	26.7
		MCWB	23.5	23.4	25.3	26.1	30.2	35.6	40.5	41.0	39.2	31.9	28.4	25.2
	10%	DB	18.6	20.5	23.2	24.9	29.8	35.6	41.2	41.6	39.6	32.1	27.1	23.4
		MCWB	17.2	19.2	21.8	23.5	28.6	33.7	38.6	39.6	37.9	30.7	25.7	21.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.5	29.7	30.4	34.9	35.9	42.1	49.1	47.2	45.1	36.6	33.0	30.6
		MCDB	30.8	30.4	31.2	36.8	38.7	45.9	52.8	51.5	48.6	37.9	33.8	32.1
	2%	WB	25.9	26.5	27.8	29.3	32.7	38.3	43.9	43.0	41.5	34.2	30.5	28.0
		MCDB	27.1	27.3	29.0	30.5	34.4	40.8	48.2	45.6	44.1	35.4	31.4	29.5
	5%	WB	23.2	23.3	25.2	26.3	30.4	35.7	40.8	41.2	39.5	32.2	28.6	25.3
		MCDB	24.8	24.6	26.7	27.5	31.5	37.6	43.4	43.2	41.4	33.2	29.6	26.8
	10%	WB	17.2	19.2	21.9	23.4	28.6	33.9	38.8	39.8	38.1	30.7	25.7	21.9
		MCDB	18.5	20.4	23.2	24.9	29.6	35.3	41.0	41.5	39.7	32.0	27.0	23.4
Mean Daily Temperature Range	5% DB	MDBR	10.3	10.7	11.1	10.9	6.5	4.7	5.5	5.0	4.8	6.6	8.5	9.3
		MCDBR	11.8	14.3	14.3	13.8	9.1	8.6	11.8	9.4	7.6	7.8	10.1	8.2
		MCWBR	11.8	14.1	14.1	13.0	8.0	6.6	8.5	6.8	5.6	7.9	9.8	7.8
	5% WB	MCDBR	11.8	14.4	14.8	13.5	8.7	8.2	11.1	8.7	7.0	7.7	9.7	8.3
		MCWBR	11.8	14.3	14.8	12.9	7.8	6.5	8.6	6.6	5.3	7.7	9.7	8.0
Clear-Sky Solar Irradiance	taub	N/A	0.196	0.269	0.298	0.323	0.316	0.336	0.325	0.280	0.360	N/A	N/A	
	taud	N/A	1.877	1.998	2.062	2.099	2.286	2.368	2.404	2.317	2.699	N/A	N/A	
	Ebn at Noon	0	28	174	237	253	265	252	234	187	38	0	0	
	Edh at Noon	0	3	19	30	36	31	28	23	15	4	0	0	
All-Sky Solar Radiation	RadAvg	0	14	299	1007	1467	1662	1285	749	287	40	0	0	
	RadStd	0	2	49	135	176	261	165	75	23	4	0	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page