

IZVESTIJ TSIK, Russian Federation

WMO: 204710

Lat: 75.952N

Lon: 82.946E

Elev: 39

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-32.4	-29.2	-37.8	0.6	-32.3	-34.5	0.8	-29.1	35.0	-2.0	31.4	1.4	7.0	60	1.153

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.0	47.4	45.8	45.5	44.3	43.7	42.7	46.2	47.3	44.5	45.4	42.8	43.6	13.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
45.3	44.8	46.6	43.7	42.0	45.1	42.0	39.4	43.5	18.3	47.4	17.4	45.5	16.6	43.7	51.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.2	30.2	27.1	DB	-32.7	49.0	6.8	5.1	-37.6	52.6	-41.6	55.6	-45.5	58.5	-50.4	62.2	(4)
(5)			WB	-32.9	46.1	6.8	4.1	-37.8	49.1	-41.8	51.4	-45.6	53.7	-50.5	56.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	-8.3	-9.4	-3.7	4.5	18.1	31.4	36.2	37.9	34.8	25.0	6.5	-2.7
	DBStd	19.84	12.94	12.77	12.90	9.14	7.34	2.64	4.48	4.00	4.07	7.40	11.61	11.42
	HDD50	13022	1808	1663	1666	1366	990	558	428	374	456	775	1304	1634
	HDD65	18497	2273	2083	2131	1816	1455	1008	893	839	906	1240	1754	2099
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	13.5	12.6	12.1	13.4	12.1	13.3	12.9	12.6	13.7	14.5	16.0	14.2	14.5
Precipitation	PrecAvg	11.6	0.6	0.6	0.5	0.4	0.4	0.9	1.3	2.0	1.9	1.5	0.8	0.7
	PrecMax	18.5	1.5	1.4	1.4	1.6	1.0	2.5	4.0	3.6	3.6	3.7	1.9	1.5
	PrecMin	4.0	0.0	0.0	0.0	0.0	0.2	0.4	0.4	0.6	0.6	0.3	0.1	0.1
	PrecStd	3.3	0.3	0.4	0.3	0.3	0.2	0.4	0.7	0.8	0.8	0.8	0.5	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.9	23.0	29.1	32.2	33.0	40.2	50.7	49.7	45.7	38.1	29.9	27.9
		MCWB	30.7	22.8	28.8	31.7	31.7	38.6	48.3	47.5	45.1	36.9	29.2	27.2
	2%	DB	23.7	19.4	26.6	25.6	31.3	38.2	48.1	47.2	43.8	36.8	27.5	25.0
		MCWB	23.6	19.1	26.3	24.9	30.5	37.0	46.2	45.9	43.2	35.9	26.7	24.6
	5%	DB	16.9	14.2	22.3	21.2	30.0	36.6	46.1	45.7	42.3	35.6	25.0	20.4
		MCWB	16.5	13.8	22.1	20.1	29.3	35.7	44.4	44.7	41.7	34.9	24.2	19.9
	10%	DB	9.5	9.4	18.4	17.9	28.5	35.2	43.8	44.0	40.8	33.8	22.7	15.3
		MCWB	9.1	8.9	18.0	17.3	27.8	34.4	42.5	43.1	40.2	33.0	21.8	14.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.9	22.9	28.9	31.8	32.4	38.8	49.0	47.6	45.3	37.6	29.3	27.6
		MCDB	30.9	23.2	29.0	32.3	32.7	39.8	50.4	48.7	45.6	37.8	29.5	27.9
	2%	WB	23.7	19.3	26.1	24.9	30.4	37.3	46.5	46.2	43.4	36.0	26.7	24.4
		MCDB	23.9	19.5	26.4	25.6	30.7	38.0	48.0	47.0	43.6	36.5	27.1	24.8
	5%	WB	16.6	13.9	22.1	20.3	29.2	35.9	44.6	44.8	41.9	35.0	24.3	19.9
		MCDB	16.8	14.3	22.3	21.1	29.7	36.4	46.0	45.5	42.3	35.6	25.0	20.3
	10%	WB	9.2	9.0	18.1	17.3	27.6	34.7	42.5	43.2	40.3	33.1	21.8	14.8
		MCDB	9.4	9.4	18.5	18.1	28.3	35.1	43.8	43.9	40.8	33.7	22.5	15.2
Mean Daily Temperature Range	5% DB	MDBR	10.2	10.5	10.9	10.1	7.0	3.7	4.8	4.0	3.2	4.3	8.9	9.3
		MCDBR	13.7	16.2	11.8	10.0	6.0	5.1	7.8	5.8	3.6	3.3	8.6	13.1
		MCWBR	14.0	16.3	11.9	9.8	5.9	4.6	7.0	5.1	3.7	3.3	8.6	13.1
	5% WB	MCDBR	13.8	16.2	11.6	10.1	6.1	4.9	7.8	5.7	3.7	2.8	9.0	13.1
		MCWBR	14.1	16.3	11.7	9.9	6.0	4.6	7.1	5.3	3.9	3.1	9.1	13.2
Clear-Sky Solar Irradiance	taub	N/A	0.184	0.267	0.298	0.319	0.319	0.347	0.336	0.296	0.355	N/A	N/A	
	taud	N/A	1.843	1.941	1.989	2.041	2.256	2.352	2.448	2.376	2.698	N/A	N/A	
	Ebn at Noon	0	51	181	239	256	266	251	235	192	56	0	0	
	Edh at Noon	0	4	22	34	38	32	29	22	15	4	0	0	
All-Sky Solar Radiation	RadAvg	0	24	385	1169	1765	1851	1417	780	295	49	0	0	
	RadStd	0	2	32	72	102	198	187	110	31	6	0	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page