

MYS STERLEGOVA, Russian FederationWMO: **204760**Lat: **75.404N**Lon: **88.911E**Elev: **36**StdP: **14.68**Time Zone: **7.00 (E07)**Period: **90-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-43.2	-40.3	-47.9	0.3	-42.9	-44.7	0.4	-39.8	42.8	-10.7	39.0	-8.3	6.2	130	1.182

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.8	57.4	52.5	52.7	49.5	48.5	46.3	52.9	57.2	49.7	52.7	46.4	48.4	13.6	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
50.2	53.9	54.8	47.0	47.7	51.8	44.6	43.6	48.6	21.9	57.6	20.1	53.0	18.4	48.5	64.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.7	32.9	28.8	-45.1	65.8	5.7	5.1	-49.2	69.5	-52.6	72.5	-55.8	75.3	-59.9	79.0		
(5)			-45.5	58.7	5.3	3.7	-49.3	61.3	-52.4	63.5	-55.4	65.5	-59.3	68.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-18.2	-19.1	-12.2	-1.2	15.3	32.5	37.8	38.6	33.4	15.5	-3.6	-13.7		
	DBStd	24.60	12.79	14.20	16.46	13.08	9.19	5.70	7.02	6.52	6.85	12.04	13.60	13.96		
	HDD50	15021	2113	1936	1930	1537	1076	526	392	357	500	1071	1607	1976		
	HDD65	20476	2578	2356	2395	1987	1541	975	844	817	949	1536	2057	2441		
	CDD50	19	0	0	0	0	0	1	12	5	1	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	13.5	14.6	14.0	13.9	12.9	12.9	12.2	11.5	12.9	13.3	14.8	13.5	15.0		
	PrecAvg	8.7	1.1	0.7	0.6	0.5	0.5	0.6	0.7	0.9	0.8	0.8	0.6	0.8		
(15) Precipitation	PrecMax	15.2	4.8	2.2	1.8	1.5	1.1	1.7	2.4	3.0	2.1	1.9	1.7	3.6		
	PrecMin	3.5	0.0	0.0	0.0	0.0	0.2	0.0	0.2	0.1	0.1	0.1	0.2	0.1		
	PrecStd	3.8	1.2	0.6	0.4	0.4	0.2	0.4	0.5	0.7	0.6	0.4	0.4	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.3	21.3	27.9	33.6	35.0	57.0	66.4	60.3	52.9	37.4	28.7	28.2		
		MCWB	19.0	20.4	26.9	32.3	33.8	51.6	58.3	55.3	49.4	36.6	27.8	27.3		
	2%	DB	11.1	15.0	25.2	28.2	33.1	49.8	60.1	55.8	47.7	34.7	25.0	25.1		
		MCWB	10.5	14.1	24.5	27.5	32.2	46.5	53.8	52.9	45.7	33.7	24.4	24.5		
	5%	DB	6.0	7.5	21.5	22.6	30.9	43.3	54.6	51.4	44.7	32.9	21.8	15.1		
		MCWB	5.3	7.0	21.0	21.9	29.9	41.0	50.4	48.9	43.3	31.9	21.1	14.2		
	10%	DB	1.0	2.0	14.4	16.5	28.4	39.4	49.2	48.0	42.4	31.3	16.4	5.4		
		MCWB	0.5	1.4	13.7	15.5	27.2	37.8	46.6	46.1	41.1	30.4	15.7	4.8		
	0.4%	WB	18.8	20.7	27.5	32.0	34.1	52.0	59.6	56.5	50.2	36.7	28.3	27.7		
		MCDB	19.0	21.2	28.1	33.7	34.7	55.9	64.9	59.1	53.1	37.1	29.3	27.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	10.5	14.2	24.6	27.6	32.2	46.6	53.7	52.6	46.1	33.9	24.4	24.4		
		MCDB	10.9	15.0	25.1	28.1	32.8	49.7	59.5	55.5	47.7	34.5	24.9	25.2		
	5%	WB	5.3	7.0	21.0	22.0	29.9	41.2	50.5	49.2	43.5	32.2	21.1	14.4		
		MCDB	5.9	7.4	21.6	22.6	30.7	43.2	54.7	51.1	44.5	32.8	21.8	15.1		
	10%	WB	0.3	1.6	13.8	15.7	27.2	37.9	46.6	46.1	41.4	30.4	15.7	4.7		
		MCDB	0.8	2.1	14.4	16.5	28.3	39.2	49.1	47.7	42.5	31.2	16.6	5.3		
	5% DB	MDBR	10.7	11.5	12.8	13.0	9.5	6.1	8.4	6.8	5.8	8.8	11.4	10.7		
		MCDBR	15.0	20.9	13.5	13.3	8.6	13.8	20.2	12.8	8.7	4.7	13.2	16.9		
		MCWBR	15.1	20.7	12.9	12.8	8.4	11.2	14.7	10.4	7.8	4.8	13.1	16.8		
		MCWBR	16.0	20.6	13.4	13.1	8.3	13.4	19.4	12.5	8.2	5.2	13.8	16.9		
(35) Mean Daily Temperature Range	5% WB	MCWBR	15.9	20.4	13.2	12.6	8.4	11.1	14.7	10.5	7.6	5.4	13.7	16.7		
	Clear-Sky Solar Irradiance	taub	N/A	0.182	0.273	0.304	0.325	0.325	0.354	0.337	0.295	N/A	N/A	N/A		
		taud	N/A	1.867	1.980	2.032	2.082	2.282	2.345	2.433	2.366	N/A	N/A	N/A		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	0	67	185	240	256	265	249	236	195	N/A	0	0		
		Edh at Noon	0	5	22	33	37	32	29	23	16	N/A	0	0		
(44) All-Sky Solar Radiation	RadStd		0	25	384	1178	1877	1762	1384	828	319	59	0	0		
			0	3	38	66	122	265	134	105	27	10	0	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page