

MYS STERLEGOVA, Russian Federation

WMO: 204760

Lat: 75.404N

Lon: 88.911E

Elev: 11

StdP: 101.19

Time Zone: 7.00 (E07)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-41.8	-40.1	-44.4	0.0	-41.6	-42.6	0.1	-39.9	19.1	-23.7	17.4	-22.4	2.8	130	1.182

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.8	14.1	11.4	11.5	9.7	9.2	7.9	11.6	14.0	9.8	11.5	8.0	9.1	6.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.1	7.7	12.7	8.3	6.8	11.0	7.0	6.2	9.2	33.1	14.2	28.9	11.6	24.8	9.2	18.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	14.7	12.9	DB	-42.8	18.8	3.2	2.8	-45.1	20.8	-47.0	22.5	-48.8	24.1	-51.1	26.1	(4)
(5)			WB	-43.1	14.8	3.0	2.0	-45.2	16.3	-46.9	17.5	-48.6	18.6	-50.7	20.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-12.8	-27.9	-28.4	-24.6	-18.5	-9.3	0.3	3.2	3.7	0.8	-9.2	-19.8	-25.4	(6)
(7)		DBStd	13.67	7.10	7.89	9.14	7.27	5.11	3.17	3.90	3.62	3.81	6.69	7.55	7.76	(7)
(8)		HDD10.0	8345	1174	1076	1072	854	598	292	218	198	278	595	893	1098	(8)
(9)		HDD18.3	11376	1432	1309	1331	1104	856	542	469	454	527	853	1143	1356	(9)
(10)		CDD10.0	11	0	0	0	0	0	1	7	3	1	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.0	6.5	6.3	6.2	5.8	5.8	5.5	5.1	5.8	6.0	6.6	6.0	6.7	(14)
(15)	Precipitation	PrecAvg	220	27	17	16	12	12	15	19	22	21	20	14	20	(15)
(16)		PrecMax	386	121	57	46	37	29	42	60	76	54	49	44	92	(16)
(17)		PrecMin	89	1	0	1	1	5	1	4	2	3	2	4	2	(17)
(18)		PrecStd	96	31	16	11	10	6	10	13	18	14	10	9	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-7.1	-5.9	-2.3	0.9	1.7	13.9	19.1	15.7	11.6	3.0	-1.8	-2.1	(19)
(20)			MCWB	-7.2	-6.4	-2.8	0.2	1.0	10.9	14.6	12.9	9.7	2.5	-2.3	-2.6	(20)
(21)		2%	DB	-11.6	-9.5	-3.8	-2.1	0.6	9.9	15.6	13.2	8.7	1.5	-3.9	-3.9	(21)
(22)			MCWB	-12.0	-9.9	-4.1	-2.5	0.1	8.1	12.1	11.6	7.6	0.9	-4.2	-4.2	(22)
(23)		5%	DB	-14.5	-13.6	-5.8	-5.2	-0.6	6.3	12.6	10.8	7.0	0.5	-5.7	-9.4	(23)
(24)			MCWB	-14.8	-13.9	-6.1	-5.6	-1.2	5.0	10.2	9.4	6.3	-0.1	-6.0	-9.9	(24)
(25)		10%	DB	-17.2	-16.7	-9.8	-8.6	-2.0	4.1	9.6	8.9	5.8	-0.4	-8.7	-14.8	(25)
(26)			MCWB	-17.5	-17.0	-10.2	-9.1	-2.7	3.2	8.1	7.8	5.1	-0.9	-9.1	-15.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-7.4	-6.3	-2.5	0.0	1.2	11.1	15.4	13.6	10.1	2.6	-2.0	-2.4	(27)
(28)			MDCB	-7.2	-6.0	-2.2	0.9	1.5	13.3	18.3	15.1	11.7	2.8	-1.5	-2.3	(28)
(29)		2%	WB	-11.9	-9.9	-4.1	-2.4	0.1	8.1	12.1	11.5	7.9	1.1	-4.2	-4.2	(29)
(30)			MDCB	-11.7	-9.5	-3.8	-2.2	0.4	9.8	15.3	13.0	8.7	1.4	-3.9	-3.8	(30)
(31)		5%	WB	-14.8	-13.9	-6.1	-5.6	-1.2	5.1	10.3	9.5	6.4	0.1	-6.1	-9.8	(31)
(32)			MDCB	-14.5	-13.6	-5.8	-5.2	-0.7	6.2	12.6	10.6	6.9	0.5	-5.7	-9.4	(32)
(33)		10%	WB	-17.6	-16.9	-10.1	-9.0	-2.6	3.3	8.1	7.8	5.2	-0.9	-9.1	-15.1	(33)
(34)			MDCB	-17.3	-16.6	-9.8	-8.6	-2.0	4.0	9.5	8.7	5.9	-0.4	-8.6	-14.9	(34)
(35)	Mean Daily Temperature Range	MDBR	5.9	6.4	7.1	7.2	5.3	3.4	4.7	3.8	3.2	4.9	6.3	5.9	(35)	
(36)		5% DB	MCDBR	8.3	11.6	7.5	7.4	4.8	7.7	11.2	7.1	4.8	2.6	7.3	9.4	(36)
(37)			MCWBR	8.4	11.5	7.2	7.1	4.7	6.2	8.2	5.8	4.3	2.7	7.3	9.3	(37)
(38)		5% WB	MCDBR	8.9	11.4	7.4	7.3	4.6	7.4	10.8	6.9	4.5	2.9	7.7	9.4	(38)
(39)			MCWBR	8.8	11.3	7.4	7.0	4.6	6.2	8.2	5.8	4.2	3.0	7.6	9.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.182	0.273	0.304	0.325	0.325	0.354	0.337	0.295	N/A	N/A	N/A	(40)	
(41)		taud	N/A	1.867	1.980	2.032	2.082	2.282	2.345	2.433	2.366	N/A	N/A	N/A	(41)	
(42)		Ebn at Noon	0	211	584	756	807	834	786	745	616	N/A	0	0	(42)	
(43)		Edh at Noon	0	16	68	103	117	101	92	72	49	N/A	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.00	0.08	1.21	3.71	5.92	5.55	4.36	2.61	1.01	0.19	0.00	0.00	(44)	
(45)		RadStd	0.00	0.01	0.12	0.21	0.39	0.84	0.42	0.33	0.09	0.03	0.00	0.00	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page