

LAKE TAYMYR, Russian Federation

WMO: 205940

Lat: 74.500N

Lon: 102.500E

Elev: 36

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 82-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-48.4	-45.8	-52.2	0.3	-48.2	-49.5	0.3	-45.8	40.3	5.0	33.7	-12.1	6.9	90	1.176

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	56.1	51.2	52.7	48.8	50.0	46.8	51.5	55.1	49.2	52.4	47.1	49.7	9.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
49.3	52.0	53.3	46.9	47.6	50.7	45.0	44.1	49.1	21.2	55.2	19.9	52.6	18.8	49.7	59.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
36.4	31.5	27.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB												
			WB	-51.4	54.8	6.2	3.6	-55.9	57.4	-59.5	59.6	-63.0	61.6	-67.5	64.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.3	-25.2	-25.4	-20.2	-6.5	14.6	32.8	43.4	42.0	31.9	8.2	-13.6	-20.0
	DBStd	28.02	13.68	13.81	13.96	12.80	9.06	6.42	5.29	5.03	6.73	12.84	11.43	12.59
	HDD50	16312	2332	2110	2177	1694	1097	516	217	251	544	1296	1908	2170
	HDD65	21771	2797	2530	2642	2144	1562	966	670	712	994	1761	2358	2635
	CDD50	15	0	0	0	0	0	0	11	4	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	12.2	10.7	10.7	11.1	13.6	11.2	12.6	11.8	13.4	13.0	13.9	12.4	12.3
	PrecAvg	14.6	1.0	0.8	0.8	0.9	1.1	1.1	1.7	1.9	1.6	1.7	1.2	0.9
(15) Precipitation	PrecMax	18.1	2.7	1.6	1.5	2.5	2.4	3.7	2.8	3.8	3.0	3.4	2.2	1.9
	PrecMin	9.2	0.1	0.2	0.3	0.0	0.1	0.3	0.4	0.4	0.4	0.8	0.2	0.3
	PrecStd	2.3	0.6	0.4	0.4	0.6	0.5	0.7	0.6	0.6	0.6	0.6	0.4	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.7	15.6	22.4	28.4	35.0	51.1	62.5	58.9	47.8	34.1	23.9	15.5
		MCWB	17.2	14.5	21.5	27.2	33.1	46.1	54.9	53.0	45.2	33.2	22.8	14.5
	2%	DB	8.5	9.0	15.8	23.1	32.9	45.8	57.9	54.4	44.7	32.4	14.6	9.3
		MCWB	7.8	8.4	15.1	22.3	31.5	41.8	52.2	50.3	42.5	31.7	13.9	8.5
	5%	DB	2.9	3.0	7.2	17.0	30.8	42.7	54.6	51.9	42.2	30.0	7.7	4.4
		MCWB	2.4	2.5	6.6	15.9	29.6	39.8	50.1	48.4	40.8	29.4	6.9	3.7
	10%	DB	-3.8	-4.3	0.4	11.5	27.9	40.1	51.5	49.8	40.3	26.4	2.0	-0.9
		MCWB	-4.3	-4.6	-0.2	10.6	26.5	37.5	48.0	46.9	38.7	25.4	1.4	-1.5
	0.4%	WB	16.9	14.4	21.9	27.6	33.2	46.8	57.0	54.3	45.8	33.6	23.0	14.2
		MCDB	17.1	15.2	22.6	28.4	34.4	51.3	62.9	57.5	47.2	33.9	23.8	15.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	7.8	8.4	15.1	22.3	31.6	42.5	52.7	50.9	42.9	31.8	13.9	8.4
		MCDB	8.4	8.8	16.0	23.2	32.6	45.1	56.4	53.7	44.1	32.4	14.4	9.0
	5%	WB	2.3	2.4	6.5	15.8	29.7	40.1	50.4	48.9	40.9	29.3	7.0	3.7
		MCDB	2.9	2.9	7.2	16.8	30.8	42.5	54.6	51.3	42.1	30.0	7.7	4.4
	10%	WB	-4.4	-4.9	-0.2	10.6	26.6	37.6	48.1	47.1	38.8	25.5	1.5	-1.4
		MCDB	-3.9	-4.6	0.5	11.4	27.8	39.8	51.3	49.4	40.1	26.4	2.0	-0.9
	5% DB	MDBR	10.9	11.3	13.2	13.2	10.6	6.1	7.7	7.1	6.0	9.4	10.7	11.2
		MCDBR	16.4	17.1	20.1	16.8	9.0	10.2	12.6	10.1	6.9	10.5	17.9	15.2
		MCWBR	15.9	16.2	19.3	16.2	8.3	7.6	8.9	7.4	5.9	10.8	17.6	14.9
		MCDBR	16.6	16.3	19.6	17.3	8.9	10.3	12.3	9.7	6.9	11.1	18.8	15.2
(38) Clear-Sky Solar Irradiance	taub		N/A	0.180	0.280	0.311	0.336	0.339	0.370	0.355	0.291	0.188	N/A	N/A
		taud	N/A	1.876	1.998	2.050	2.132	2.384	2.369	2.374	2.372	1.928	N/A	N/A
	Ebn at Noon		0	90	190	241	255	263	246	231	204	77	0	0
		Edh at Noon	0	7	23	33	36	30	29	25	16	5	0	0
(44) All-Sky Solar Radiation	RadAvg	0	29	360	1116	1631	1572	1473	853	349	69	0	0	0
	RadStd	0	2	41	96	129	160	119	122	34	8	0	0	0

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page