

LAKE TAYMYR, Russian Federation

WMO: 205940

Lat: 74.500N

Lon: 102.500E

Elev: 11

StdP: 101.19

Time Zone: 7.00 (E07)

Period: 82-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-44.7	-43.2	-46.8	0.0	-44.5	-45.3	0.0	-43.2	18.0	-15.0	15.1	-24.5	3.1	90	1.176

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.3	13.4	10.7	11.5	9.4	10.0	8.2	10.9	12.8	9.6	11.3	8.4	9.8	4.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.6	7.4	11.8	8.3	6.8	10.4	7.2	6.3	9.5	31.3	12.9	28.3	11.4	25.8	9.8	15.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	14.1	12.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	-46.3	12.7	3.4	2.0	-48.8	14.1	-50.8	15.3	-52.8	16.4	-55.3	17.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-14.8	-31.8	-31.9	-29.0	-21.4	-9.7	0.4	6.3	5.6	-0.1	-13.2	-25.3	-28.9
	DBStd	15.57	7.60	7.67	7.75	7.11	5.04	3.56	2.94	2.79	3.74	7.13	6.35	7.00
	HDD10.0	9062	1296	1172	1209	941	609	287	121	139	302	720	1060	1206
	HDD18.3	12095	1554	1406	1468	1191	868	537	372	396	552	978	1310	1464
	CDD10.0	8	0	0	0	0	0	0	6	2	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.5	4.8	4.8	5.0	6.1	5.0	5.6	5.3	6.0	5.8	6.2	5.5	5.5
Precipitation	PrecAvg	372	26	20	20	24	28	28	42	47	41	42	31	22
	PrecMax	460	69	41	39	64	61	95	71	96	76	87	57	49
	PrecMin	234	3	5	7	1	3	7	9	11	11	21	6	7
	PrecStd	58	16	10	10	14	13	19	15	16	16	15	10	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-7.9	-9.1	-5.3	-2.0	1.7	10.6	16.9	14.9	8.8	1.2	-4.5	-9.1
		MCWB	-8.2	-9.7	-5.8	-2.6	0.6	7.8	12.7	11.6	7.3	0.6	-5.1	-9.7
	2%	DB	-13.1	-12.8	-9.0	-4.9	0.5	7.6	14.4	12.5	7.0	0.2	-9.7	-12.6
		MCWB	-13.5	-13.1	-9.4	-5.4	-0.3	5.4	11.2	10.2	5.8	-0.2	-10.0	-13.0
	5%	DB	-16.1	-16.1	-13.8	-8.3	-0.7	5.9	12.6	11.1	5.7	-1.1	-13.5	-15.3
		MCWB	-16.4	-16.4	-14.1	-8.9	-1.3	4.4	10.1	9.1	4.9	-1.5	-14.0	-15.7
	10%	DB	-19.9	-20.1	-17.5	-11.4	-2.3	4.5	10.8	9.9	4.6	-3.1	-16.6	-18.3
		MCWB	-20.2	-20.4	-17.9	-11.9	-3.0	3.0	8.9	8.3	3.7	-3.7	-17.0	-18.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-8.4	-9.8	-5.6	-2.5	0.7	8.2	13.9	12.4	7.7	0.9	-5.0	-9.9
		MCDB	-8.3	-9.3	-5.2	-2.0	1.3	10.7	17.2	14.2	8.5	1.1	-4.5	-9.4
	2%	WB	-13.4	-13.1	-9.4	-5.4	-0.2	5.8	11.5	10.5	6.0	-0.1	-10.1	-13.1
		MCDB	-13.1	-12.9	-8.9	-4.9	0.3	7.3	13.5	12.0	6.7	0.2	-9.8	-12.8
	5%	WB	-16.5	-16.5	-14.2	-9.0	-1.3	4.5	10.2	9.4	4.9	-1.5	-13.9	-15.7
		MCDB	-16.2	-16.2	-13.8	-8.4	-0.7	5.9	12.6	10.7	5.6	-1.1	-13.5	-15.3
	10%	WB	-20.2	-20.5	-17.9	-11.9	-3.0	3.1	9.0	8.4	3.8	-3.6	-17.0	-18.6
		MCDB	-19.9	-20.3	-17.5	-11.4	-2.3	4.3	10.7	9.7	4.5	-3.1	-16.7	-18.3
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.3	7.3	7.3	5.9	3.4	4.3	4.0	3.3	5.2	5.9	6.2
		MCDBR	9.1	9.5	11.2	9.3	5.0	5.7	7.0	5.6	3.8	5.8	10.0	8.5
		MCWBR	8.9	9.0	10.7	9.0	4.6	4.2	5.0	4.1	3.3	6.0	9.8	8.3
	5% WB	MCDBR	9.2	9.1	10.9	9.6	4.9	5.7	6.9	5.4	3.8	6.1	10.4	8.5
		MCWBR	9.0	8.9	10.8	9.3	4.7	4.3	5.1	4.4	3.6	6.3	10.0	8.3
Clear-Sky Solar Irradiance	taub	N/A	0.180	0.280	0.311	0.336	0.339	0.370	0.355	0.291	0.188	N/A	N/A	
	taud	N/A	1.876	1.998	2.050	2.132	2.384	2.369	2.374	2.372	1.928	N/A	N/A	
	Ebn at Noon	0	285	600	760	804	830	777	728	643	243	0	0	
	Edh at Noon	0	21	71	104	113	93	91	78	51	17	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.09	1.14	3.52	5.14	4.96	4.64	2.69	1.10	0.22	0.00	0.00	
	RadStd	0.00	0.01	0.13	0.30	0.41	0.50	0.37	0.38	0.11	0.02	0.00	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page