

OSTROV DIKSON, Russian Federation

WMO: 206740

Lat: 73.514N

Lon: 80.406E

Elev: 152

StdP: 14.62

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-37.2	-33.9	-41.8	0.5	-36.8	-38.4	0.6	-33.7	44.0	-11.2	39.0	-8.8	9.4	190	1.136

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	60.2	55.0	55.9	52.3	52.0	49.5	55.5	59.8	52.4	55.6	49.6	51.9	9.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
53.2	60.5	57.7	50.3	54.4	54.2	47.7	49.2	51.6	23.6	60.1	21.7	56.2	20.2	52.1	67.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.5	33.2	29.7	-38.8	65.3	5.1	5.1	-42.4	68.9	-45.4	71.9	-48.2	74.7	-51.9	78.4		
(5)			-38.9	58.5	5.0	3.9	-42.5	61.3	-45.5	63.5	-48.3	65.7	-52.0	68.5	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	-10.5	-11.5	-5.1	4.5	19.1	34.2	42.6	42.9	36.2	21.1	2.0	-6.6
	DBStd	22.82	13.71	14.18	13.66	11.21	7.74	5.61	7.09	5.62	5.91	10.71	11.57	13.98
	HDD50	13097	1876	1722	1707	1365	957	478	256	232	414	895	1439	1756
	HDD65	18529	2341	2142	2172	1815	1422	925	695	684	863	1360	1889	2221
	CDD50	44	0	0	0	0	0	3	26	13	2	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.3	15.5	15.0	14.4	14.1	14.0	13.6	12.7	13.1	13.8	15.1	14.1	16.1
Precipitation	PrecAvg	14.1	1.5	1.1	0.9	0.7	0.8	1.1	1.4	1.7	1.7	1.3	0.9	1.3
	PrecMax	22.1	8.7	3.9	2.8	1.9	1.9	2.4	2.8	3.2	3.3	2.9	2.1	3.2
	PrecMin	7.1	0.1	0.0	0.1	0.0	0.1	0.2	0.2	0.4	0.4	0.1	0.0	0.2
	PrecStd	3.4	1.4	0.7	0.6	0.5	0.5	0.5	0.7	0.7	0.6	0.6	0.6	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.1	26.9	28.9	33.8	37.1	59.6	68.8	63.1	54.9	39.6	30.5	27.8
		MCWB	25.3	26.2	28.3	32.8	34.7	52.1	59.2	56.4	52.3	38.6	30.1	27.2
	2%	DB	21.4	22.5	24.9	29.9	33.1	51.4	63.0	57.8	49.5	37.0	27.1	25.0
		MCWB	20.7	22.0	24.2	28.9	32.1	47.2	56.5	54.3	47.8	35.8	26.5	24.6
	5%	DB	16.2	17.0	20.7	26.4	31.7	45.6	58.1	54.5	46.4	34.9	23.4	20.5
		MCWB	15.5	16.3	20.1	25.4	31.1	43.2	53.6	51.9	45.2	34.0	22.8	20.1
	10%	DB	9.7	9.3	15.8	21.9	29.8	41.2	53.4	51.3	43.7	33.1	19.5	14.4
		MCWB	9.2	8.8	15.3	21.0	29.0	39.5	50.0	49.3	42.5	32.2	18.9	13.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.4	26.6	28.4	32.9	34.8	52.5	60.1	57.3	52.4	39.1	30.0	27.5
		MCDB	26.0	27.1	28.8	33.7	36.4	58.5	66.0	61.0	54.5	39.3	30.2	27.8
	2%	WB	20.8	22.1	24.3	29.2	32.4	47.7	57.0	54.9	48.4	36.0	26.7	24.6
		MCDB	21.4	22.5	24.9	29.9	33.1	50.9	62.3	57.8	49.5	36.8	27.1	24.9
	5%	WB	15.6	16.4	20.1	25.4	31.1	43.3	53.6	52.0	45.3	34.2	22.9	20.1
		MCDB	16.2	17.0	20.6	26.3	31.7	45.5	58.2	53.9	46.2	34.8	23.3	20.5
	10%	WB	9.1	8.8	15.3	21.0	29.0	39.5	50.3	49.5	42.7	32.4	18.7	13.9
		MCDB	9.6	9.3	15.8	22.0	29.7	41.0	53.2	51.2	43.6	33.0	19.3	14.4
Mean Daily Temperature Range	5% DB	MDBR	11.2	11.2	11.4	10.7	7.2	5.4	7.5	6.0	4.6	6.7	10.1	10.4
		MCDBR	16.3	16.6	13.0	11.6	7.2	12.1	14.2	10.9	7.5	4.6	12.4	14.0
		MCWBR	16.2	16.6	12.9	11.6	7.0	9.4	9.8	8.2	6.4	5.0	12.4	13.8
	5% WB	MCDBR	16.3	16.5	12.8	11.7	7.2	11.9	13.7	10.0	7.1	4.6	12.4	14.1
		MCWBR	16.2	16.4	12.8	11.7	7.0	9.5	10.0	8.1	6.5	5.1	12.4	13.9
Clear-Sky Solar Irradiance	taub	N/A	0.193	0.279	0.304	0.326	0.335	0.362	0.345	0.304	0.356	N/A	N/A	
	taud	N/A	1.872	1.998	2.053	2.111	2.340	2.397	2.434	2.408	2.737	N/A	N/A	
	Ebn at Noon	0	103	199	247	261	266	252	239	207	101	0	0	
	Edh at Noon	0	8	23	34	37	31	29	24	17	7	0	0	
All-Sky Solar Radiation	RadAvg	0	43	445	1197	1801	1682	1369	830	357	79	0	0	
	RadStd	0	4	30	83	128	129	171	137	36	9	0	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			+2.86	+3.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)			+2.86	+3.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page